

NAMLEA BURU, Indonesia

WMO: 977000

Lat: 3.2388S

Lon: 127.0997E

Elev: 20

StdP: 101.08

Time Zone: 9.00 (E09)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	22.4	18.9	13.7	24.6	19.7	14.4	24.6	10.3	28.8	9.6	28.6	2.6	220	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.1	32.3	26.4	32.0	26.5	31.6	26.4	27.7	30.8	27.5	30.6	27.2	30.4	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.6	30.1	26.6	22.2	29.8	26.2	21.7	29.5	88.9	31.0	87.4	30.7	86.2	30.6	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.7	7.8	6.6	DB	18.5	33.8	2.5	1.5	16.7	34.8	15.3	35.7	13.9	36.5	12.1	37.6
			WB	17.6	28.6	2.0	0.8	16.1	29.2	15.0	29.6	13.8	30.1	12.4	30.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	27.2	27.1	27.2	27.5	27.5	26.9	26.3	26.4	26.9	27.7	28.0	27.7	(6)
	DBStd	0.94	0.86	0.65	0.82	0.63	0.73	0.91	0.93	0.88	0.79	0.81	0.66	0.74	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD10.0	6281	532	479	532	527	543	506	506	509	507	549	541	548	(10)
	CDD18.3	3239	274	246	273	277	285	256	248	251	257	291	291	290	(11)
	CDH23.3	31611	2626	2303	2551	2702	2887	2346	2089	2191	2507	3191	3257	2961	(12)
(13)	CDH26.7	9485	700	593	691	833	902	604	450	545	792	1194	1247	934	(13)
(14)	Wind	WSAvg	2.8	2.3	2.5	2.3	2.2	2.5	3.0	3.3	3.7	3.1	2.6	2.4	(14)
(15) Precipitation	PrecAvg	1747	277	274	211	150	103	127	120	79	37	54	82	217	(15)
	PrecMax	3136	582	648	433	389	282	267	475	529	126	159	526	1005	(16)
	PrecMin	918	54	85	80	31	13	5	6	0	2	1	3	47	(17)
	PrecStd	569	132	118	90	83	69	85	109	125	37	47	100	174	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	31.2	31.3	32.2	32.1	31.8	30.7	31.4	32.2	32.8	33.0	32.5	(19)
		MCWB	26.8	26.8	26.9	27.0	27.0	26.5	26.0	25.5	25.6	26.1	26.3	26.7	(20)
	2%	DB	30.8	30.7	30.9	31.5	31.5	31.1	30.1	30.6	31.4	32.2	32.3	31.7	(21)
		MCWB	26.7	26.6	26.8	27.0	26.8	26.3	25.5	25.2	25.4	26.2	26.5	26.7	(22)
	5%	DB	30.4	30.2	30.4	31.0	31.0	30.3	29.6	30.0	30.9	31.7	31.9	31.1	(23)
		MCWB	26.6	26.5	26.6	26.9	26.6	26.0	25.2	25.0	25.2	26.1	26.5	26.7	(24)
	10%	DB	29.9	29.7	29.9	30.5	30.5	29.7	29.1	29.4	30.3	31.2	31.4	30.6	(25)
		MCWB	26.4	26.3	26.4	26.7	26.5	25.8	24.9	24.7	25.1	26.0	26.4	26.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.7	27.7	28.2	27.8	27.2	26.6	26.5	26.9	28.1	28.0	27.8	(27)
		MCDB	30.0	30.3	30.4	31.0	30.9	30.7	29.9	30.2	31.0	31.7	31.1	30.8	(28)
	2%	WB	27.2	27.2	27.2	27.7	27.3	26.7	26.1	26.0	26.4	27.3	27.3	27.3	(29)
		MCDB	30.0	29.9	30.1	30.6	30.6	30.1	29.3	29.7	30.4	31.1	31.0	30.6	(30)
	5%	WB	26.9	26.7	26.9	27.2	27.0	26.4	25.7	25.5	26.0	26.7	26.9	27.0	(31)
		MCDB	29.7	29.4	29.8	30.3	30.4	29.6	28.7	29.1	29.9	30.6	30.9	30.4	(32)
	10%	WB	26.5	26.4	26.6	26.8	26.7	26.0	25.3	25.1	25.5	26.3	26.6	26.7	(33)
		MCDB	29.3	29.0	29.3	29.9	29.8	29.1	28.0	28.4	29.3	30.2	30.5	29.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.6	5.4	5.8	6.2	6.2	5.7	5.6	6.2	7.2	7.6	7.1	6.1	(35)
		MCDBR	6.2	6.0	6.3	6.6	6.8	6.7	6.3	7.0	7.9	8.0	7.6	6.8	(36)
		MCWBR	3.0	3.0	3.1	3.3	3.1	2.9	2.9	3.1	3.5	3.6	3.2	3.1	(37)
	5% WB	MCDBR	5.8	5.8	6.0	6.3	6.4	6.0	5.8	6.4	7.1	7.5	7.2	6.5	(38)
		MCWBR	3.1	3.0	3.2	3.4	3.1	2.9	2.9	3.1	3.3	3.8	3.3	3.1	(39)
(40) Clear-Sky Solar Irradiance	taub	0.416	0.422	0.417	0.405	0.413	0.422	0.417	0.417	0.417	0.426	0.454	0.439	0.424	(40)
	taud	2.488	2.462	2.477	2.529	2.515	2.487	2.497	2.483	2.442	2.344	2.394	2.454		(41)
	Ebn at Noon	919	914	908	895	863	840	851	872	886	874	891	907		(42)
	Edh at Noon	115	119	116	106	104	104	104	110	118	132	125	117		(43)
(44) All-Sky Solar Radiation	RadAvg	5.04	5.28	5.42	5.37	5.02	4.40	4.59	5.25	5.72	6.15	5.98	5.22		(44)
	RadStd	0.38	0.38	0.31	0.25	0.37	0.48	0.56	0.65	0.49	0.35	0.32	0.42		(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page