

AMBON PATTIMURA, Indonesia

WMO: 977240

Lat: 3.7111S

Lon: 128.0853E

Elev: 12

StdP: 101.18

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.0	22.6	20.0	14.7	25.1	20.5	15.2	25.2	6.4	25.7	5.8	26.1	1.5	340	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.0	33.1	26.0	32.4	25.9	31.9	25.9	27.1	30.9	26.8	30.6	26.6	30.4	3.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	29.4	25.7	21.0	29.1	25.5	20.7	28.9	85.7	31.1	84.4	30.9	83.4	30.6	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 5.8	5.2	4.6	DB	19.5	34.4	2.4	1.2	17.8	35.3	16.4	36.0	15.1	36.6	13.4	37.5	(4)
(5)			WB	17.8	28.6	2.3	1.2	16.1	29.5	14.8	30.1	13.5	30.8	11.8	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	27.8	27.7	27.7	27.5	26.9	26.1	25.5	25.5	26.0	27.0	27.6	27.9	(6)
(7)		DBStd	1.25	0.93	0.97	1.02	0.80	0.84	0.87	0.87	0.87	0.83	0.72	0.76	0.91	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6178	553	496	550	524	525	482	479	479	479	526	529	556	(10)
(11)		CDD18.3	3136	294	263	292	274	267	232	221	221	229	268	279	297	(11)
(12)		CDH23.3	29395	3116	2751	3068	2728	2446	1798	1513	1504	1828	2552	2919	3171	(12)
(13)		CDH26.7	8593	1137	996	1118	858	630	290	136	154	328	727	1033	1187	(13)
(14)	Wind	WSAvg	2.1	2.2	2.2	2.1	1.9	1.8	2.0	2.2	2.3	2.1	2.1	2.1	2.2	(14)
(15)	Precipitation	PrecAvg	2978	166	130	155	207	377	487	481	292	194	123	95	157	(15)
(16)		PrecMax	5552	299	319	296	523	1237	1333	1755	1262	674	272	177	296	(16)
(17)		PrecMin	1236	24	37	74	64	54	66	72	0	0	9	19	50	(17)
(18)		PrecStd	1071	64	71	55	94	239	308	371	294	165	69	48	62	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.5	33.8	33.5	32.6	31.7	30.5	29.8	30.0	30.7	31.6	33.1	34.0	(19)
(20)			MCWB	25.8	25.6	25.7	26.2	26.6	25.7	25.4	25.3	26.0	26.3	26.6	26.4	(20)
(21)		2%	DB	32.6	32.7	32.5	31.6	30.8	29.8	28.9	29.0	29.7	30.9	32.1	32.9	(21)
(22)			MCWB	25.7	25.7	25.7	26.2	26.4	25.5	25.0	24.9	25.4	25.9	26.3	26.2	(22)
(23)		5%	DB	31.9	31.9	31.8	31.0	30.2	29.1	28.1	28.2	29.1	30.2	31.4	32.0	(23)
(24)			MCWB	25.7	25.6	25.7	26.1	26.1	25.4	24.6	24.4	25.0	25.7	26.1	26.1	(24)
(25)		10%	DB	31.1	31.0	31.1	30.4	29.6	28.4	27.4	27.5	28.5	29.8	30.8	31.2	(25)
(26)			MCWB	25.7	25.6	25.7	26.0	25.9	25.2	24.3	24.1	24.8	25.6	26.0	26.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.2	27.2	27.2	27.2	26.6	26.1	25.9	26.7	26.9	27.2	27.4	(27)
(28)			MCDWB	31.0	30.9	30.9	30.9	30.3	29.2	28.5	28.6	30.0	30.4	31.4	31.6	(28)
(29)		2%	WB	26.7	26.6	26.6	26.7	26.7	26.1	25.6	25.4	26.0	26.5	26.8	26.9	(29)
(30)			MCDWB	30.8	30.7	30.6	30.3	29.8	28.6	27.7	27.8	28.8	29.9	30.8	31.2	(30)
(31)		5%	WB	26.3	26.2	26.2	26.5	26.4	25.7	25.2	25.0	25.5	26.2	26.6	26.6	(31)
(32)			MCDWB	30.5	30.4	30.3	30.0	29.4	28.0	27.1	27.2	28.2	29.5	30.5	30.8	(32)
(33)		10%	WB	26.0	25.9	26.0	26.2	26.1	25.5	24.8	24.6	25.1	25.8	26.2	26.2	(33)
(34)			MCDWB	30.2	30.0	30.1	29.6	28.9	27.6	26.5	26.7	27.6	29.1	30.1	30.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.9	6.8	6.1	5.3	4.4	3.8	4.1	5.1	5.9	6.8	7.0	(35)
(36)			MCDBR	7.8	8.1	7.8	7.0	6.2	5.7	4.9	5.3	6.0	6.5	7.6	8.1	(36)
(37)			MCWBR	2.9	2.9	2.9	2.9	2.8	2.5	2.2	2.3	2.7	2.9	3.3	3.2	(37)
(38)		5% WB	MCDWB	7.2	7.2	7.0	6.4	5.7	4.9	4.2	4.5	5.5	6.1	6.9	7.4	(38)
(39)			MCWBR	3.1	3.2	3.1	3.0	2.8	2.4	2.2	2.2	2.8	3.0	3.3	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.416	0.419	0.413	0.405	0.421	0.435	0.428	0.426	0.431	0.451	0.436	0.421	(40)	
(41)		taud	2.502	2.484	2.502	2.543	2.504	2.460	2.477	2.471	2.446	2.369	2.415	2.475	(41)	
(42)		Ebn at Noon	920	917	911	895	855	828	841	864	881	877	894	911	(42)	
(43)		Edh at Noon	113	116	113	105	105	107	106	111	118	129	123	115	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.20	5.49	5.54	5.25	4.73	4.03	4.22	4.94	5.46	6.07	6.00	5.34	(44)	
(45)		RadStd	0.41	0.40	0.33	0.26	0.45	0.52	0.54	0.68	0.53	0.39	0.30	0.40	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page