

GESER, Indonesia

WMO: 977480

Lat: 3.8869S

Lon: 130.8954E

Elev: 10

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	74.9	75.9	71.1	114.8	79.2	71.7	117.1	79.1	22.2	79.2	20.3	79.0	8.4	110	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.0	89.6	80.4	89.0	80.2	88.3	80.0	81.8	87.3	81.2	86.7	80.9	86.4	6.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	156.0	85.3	79.6	153.7	84.9	79.2	151.4	84.5	45.5	87.9	45.0	87.4	44.5	86.9	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.1	15.5	64.8	93.5	5.3	4.3	60.9	96.6	57.8	99.1	54.8	101.6	51.0	104.7		
(5)			68.6	83.5	3.8	1.1	65.8	84.3	63.6	85.0	61.5	85.6	58.7	86.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	83.2	83.2	83.2	82.9	82.4	81.2	80.2	79.9	80.6	82.3	83.5	83.7	
	DBStd	2.13	1.60	1.59	1.51	1.70	1.79	2.09	1.74	1.57	1.47	1.59	1.57	1.89	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11748	1030	930	1028	987	1003	935	938	927	917	1001	1006	1046	
	CDD65	6273	565	510	563	537	538	485	473	462	467	536	556	581	
	CDH74	69913	6702	6029	6698	6332	6166	5083	4386	4084	4451	5971	6842	7169	
	CDH80	20826	2371	2116	2360	2159	1881	1095	610	484	674	1676	2610	2790	
Wind	WSAvg	6.9	6.6	5.8	5.9	5.6	5.8	8.4	9.0	9.1	8.0	6.8	5.0	5.9	
Precipitation	PrecAvg	84.4	7.3	6.4	7.5	10.5	11.8	9.1	7.1	4.2	4.0	4.8	4.4	7.3	
	PrecMax	150.7	13.8	10.2	14.0	24.5	27.6	25.5	37.5	18.2	11.8	13.2	11.1	15.5	
	PrecMin	46.5	2.1	2.6	2.5	5.2	3.0	0.4	0.5	0.0	0.0	0.0	0.8	3.5	
	PrecStd	27.0	3.2	2.3	2.7	4.6	6.0	7.0	7.9	4.4	3.1	4.1	2.8	2.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	89.8	89.5	89.9	88.8	87.7	86.4	86.0	86.4	88.0	89.8	90.5	
		MCWB	80.4	80.1	80.3	80.5	80.6	80.5	79.5	79.0	79.2	79.9	80.4	80.6	
	2%	DB	88.9	88.7	88.6	88.6	87.6	86.3	85.1	84.5	85.2	86.9	88.9	89.6	
		MCWB	80.1	79.8	80.0	80.3	80.2	79.9	78.9	78.2	78.7	79.5	80.1	80.7	
	5%	DB	88.1	87.9	87.8	87.6	86.7	85.4	84.0	83.5	84.1	86.1	88.1	88.8	
		MCWB	79.9	79.6	79.8	80.0	80.0	79.5	78.3	77.7	78.3	79.3	79.9	80.4	
	10%	DB	87.2	87.1	86.9	86.6	85.8	84.4	82.9	82.5	83.2	85.3	87.3	87.8	
		MCWB	79.7	79.3	79.5	79.7	79.7	79.0	77.8	77.2	77.8	79.0	79.7	80.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	81.7	81.5	81.9	81.9	81.3	80.1	79.8	80.5	81.5	81.9	81.9
			MCDB	87.4	87.6	87.3	87.5	86.6	85.6	84.7	84.7	84.7	86.0	87.6	88.2
2%		WB	81.1	80.8	80.8	81.0	81.1	80.5	79.3	79.0	79.5	80.5	81.1	81.4	
		MCDB	86.9	86.8	86.8	86.4	85.6	85.3	83.5	83.3	83.5	85.1	86.7	87.6	
5%		WB	80.6	80.2	80.2	80.6	80.7	79.8	78.9	78.3	78.9	79.9	80.7	80.9	
		MCDB	86.5	86.0	86.0	85.9	85.1	84.2	82.8	82.3	82.8	84.4	86.3	87.0	
10%		WB	80.0	79.8	79.9	80.1	80.1	79.2	78.3	77.8	78.3	79.4	80.1	80.4	
		MCDB	85.7	85.5	85.5	85.1	84.4	83.2	82.0	81.6	82.1	83.9	85.6	86.3	
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.9	7.7	7.2	6.4	5.8	5.4	5.3	5.5	6.0	7.6	8.0	
		MCDBR	8.8	8.7	8.6	8.3	7.4	6.8	6.3	6.2	6.4	6.8	8.3	8.8	
		MCWBR	3.7	3.7	3.8	3.3	3.1	3.2	3.0	2.6	2.8	2.9	3.2	3.6	
	5% WB	MCDBR	8.4	8.2	8.2	7.8	6.7	6.1	5.7	5.9	5.8	6.4	7.8	8.1	
		MCWBR	3.8	3.9	3.8	3.6	3.2	3.2	2.9	2.8	2.9	3.1	3.4	3.9	
Clear-Sky Solar Irradiance	taub	0.414	0.418	0.410	0.404	0.419	0.434	0.431	0.434	0.439	0.456	0.435	0.420		
	taud	2.521	2.502	2.527	2.561	2.521	2.469	2.476	2.459	2.436	2.366	2.433	2.491		
	Ebn at Noon	292	291	290	284	272	263	266	272	277	277	284	290		
	Edh at Noon	35	36	35	33	33	34	34	36	38	41	38	36		
All-Sky Solar Radiation	RadAvg	1590	1682	1678	1572	1464	1364	1429	1585	1681	1795	1763	1604		
	RadStd	123	134	118	88	130	146	139	165	144	153	117	129		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page