

KOKONAO TIMUKA, Indonesia

WMO: 977960

Lat: 4.5297S

Lon: 136.8925E

Elev: 10

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	71.9	72.4	70.3	111.4	75.2	70.9	114.0	75.3	13.2	81.1	11.5	80.4	1.2	N/A	0.269

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.1	92.0	79.9	91.1	79.8	90.2	79.6	81.2	89.0	80.8	88.5	80.3	87.8	6.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.3	85.1	78.7	148.9	84.6	78.2	146.6	84.1	45.0	89.5	44.4	89.0	44.0	88.4	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.8	10.7	9.3	70.5	94.3	0.8	0.7	69.8	94.8	69.4	95.3	68.9	95.7	68.3	96.2
			69.5	83.5	1.0	1.1	68.8	84.3	68.1	84.9	67.6	85.6	66.8	86.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	82.1	81.9	82.0	81.7	81.0	79.1	77.9	78.1	79.5	81.1	82.0	82.2	
	DBStd	2.22	1.50	1.46	1.55	1.28	1.54	1.90	1.67	1.88	1.75	1.54	1.47	1.53	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11205	994	892	992	950	960	873	866	870	886	964	960	998	
	CDD65	5730	529	472	527	500	495	423	401	405	436	499	510	533	
	CDH74	47282	4816	4218	4864	4487	4299	2978	2276	2382	3143	4271	4658	4890	
	CDH80	14698	1785	1538	1769	1501	1248	600	332	391	754	1336	1640	1804	
Wind	WSAvg	2.5	2.8	2.8	2.6	2.4	2.3	2.3	2.4	2.6	2.6	2.4	2.4	2.5	
Precipitation	PrecAvg	220.5	15.5	14.5	17.8	21.5	18.5	21.7	25.8	22.7	17.0	15.2	14.3	18.1	
	PrecMax	317.4	30.6	26.9	31.0	32.6	33.9	52.1	58.4	47.9	33.0	29.3	25.8	31.6	
	PrecMin	128.1	6.9	6.5	7.9	11.3	8.9	7.4	5.4	0.3	1.3	2.5	6.2	8.1	
	PrecStd	46.7	6.0	6.5	6.6	5.4	6.2	10.6	11.3	11.7	7.5	6.7	4.5	6.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.1	92.5	93.1	91.6	90.4	88.9	87.4	87.5	89.7	91.4	92.3	92.7	
		MCWB	80.0	79.8	79.7	79.4	79.8	79.3	78.7	78.1	79.9	79.7	80.5	80.2	
	2%	DB	91.4	91.0	91.3	90.0	88.9	87.0	85.1	85.4	87.6	89.7	90.9	91.3	
		MCWB	79.7	79.6	79.5	79.6	79.5	78.9	77.9	77.6	79.0	79.2	79.9	80.1	
	5%	DB	90.0	89.8	90.0	88.9	87.7	85.3	83.4	83.8	86.0	88.2	89.6	90.0	
		MCWB	79.6	79.3	79.5	79.5	79.2	78.4	77.4	77.2	78.1	79.0	79.5	79.9	
	10%	DB	88.5	88.2	88.3	87.4	86.3	83.6	81.8	82.3	84.4	86.8	88.1	88.6	
		MCWB	79.3	79.1	79.1	79.2	79.0	77.9	76.8	76.7	77.7	78.7	79.2	79.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	81.3	81.6	81.2	81.0	80.2	79.7	79.5	80.5	81.2	81.9	81.8
			MCDB	89.7	88.9	89.7	88.0	87.6	86.3	84.6	84.8	87.6	88.5	90.3	89.9
2%		WB	80.8	80.5	80.7	80.6	80.2	79.3	78.6	78.4	79.5	80.2	80.7	80.9	
		MCDB	89.0	88.6	88.7	87.5	86.3	85.0	83.4	83.6	85.9	87.2	88.8	89.1	
5%		WB	80.1	79.8	80.0	80.0	79.8	78.8	77.8	77.7	78.7	79.5	80.0	80.2	
		MCDB	88.0	87.6	87.6	86.5	85.7	84.2	82.1	82.2	84.6	86.2	87.6	88.0	
10%		WB	79.5	79.2	79.4	79.4	79.2	78.1	77.1	77.0	78.0	78.9	79.4	79.7	
		MCDB	86.9	86.6	86.6	85.6	84.8	82.6	80.7	81.0	83.1	85.3	86.6	87.2	
Mean Daily Temperature Range	5% DB	MDBR	14.4	14.4	14.2	13.3	11.8	9.5	8.7	9.3	11.0	12.6	13.7	14.1	
		MCDBR	16.3	16.1	16.1	14.7	13.6	12.0	11.0	11.5	13.3	14.5	15.4	15.8	
		MCWBR	6.3	6.3	6.1	5.9	5.4	4.9	4.8	4.7	5.6	5.8	6.1	6.4	
	5% WB	MCDBR	15.2	15.0	14.6	13.8	12.5	11.0	10.2	10.5	12.3	13.6	14.5	14.8	
		MCWBR	6.4	6.4	6.2	6.0	5.4	4.8	4.9	4.8	5.6	6.0	6.2	6.4	
Clear-Sky Solar Irradiance	taub	0.406	0.403	0.399	0.400	0.415	0.418	0.417	0.436	0.443	0.480	0.457	0.424		
	taud	2.494	2.503	2.521	2.521	2.478	2.477	2.487	2.422	2.399	2.271	2.341	2.445		
	Ebn at Noon	295	296	293	285	272	267	270	271	276	270	278	288		
	Edh at Noon	36	36	35	34	34	33	33	37	39	45	42	38		
All-Sky Solar Radiation	RadAvg	1623	1619	1618	1520	1390	1203	1156	1235	1369	1502	1541	1551		
	RadStd	60	71	56	67	74	82	55	61	88	82	56	72		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page