

SAUMLAKI OLILIT, Indonesia

WMO: 979000

Lat: 7.9825S

Lon: 131.2980E

Elev: 24

StdP: 101.04

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.9	23.6	18.4	13.3	25.2	19.2	14.0	25.6	10.1	26.4	8.8	26.9	1.6	100	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	6.5	33.4	27.0	32.8	26.8	32.3	26.7	27.8	31.7	27.5	31.4	27.2	30.9	3.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.4	30.1	26.4	22.0	29.7	26.2	21.7	29.3	89.0	32.1	87.5	31.6	86.3	31.3	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.6	6.7	19.6	34.9	3.4	0.6	17.2	35.3	15.2	35.7	13.3	36.0	10.9	36.5		
(5)			18.3	29.4	2.2	0.7	16.7	29.9	15.4	30.3	14.2	30.7	12.6	31.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	28.5	28.4	28.3	28.2	27.9	26.9	26.5	26.4	27.0	28.0	28.9	28.7
	DBStd	1.31	1.21	1.14	1.15	1.10	1.01	0.98	0.84	0.74	0.86	0.91	0.85	1.16
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6494	573	514	567	546	554	506	511	509	509	558	566	580
	CDD18.3	3453	314	281	309	296	296	256	253	251	259	300	316	322
	CDH23.3	36432	3506	3118	3396	3313	3190	2398	2140	2085	2464	3321	3810	3691
(13)	CDH26.7	11084	1206	1060	1147	1113	903	409	280	315	583	1114	1568	1385
(14)	Wind	WSAvg	3.1	2.9	3.0	2.3	2.4	3.5	4.1	4.3	4.1	3.4	2.1	2.1
(15) Precipitation	PrecAvg	1131	139	147	159	147	176	102	24	12	2	25	42	156
	PrecMax	3004	415	448	445	621	652	553	95	91	33	347	198	471
	PrecMin	64	0	3	0	7	7	0	0	0	0	1	1	1
	PrecStd	764	148	142	150	173	188	140	29	20	6	69	58	132
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	33.5	33.4	32.7	31.7	30.9	29.7	29.8	31.1	32.6	33.9	34.2
		MCWB	27.3	27.4	27.5	26.9	26.8	25.8	24.4	24.6	25.6	25.9	26.8	27.0
	2%	DB	32.7	32.6	32.6	32.0	31.1	29.9	29.1	29.3	30.4	31.7	33.1	33.4
		MCWB	27.1	27.2	27.2	26.7	26.2	25.3	24.5	24.4	25.2	25.8	26.5	26.8
	5%	DB	32.0	31.9	31.9	31.5	30.6	29.3	28.7	28.8	29.9	31.2	32.5	32.6
		MCWB	27.0	27.0	27.0	26.5	26.0	25.1	24.4	24.1	24.9	25.6	26.3	26.7
	10%	DB	31.3	31.2	31.2	30.9	30.0	28.7	28.2	28.3	29.3	30.7	31.9	31.7
		MCWB	26.8	26.8	26.8	26.3	25.7	24.8	24.1	23.9	24.6	25.5	26.1	26.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.2	28.2	27.8	27.6	26.6	26.1	25.7	26.6	26.8	27.7	28.2
		MCDB	32.1	31.9	32.1	31.4	30.8	29.5	28.3	28.5	30.1	30.7	32.4	32.5
	2%	WB	27.6	27.6	27.6	27.3	27.0	26.1	25.6	25.2	26.0	26.5	27.1	27.5
		MCDB	31.4	31.5	31.4	30.9	30.2	28.8	27.9	28.1	29.2	30.3	31.7	31.6
	5%	WB	27.2	27.2	27.2	27.0	26.6	25.7	25.1	24.8	25.5	26.1	26.7	27.1
		MCDB	30.8	30.8	30.7	30.4	29.6	28.2	27.5	27.7	28.8	30.0	31.1	31.0
	10%	WB	27.0	26.9	27.0	26.6	26.2	25.3	24.8	24.4	25.1	25.8	26.4	26.8
		MCDB	30.4	30.4	30.3	29.8	28.9	27.8	27.2	27.4	28.4	29.6	30.7	30.4
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.3	5.5	5.0	4.1	3.6	3.7	4.1	4.9	5.6	6.5	6.0
		MCDBR	6.4	6.4	6.5	5.9	4.8	4.3	4.1	4.4	5.4	6.0	7.2	7.3
		MCWBR	2.3	2.4	2.4	2.5	2.2	2.0	2.0	2.1	2.1	2.1	2.4	2.4
	5% WB	MCDBR	5.8	5.8	6.0	5.3	4.5	3.8	3.6	4.1	4.8	5.6	6.7	6.4
		MCWBR	2.4	2.5	2.6	2.5	2.3	2.0	2.0	2.2	2.1	2.1	2.4	2.5
(40) Clear-Sky Solar Irradiance	taub		0.424	0.420	0.405	0.406	0.430	0.432	0.418	0.413	0.421	0.442	0.431	0.419
	taud		2.481	2.484	2.532	2.532	2.452	2.419	2.462	2.465	2.419	2.350	2.412	2.477
	Ebn at Noon		917	918	917	888	837	820	841	870	889	887	904	919
	Edh at Noon		117	116	109	105	108	109	106	110	120	131	124	116
(44) All-Sky Solar Radiation	RadAvg		5.09	5.36	5.30	5.20	4.76	4.46	4.84	5.80	6.54	6.77	6.58	5.48
	RadStd		0.61	0.58	0.46	0.54	0.52	0.44	0.29	0.29	0.30	0.34	0.37	0.61

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page