

BASCO RADAR, Philippines

WMO: 981340

Lat: 20.4275N

Lon: 121.9706E

Elev: 548

StdP: 14.41

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	63.4	64.8	54.2	63.8	65.7	56.4	69.2	66.9	26.5	69.6	23.4	69.6	14.6	40	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	87.9	81.5	87.1	81.1	86.3	80.7	82.6	86.5	81.9	85.9	81.4	85.4	9.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.5	167.3	85.7	80.8	163.4	85.2	80.1	159.7	84.6	47.0	86.6	46.4	86.1	45.7	85.8	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.6	25.3	21.9	59.5	91.6	4.3	4.0	56.4	94.4	53.9	96.7	51.5	99.0	48.3	101.8
			57.1	84.2	3.2	0.9	54.8	84.9	52.9	85.4	51.1	85.9	48.8	86.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.9	71.7	72.4	74.2	77.8	81.0	82.5	82.5	81.7	81.0	79.3	76.9	73.0
	DBStd	4.79	3.47	3.57	3.65	3.26	2.30	2.02	1.85	1.86	1.89	2.24	2.47	3.38
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	5	2	2	1	0	0	0	0	0	0	0	0	0
	CDD50	10171	672	628	752	835	961	975	1009	982	930	907	808	712
	CDD65	4701	209	210	287	385	496	525	544	517	480	442	358	248
	CDH74	39504	409	541	1242	2877	5062	5988	6246	5589	4895	3769	2193	693
CDH80	8636	9	15	76	426	1230	1875	1938	1422	1028	501	102	14	
Wind	WSAvg	12.1	13.2	12.6	12.4	11.0	9.9	10.5	11.7	13.0	12.1	12.6	12.8	13.3
Precipitation	PrecAvg	94.8	6.7	4.0	2.8	2.0	7.6	7.5	9.8	11.9	12.8	13.0	10.5	6.7
	PrecMax	130.7	19.3	16.9	7.3	8.0	18.1	20.0	22.7	25.4	27.1	28.6	30.8	18.3
	PrecMin	66.7	1.5	0.4	0.6	0.0	0.6	0.2	1.9	4.1	3.3	2.0	2.2	1.7
	PrecStd	17.4	4.2	3.3	1.7	1.9	4.1	4.4	5.7	5.2	5.5	7.4	7.0	4.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.7	81.9	83.7	86.2	88.3	88.9	88.8	88.1	87.1	86.1	84.5	82.0
		MCWB	73.1	75.3	77.5	79.6	81.0	82.0	82.1	81.8	81.3	80.1	79.3	76.2
	2%	DB	78.9	80.2	81.9	84.8	87.1	87.6	87.6	86.8	86.0	84.7	82.4	79.5
		MCWB	73.2	74.6	76.5	78.9	80.8	81.6	81.5	81.1	80.7	79.3	77.8	74.5
	5%	DB	77.3	78.8	80.6	83.7	86.1	86.7	86.7	85.9	85.1	83.8	81.2	78.2
		MCWB	72.3	73.7	75.8	78.3	80.4	81.2	81.0	80.6	80.1	78.7	77.0	73.7
	10%	DB	76.2	77.2	79.2	82.6	85.1	86.0	85.9	85.0	84.2	82.7	80.2	77.2
		MCWB	71.4	72.6	74.8	77.6	79.9	80.8	80.6	80.2	79.5	78.1	76.3	73.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.6	77.1	78.6	80.9	82.7	83.5	83.3	82.8	82.5	81.7	79.9	77.2
		MCDB	78.6	80.5	82.4	85.6	86.5	87.4	87.4	86.5	85.9	84.5	83.2	79.9
	2%	WB	74.4	75.4	77.3	79.7	81.7	82.6	82.3	81.9	81.5	80.5	78.6	75.9
		MCDB	77.3	79.0	81.0	83.6	85.8	86.7	86.5	85.5	85.0	83.6	81.5	78.4
	5%	WB	73.2	74.3	76.3	78.9	80.9	81.8	81.7	81.2	80.7	79.7	77.7	74.9
		MCDB	76.3	77.8	79.9	82.6	85.2	85.9	85.8	84.8	84.3	82.8	80.5	77.6
	10%	WB	72.1	73.3	75.3	78.2	80.3	81.0	81.0	80.6	80.0	78.9	77.0	73.9
		MCDB	75.5	76.6	78.8	81.8	84.5	85.1	85.0	84.2	83.5	82.2	79.7	76.8
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.9	6.2	6.5	6.6	6.0	5.7	5.6	5.5	4.9	4.6	4.5
		MCDBR	7.4	7.6	7.8	8.0	7.9	6.9	6.7	6.5	6.3	6.1	5.4	5.6
		MCWBR	5.4	5.6	6.0	5.4	5.1	4.5	4.5	4.5	4.6	4.4	4.1	4.4
	5% WB	MCDBR	6.2	6.9	7.4	7.3	7.5	6.4	6.3	6.1	6.1	5.7	5.3	5.2
		MCWBR	5.5	5.7	6.2	5.3	5.3	4.7	4.7	4.7	4.8	4.7	4.3	4.4
Clear-Sky Solar Irradiance	taub	0.443	0.443	0.522	0.507	0.448	0.444	0.445	0.461	0.474	0.475	0.474	0.482	
	taud	2.276	2.304	2.069	2.162	2.413	2.434	2.424	2.365	2.300	2.252	2.237	2.151	
	Ebn at Noon	262	270	253	258	271	269	269	266	262	257	250	244	
	Edh at Noon	40	41	53	49	38	37	37	40	42	43	41	44	
All-Sky Solar Radiation	RadAvg	1071	1370	1578	1892	1910	1986	1892	1706	1625	1476	1178	948	
	RadStd	103	175	154	186	156	169	164	153	174	88	128	140	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page