

BASCO RADAR, Philippines

WMO: 981340

Lat: 20.4275N

Lon: 121.9706E

Elev: 167

StdP: 99.33

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.4	18.2	12.4	9.1	18.7	13.6	9.9	19.4	11.8	20.9	10.5	20.9	6.5	40	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.2	31.0	27.5	30.6	27.3	30.2	27.1	28.1	30.3	27.7	29.9	27.5	29.6	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.9	29.8	27.1	23.3	29.5	26.7	22.8	29.2	91.4	30.3	90.0	30.1	88.4	29.9	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.1	11.3	9.8														
			DB		15.3	33.1	2.4	2.2	13.5	34.7	12.1	36.0	10.8	37.2	9.1	38.8
			WB		13.9	29.0	1.8	0.5	12.7	29.4	11.6	29.7	10.6	30.0	9.3	30.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.5	22.0	22.5	23.5	25.5	27.2	28.1	28.1	27.6	27.2	26.3	25.0	22.8	
	DBStd	2.66	1.93	1.98	2.03	1.81	1.28	1.12	1.03	1.03	1.05	1.24	1.37	1.88	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	3	1	1	1	0	0	0	0	0	0	0	0	0	
	CDD10.0	5651	373	349	418	464	534	542	561	546	517	504	449	396	
	CDD18.3	2612	116	117	159	214	276	292	302	287	267	246	199	138	
	CDH23.3	21947	227	301	690	1598	2812	3327	3470	3105	2719	2094	1218	385	
CDH26.7	4798	5	8	42	237	683	1042	1077	790	571	278	57	8		
Wind	WSAvg	5.4	5.9	5.6	5.5	4.9	4.4	4.7	5.2	5.8	5.4	5.6	5.7	5.9	
Precipitation	PrecAvg	2407	170	102	71	52	194	190	250	302	324	331	266	171	
	PrecMax	3319	489	429	185	204	459	509	576	646	688	726	783	466	
	PrecMin	1693	37	11	16	0	15	4	48	104	83	51	55	43	
	PrecStd	442	107	84	44	48	103	111	146	132	140	187	178	101	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.1	27.7	28.7	30.1	31.3	31.6	31.5	31.2	30.6	30.1	29.1	27.8	
		MCWB	22.8	24.1	25.3	26.4	27.2	27.8	27.8	27.7	27.4	26.7	26.3	24.5	
	2%	DB	26.1	26.8	27.7	29.3	30.6	30.9	30.9	30.4	30.0	29.3	28.0	26.4	
		MCWB	22.9	23.7	24.7	26.0	27.1	27.6	27.5	27.3	27.1	26.3	25.4	23.6	
	5%	DB	25.2	26.0	27.0	28.7	30.1	30.4	30.4	29.9	29.5	28.8	27.4	25.7	
		MCWB	22.4	23.1	24.3	25.7	26.9	27.3	27.2	27.0	26.7	25.9	25.0	23.2	
	10%	DB	24.5	25.1	26.2	28.1	29.5	30.0	29.9	29.4	29.0	28.2	26.8	25.1	
		MCWB	21.9	22.6	23.8	25.3	26.6	27.1	27.0	26.8	26.4	25.6	24.6	22.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	25.1	25.9	27.2	28.2	28.6	28.5	28.2	28.1	27.6	26.6	25.1
			MCDB	25.9	26.9	28.0	29.8	30.3	30.8	30.8	30.3	30.0	29.2	28.4	26.6
2%		WB	23.6	24.1	25.1	26.5	27.6	28.1	28.0	27.7	27.5	27.0	25.9	24.4	
		MCDB	25.2	26.1	27.2	28.7	29.9	30.4	30.3	29.7	29.5	28.7	27.5	25.8	
5%		WB	22.9	23.5	24.6	26.1	27.2	27.7	27.6	27.3	27.1	26.5	25.4	23.8	
		MCDB	24.6	25.4	26.6	28.1	29.6	29.9	29.9	29.3	29.1	28.2	26.9	25.3	
10%		WB	22.3	22.9	24.0	25.6	26.8	27.2	27.2	27.0	26.7	26.0	25.0	23.3	
		MCDB	24.2	24.8	26.0	27.7	29.2	29.5	29.4	29.0	28.6	27.9	26.5	24.9	
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.3	3.5	3.6	3.7	3.3	3.2	3.1	3.1	2.7	2.6	2.5	
		MCDBR	4.1	4.2	4.3	4.5	4.4	3.8	3.7	3.6	3.5	3.4	3.0	3.1	
		MCWBR	3.0	3.1	3.4	3.0	2.8	2.5	2.5	2.5	2.5	2.5	2.3	2.5	
	5% WB	MCDBR	3.4	3.9	4.1	4.1	4.2	3.6	3.5	3.4	3.4	3.2	2.9	2.9	
		MCWBR	3.0	3.2	3.5	2.9	3.0	2.6	2.6	2.6	2.7	2.6	2.4	2.5	
Clear-Sky Solar Irradiance	taub	0.443	0.443	0.522	0.507	0.448	0.444	0.445	0.461	0.474	0.475	0.474	0.474	0.482	
	taud	2.276	2.304	2.069	2.162	2.413	2.434	2.424	2.365	2.300	2.252	2.237	2.151		
	Ebn at Noon	826	852	797	812	853	848	848	839	827	811	789	769		
	Edh at Noon	125	128	168	155	120	116	117	125	132	134	129	138		
All-Sky Solar Radiation	RadAvg	3.38	4.32	4.98	5.96	6.02	6.26	5.96	5.38	5.12	4.65	3.71	2.99		
	RadStd	0.32	0.55	0.49	0.59	0.49	0.53	0.52	0.48	0.55	0.28	0.40	0.44		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page