

SINAIT, Philippines

WMO: 982220

Lat: 17.8903N

Lon: 120.4598E

Elev: 191

StdP: 14.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	69.0	70.5	58.5	73.6	74.0	60.6	79.4	74.7	15.7	79.9	14.1	79.7	4.0	40	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.2	91.6	80.5	90.7	80.3	89.9	80.1	82.8	88.9	82.2	88.4	81.7	87.9	7.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	162.3	87.4	80.4	159.2	87.0	79.9	156.2	86.5	46.9	89.1	46.2	88.7	45.6	88.2	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	13.0	11.5	65.4	95.4	2.9	2.8	63.4	97.4	61.7	99.0	60.1	100.6	58.0	102.6		
(5)			61.2	84.5	2.7	1.1	59.2	85.3	57.7	85.9	56.2	86.5	54.3	87.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	78.4	79.2	81.1	83.3	83.9	83.0	81.8	81.1	81.4	81.3	81.3	79.9	
	DBStd	2.59	2.22	2.38	2.13	1.73	2.07	1.98	1.88	2.09	1.77	1.96	2.08	2.43	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11434	880	818	963	999	1052	990	986	965	942	972	940	927	
	CDD65	5959	415	398	498	549	587	540	521	500	492	507	490	462	
	CDH74	62180	3219	3425	5147	6681	7395	6319	5552	5076	5105	5224	4965	4072	
	CDH80	21315	865	986	1741	2734	3218	2451	1795	1425	1559	1715	1617	1209	
Wind	WSAvg	4.8	4.9	5.0	4.8	4.6	4.6	4.7	4.7	5.2	4.4	4.9	4.6	4.9	
Precipitation	PrecAvg	96.8	0.3	0.1	0.1	1.1	7.2	11.3	21.0	27.1	18.1	6.2	1.9	0.4	
	PrecMax	128.3	2.6	0.4	0.2	7.9	14.9	26.0	43.8	43.7	36.3	27.5	10.6	1.9	
	PrecMin	72.6	0.0	0.0	0.0	0.3	1.5	0.7	4.5	10.2	4.4	1.1	0.1	0.0	
	PrecStd	16.6	0.6	0.1	0.1	1.7	3.7	7.1	12.6	10.8	7.2	5.9	2.7	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.3	89.7	91.2	92.1	93.4	92.1	90.9	89.7	89.8	90.7	90.9	90.1	
		MCWB	75.6	76.4	78.0	79.7	81.7	81.6	81.7	81.6	81.1	79.6	78.9	76.9	
	2%	DB	87.2	87.8	89.4	90.9	91.7	90.7	89.3	88.4	88.3	89.3	89.2	88.3	
		MCWB	75.6	76.1	77.9	79.9	81.2	81.4	81.2	81.0	80.7	79.5	79.1	77.1	
	5%	DB	85.7	86.5	88.1	89.9	90.8	89.6	88.2	87.4	87.5	88.2	88.1	87.2	
		MCWB	75.4	75.9	77.7	79.7	80.9	81.3	80.9	80.6	80.5	79.5	78.9	77.1	
	10%	DB	84.5	85.4	87.1	89.0	89.8	88.6	87.2	86.3	86.5	87.2	87.0	85.9	
		MCWB	75.0	75.6	77.4	79.4	80.6	80.9	80.6	80.2	80.2	79.3	78.6	76.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.1	79.8	81.0	82.4	83.8	83.5	83.1	82.7	82.7	82.6	81.9	80.7
			MCDB	85.6	86.8	88.3	89.7	90.7	89.7	88.4	87.8	87.7	87.8	87.9	86.9
2%		WB	77.9	78.5	79.8	81.4	82.6	82.6	82.2	81.8	81.7	81.6	80.9	79.5	
		MCDB	84.6	85.4	87.3	89.0	90.0	88.9	87.9	87.0	87.0	87.1	87.1	86.1	
5%		WB	77.0	77.6	78.9	80.7	81.8	81.9	81.5	81.0	81.0	80.7	80.1	78.5	
		MCDB	83.9	84.5	86.5	88.5	89.2	88.2	87.2	86.1	86.3	86.5	86.3	85.3	
10%		WB	76.0	76.7	78.1	80.0	81.0	81.3	80.8	80.4	80.4	79.9	79.3	77.6	
		MCDB	82.9	83.6	85.5	87.7	88.5	87.6	86.5	85.4	85.7	85.7	85.6	84.2	
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.3	12.0	11.6	11.2	10.6	9.9	8.6	9.7	11.1	11.1	11.8	
		MCDBR	13.6	13.1	12.8	12.2	12.5	11.9	11.6	10.8	11.0	12.5	12.5	13.0	
		MCWBR	7.8	7.3	7.0	6.5	6.4	6.4	6.5	6.1	6.3	7.3	7.1	7.6	
	5% WB	MCDBR	12.3	12.1	12.0	11.6	11.9	11.2	11.0	10.4	10.4	11.2	11.4	12.1	
		MCWBR	7.8	7.6	7.2	6.6	6.7	6.7	6.7	6.1	6.3	7.0	7.0	7.9	
Clear-Sky Solar Irradiance	taub	0.391	0.403	0.463	0.491	0.457	0.454	0.453	0.457	0.452	0.441	0.418	0.412		
	taud	2.478	2.431	2.269	2.207	2.354	2.376	2.375	2.353	2.357	2.374	2.452	2.447		
	Ebn at Noon	283	285	271	262	268	266	267	268	270	270	272	272		
	Edh at Noon	33	36	44	47	40	39	39	40	40	38	34	33		
All-Sky Solar Radiation	RadAvg	1494	1719	1949	2098	1887	1814	1655	1513	1595	1592	1444	1338		
	RadStd	63	100	82	95	136	183	187	170	136	122	124	86		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	-0.59	-0.43	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page