

CLARK INTL, Philippines

WMO: 983270

Lat: 15.1851N

Lon: 120.5490E

Elev: 484

StdP: 14.44

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	66.4	68.1	57.3	71.2	78.0	59.3	76.6	78.2	17.4	81.5	15.4	81.0	6.5	300	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	18.3	95.1	76.3	93.6	76.3	92.7	76.4	81.0	88.8	80.1	87.6	79.5	86.7	7.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	153.7	84.7	78.4	150.0	83.7	77.4	145.1	82.5	45.2	89.3	44.3	88.4	43.5	87.1	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	13.5	11.7	64.1	98.0	2.5	1.3	62.3	99.0	60.9	99.8	59.5	100.5	57.7	101.5		
(5)			59.5	83.7	2.1	2.1	57.9	85.2	56.7	86.4	55.5	87.6	53.9	89.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.0	77.7	78.9	81.3	84.0	84.1	82.3	80.9	80.4	80.8	81.1	80.5	79.3
	DBStd	2.94	2.45	2.30	2.33	2.15	2.59	2.67	2.43	2.26	2.23	2.09	1.89	2.29
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11295	858	809	970	1020	1056	970	958	943	924	963	916	908
	CDD65	5820	393	389	505	570	591	520	493	478	474	498	466	443
	CDH74	55268	3020	3383	5164	6791	6695	5233	4345	3985	4128	4626	4211	3687
CDH80	20722	886	1222	2191	3303	3051	1988	1419	1142	1313	1601	1435	1171	
Wind	WSAvg	5.4	6.2	5.9	5.9	5.5	5.1	5.1	5.0	4.9	4.6	5.0	5.7	6.2
Precipitation	PrecAvg	83.5	0.6	0.6	0.9	1.6	7.5	10.7	17.8	17.8	13.0	7.8	2.8	2.0
	PrecMax	114.3	4.4	3.1	3.0	7.1	16.0	23.8	42.0	34.6	22.1	22.2	6.9	11.2
	PrecMin	59.7	0.0	0.0	0.0	0.1	0.7	3.4	6.4	8.3	2.4	1.2	0.0	0.0
	PrecStd	16.1	0.9	0.7	0.8	1.9	4.3	6.1	8.0	6.8	4.8	4.9	2.1	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.4	91.7	94.7	96.9	96.9	95.1	92.7	91.7	92.0	91.6	90.9	90.0
		MCWB	74.6	74.2	75.0	75.8	76.3	79.1	78.7	78.8	78.8	77.3	76.5	75.2
	2%	DB	87.7	89.8	92.9	95.2	95.1	92.8	90.8	89.7	90.0	90.0	89.6	88.7
		MCWB	73.5	73.2	74.3	75.6	76.7	78.6	78.2	78.2	78.2	76.9	76.0	74.9
	5%	DB	86.2	88.1	91.4	93.6	93.5	91.0	89.2	88.0	88.5	89.2	88.2	87.6
		MCWB	73.2	72.9	74.2	75.5	77.0	78.2	77.9	78.1	77.9	76.7	75.5	74.6
	10%	DB	84.6	86.7	89.6	92.7	91.6	89.1	87.4	86.1	86.8	87.6	87.3	86.0
		MCWB	72.2	72.6	73.7	75.5	77.2	78.0	77.9	78.1	77.8	76.3	75.3	74.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.8	77.4	81.5	83.5	81.4	81.5	80.8	80.9	81.0	80.3	79.1	78.9
		MCDB	85.8	86.1	89.0	91.4	90.5	89.2	87.8	86.9	87.9	87.4	86.4	86.2
	2%	WB	76.4	76.1	78.0	80.7	80.1	80.2	79.7	79.8	79.8	79.1	78.2	77.4
		MCDB	84.4	85.1	86.3	89.7	89.1	88.0	86.4	85.7	86.6	86.0	85.3	84.4
	5%	WB	74.9	75.0	76.4	78.6	79.3	79.5	79.0	79.0	79.0	78.2	77.3	76.4
		MCDB	82.2	84.1	85.6	87.2	87.8	86.9	85.4	84.6	85.5	84.9	84.4	83.4
	10%	WB	73.8	74.0	75.3	77.4	78.5	78.8	78.3	78.3	78.3	77.6	76.5	75.5
		MCDB	81.3	82.9	84.4	86.6	86.6	85.8	84.3	83.5	84.3	84.1	83.5	82.6
Mean Daily Temperature Range	5% DB	MDBR	15.0	16.7	17.3	18.3	15.8	13.3	12.2	11.2	12.3	13.4	13.7	14.1
		MCDBR	16.1	18.4	19.3	19.5	17.7	15.9	15.4	14.3	14.8	15.1	15.2	15.4
		MCWBR	6.0	6.4	6.0	5.6	5.4	5.6	5.9	5.8	5.9	5.6	5.5	5.8
	5% WB	MCDBR	13.7	15.8	16.9	16.9	15.4	13.9	13.2	12.3	13.3	13.3	13.3	13.1
MCWBR		5.9	6.5	6.5	6.5	5.7	5.6	5.8	5.6	6.0	5.6	5.6	6.0	
Clear-Sky Solar Irradiance	taub	0.402	0.409	0.448	0.489	0.472	0.459	0.457	0.463	0.459	0.471	0.422	0.418	
	taud	2.440	2.407	2.302	2.194	2.277	2.328	2.335	2.311	2.314	2.262	2.423	2.418	
	Ebn at Noon	283	285	276	263	264	265	266	267	269	263	274	274	
	Edh at Noon	35	38	43	48	43	41	41	42	42	43	36	35	
All-Sky Solar Radiation	RadAvg	1476	1698	1892	2031	1821	1633	1443	1349	1485	1514	1428	1347	
	RadStd	65	112	92	92	163	192	200	152	148	124	120	90	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (16 neighbors)		+1.46	+2.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.58	+1.03	N/A	+0.72	+0.65	+0.76	N/A	N/A	+284

Nomenclature: See separate page