

BAGUIO, Philippines

WMO: 983280

Lat: 16.4040N

Lon: 120.6015E

Elev: 4925

StdP: 12.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	53.5	55.2	50.0	64.1	56.5	51.7	68.3	57.3	14.2	64.9	12.5	64.3	4.3	110	0.259

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	13.9	79.4	70.5	77.8	70.2	76.7	69.8	73.4	76.7	72.1	75.8	71.2	75.1	5.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.4	144.5	76.0	71.0	137.9	75.0	70.0	132.9	74.2	40.8	76.9	39.5	75.9	38.6	75.2	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.6	12.7	10.8	DB	50.7	86.1	2.4	4.5	49.0	89.3	47.7	92.0	46.3	94.5	44.6	97.8	
			WB	48.9	78.7	2.1	3.2	47.4	81.0	46.1	82.9	44.9	84.7	43.4	87.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	64.8	65.8	67.3	69.3	69.2	68.8	67.5	66.8	67.5	67.6	67.5	66.3
	DBStd	2.66	2.61	2.59	2.19	1.89	2.24	2.35	2.49	2.48	2.33	2.12	2.09	2.49
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	114	35	20	6	0	2	3	7	10	6	5	5	15
	CDD50	6336	458	441	537	578	594	564	542	520	524	546	526	506
	CDD65	973	28	41	78	128	132	116	84	65	79	85	81	56
	CDH74	1323	33	76	153	294	206	147	71	47	54	74	98	70
	CDH80	55	3	3	2	6	8	8	7	3	5	4	2	4
Wind	WSAvg	4.5	4.5	4.3	4.0	3.8	4.0	4.9	5.0	5.1	4.2	4.9	4.5	4.8
Precipitation	PrecAvg	149.6	0.6	0.7	1.3	4.1	12.2	16.9	29.6	34.4	23.3	16.0	3.9	1.4
	PrecMax	282.1	6.3	5.1	4.8	16.0	30.1	55.8	188.0	75.1	66.7	89.5	25.0	6.6
	PrecMin	83.9	0.0	0.0	0.0	0.3	0.7	5.2	4.6	9.5	7.0	1.2	0.3	0.0
	PrecStd	52.3	1.1	1.3	1.5	3.3	5.9	10.6	29.3	17.2	15.6	18.7	4.8	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.0	78.6	79.3	80.7	80.5	80.0	79.6	78.0	78.4	78.6	78.3	78.4
		MCWB	68.0	69.0	69.9	71.0	72.1	71.1	70.6	70.2	70.0	70.0	69.8	68.7
	2%	DB	74.5	76.1	77.2	78.7	77.8	77.1	75.6	75.0	75.2	75.8	76.4	75.6
		MCWB	67.7	68.5	69.2	70.5	71.1	70.6	70.1	69.6	69.8	69.7	69.0	68.2
	5%	DB	72.9	74.4	75.6	77.2	76.3	75.6	74.0	73.2	73.8	74.4	75.0	74.2
		MCWB	66.7	67.7	68.4	70.1	70.4	70.1	69.5	69.0	69.2	69.1	68.5	67.6
	10%	DB	71.5	72.7	74.1	75.7	74.7	74.1	72.3	71.3	72.2	72.9	73.4	72.6
		MCWB	66.0	66.8	67.7	69.6	69.7	69.4	68.6	68.0	68.4	68.4	67.9	66.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	72.4	73.3	74.7	74.6	73.9	73.0	72.4	72.7	73.0	72.5	72.6
		MCDB	74.8	76.0	77.2	78.0	77.8	77.1	75.7	75.1	75.7	76.0	75.9	75.8
	2%	WB	69.3	70.1	71.1	72.6	72.5	71.9	71.0	70.3	70.8	70.9	70.7	70.1
		MCDB	73.1	74.6	75.2	76.7	76.2	75.4	74.5	73.7	74.1	74.3	74.8	74.1
	5%	WB	67.9	68.6	69.7	71.2	71.1	70.6	69.8	69.1	69.6	69.7	69.5	68.5
		MCDB	71.9	73.2	74.4	75.8	75.2	74.5	73.4	72.5	73.1	73.5	73.8	72.8
	10%	WB	66.5	67.4	68.3	69.9	69.9	69.5	68.6	68.0	68.5	68.5	68.2	67.3
		MCDB	70.5	71.9	73.2	74.9	74.1	73.5	71.9	71.1	71.7	72.2	72.5	71.7
Mean Daily Temperature Range	5% DB	MDBR	14.8	15.4	14.9	13.9	12.0	11.1	9.7	8.3	10.0	11.4	12.8	13.8
		MCDBR	16.3	17.2	16.7	15.9	14.4	13.6	13.2	12.6	13.0	13.9	15.0	15.8
		MCWBR	11.6	11.9	11.2	10.5	9.5	8.8	8.7	8.5	8.6	9.4	9.9	10.7
	5% WB	MCDBR	15.6	16.4	15.8	14.9	13.6	12.9	12.4	11.7	12.2	13.0	14.2	15.0
		MCWBR	12.6	12.6	11.9	11.1	10.1	9.4	9.0	8.6	8.9	9.9	10.5	11.7
Clear-Sky Solar Irradiance	taub	0.325	0.338	0.378	0.420	0.403	0.388	0.387	0.390	0.389	0.381	0.345	0.334	
	taud	2.546	2.495	2.390	2.286	2.377	2.443	2.449	2.431	2.421	2.421	2.537	2.549	
	Ebn at Noon	307	307	296	282	283	284	285	287	289	289	298	301	
	Edh at Noon	31	34	39	43	39	36	36	37	37	36	31	30	
All-Sky Solar Radiation	RadAvg	1464	1669	1852	1987	1823	1695	1518	1426	1520	1521	1406	1324	
	RadStd	70	115	94	91	137	176	184	144	122	116	132	88	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	-0.52	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page