

MUNOZ, Philippines

WMO: 983290

Lat: 15.7359N

Lon: 120.9368E

Elev: 76

StdP: 100.41

Time Zone: 8.00 (E08)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.2	21.9	17.4	12.6	24.1	18.4	13.4	24.5	8.4	26.9	7.8	27.2	2.3	40	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.0	35.2	27.5	34.2	27.5	33.4	27.4	29.0	33.1	28.5	32.7	28.1	32.3	2.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.9	24.3	32.2	27.4	23.5	31.7	26.9	22.8	31.3	95.4	33.2	92.9	32.7	90.9	32.4	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.7	6.2	5.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	26.3	26.4	27.0	28.6	29.3	28.6	27.6	27.5	27.5	27.5	27.3	26.9
	DBStd	1.45	0.98	0.93	0.90	1.24	1.26	1.17	1.38	1.21	1.18	1.06	1.24	1.16
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6407	506	458	526	559	598	545	544	524	543	521	523	
	CDD18.3	3365	247	225	268	309	340	309	287	286	274	285	271	264
	CDH23.3	32499	1950	1807	2398	3504	3894	3352	2724	2704	2534	2724	2568	2337
	CDH26.7	11441	534	521	778	1514	1771	1329	868	797	761	912	917	738
(14) Wind	WSAvg	2.3	2.9	2.7	2.7	2.5	1.8	1.7	1.9	1.8	1.6	2.3	2.6	3.0
(15) Precipitation	PrecAvg	2446	12	14	22	48	214	317	525	552	412	221	70	39
	PrecMax	3231	113	81	77	197	582	738	1177	1072	736	498	220	278
	PrecMin	1781	0	1	2	5	27	101	170	256	102	42	0	0
	PrecStd	396	22	18	22	42	127	174	213	209	144	137	54	54
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	32.1	33.3	36.2	36.6	35.0	34.1	33.4	33.2	33.4	33.6	32.9
		MCWB	26.3	26.5	26.4	27.5	27.8	28.6	28.2	28.2	27.9	27.2	26.9	25.8
	2%	DB	31.1	31.2	31.9	34.9	35.5	34.1	33.1	32.2	32.2	32.5	32.7	31.9
		MCWB	25.5	26.0	26.4	27.2	27.4	28.3	27.9	27.8	27.6	27.1	26.3	25.8
	5%	DB	30.2	30.4	31.1	33.7	34.5	33.3	32.2	31.5	31.4	31.8	31.9	31.1
		MCWB	24.9	25.5	26.1	27.0	27.3	28.0	27.5	27.5	27.3	26.9	25.9	25.4
	10%	DB	29.4	29.8	30.3	32.6	33.4	32.4	31.1	30.5	30.6	31.0	31.1	30.2
		MCWB	24.4	25.1	25.7	26.7	27.2	27.6	27.1	27.0	27.0	26.5	25.7	25.0
	0.4%	WB	27.0	27.8	28.1	29.2	29.9	29.5	28.9	29.2	28.7	29.0	28.1	27.5
		MCDB	31.2	31.1	31.5	33.4	34.0	33.7	32.7	32.4	32.1	31.9	32.3	31.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.2	26.7	27.1	28.4	28.8	28.7	28.2	28.2	28.1	28.0	27.2	26.6
		MCDB	30.2	30.4	31.1	33.2	33.7	33.1	32.1	31.6	31.5	31.6	31.5	30.7
	5%	WB	25.6	26.0	26.5	27.7	28.1	28.2	27.7	27.7	27.5	27.3	26.6	25.9
		MCDB	29.4	29.9	30.5	32.7	33.2	32.6	31.4	31.0	30.9	31.0	30.9	30.0
	10%	WB	25.0	25.4	25.9	27.0	27.5	27.7	27.2	27.2	27.0	26.7	26.1	25.4
		MCDB	28.5	29.2	29.8	32.0	32.4	31.8	30.6	30.3	30.3	30.3	30.1	29.3
	5% DB	MDBR	7.0	7.1	7.6	8.7	9.0	7.7	6.6	6.1	6.5	7.1	8.0	7.3
		MCDBR	7.9	8.2	8.4	10.1	10.4	9.1	8.6	7.6	8.0	8.4	9.2	8.6
		MCWBR	3.8	4.6	4.5	4.6	4.4	4.3	4.2	4.1	4.2	4.3	4.2	4.1
		MCWBR	7.5	7.9	7.9	9.3	9.6	8.7	7.9	7.2	7.5	8.0	8.7	8.0
(40) Clear-Sky Solar Irradiance	taub		0.402	0.409	0.451	0.494	0.483	0.463	0.459	0.470	0.467	0.467	0.422	0.417
		taud	2.435	2.403	2.290	2.179	2.240	2.309	2.323	2.286	2.287	2.275	2.421	2.416
	Ebn at Noon		889	898	867	826	822	831	836	835	840	832	862	862
		Edh at Noon	111	119	137	153	142	131	129	136	135	134	112	111
(44) All-Sky Solar Radiation	RadAvg		4.29	4.98	5.58	6.17	5.75	5.27	4.72	4.40	4.77	4.58	4.19	3.90
	RadStd		0.22	0.40	0.34	0.31	0.47	0.55	0.55	0.43	0.41	0.38	0.42	0.29

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.32	+0.57	N/A	+0.40	+0.36	+0.42	N/A	N/A	+158	+158	

Nomenclature: See separate page