

CABANATUAN, Philippines

WMO: 983300

Lat: 15.471N

Lon: 120.952E

Elev: 105

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 96-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	68.3	69.8	63.5	87.9	73.9	65.0	92.9	74.0	14.4	82.4	12.5	82.0	0.9	0	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	16.9	97.3	83.8	95.8	83.5	94.3	83.3	86.4	93.8	85.6	92.9	84.8	91.8	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
84.5	182.0	92.2	83.7	177.0	91.3	82.9	172.6	90.4	51.2	94.3	50.2	93.0	49.2	91.9	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.1	9.8	8.0	63.9	100.0	5.2	1.1	60.1	100.8	57.1	101.5	54.1	102.1	50.4	102.9	
			DB	62.1	88.6	3.3	1.9	59.8	89.9	57.9	91.0	56.0	92.1	53.7	93.4
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	79.2	80.3	82.4	85.4	85.8	84.1	82.8	82.1	82.4	82.4	81.7	80.6
	DBStd	2.97	2.33	2.27	2.27	2.44	2.67	2.33	2.33	2.21	2.12	2.11	2.16	2.47
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11845	906	850	1006	1062	1111	1022	1016	996	971	1004	952	949
	CDD65	6370	441	430	541	612	646	572	551	531	521	539	502	484
	CDH74	65175	3622	3857	5615	7448	7747	6351	5592	5174	5115	5381	4876	4397
	CDH80	25776	1221	1482	2469	3752	3773	2623	1963	1612	1703	1929	1777	1472
Wind	WSAvg	2.3	2.8	2.6	2.4	2.0	2.2	1.9	2.1	2.0	1.9	2.4	2.3	3.1
Precipitation	PrecAvg	75.6	0.2	0.3	0.7	1.5	6.7	9.9	12.5	15.3	11.7	8.8	4.1	2.6
	PrecMax	104.4	0.9	1.9	4.8	9.3	23.1	23.3	23.9	27.2	24.8	26.3	13.5	20.6
	PrecMin	51.4	0.0	0.0	0.0	0.0	0.6	3.5	3.7	7.8	4.7	0.3	0.0	0.0
	PrecStd	14.3	0.2	0.5	1.0	2.0	4.6	5.2	4.8	5.4	4.3	6.0	3.6	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.9	93.0	95.7	98.8	99.7	96.5	94.2	93.0	93.0	93.3	92.8	91.6
		MCWB	80.9	81.4	82.9	84.1	84.4	84.5	85.4	85.1	84.3	83.3	82.2	81.3
	2%	DB	89.1	91.2	93.8	97.2	97.8	94.4	92.4	91.3	91.4	91.7	91.3	90.0
		MCWB	79.9	81.1	82.4	83.6	84.1	84.4	84.5	83.9	83.4	82.6	81.6	80.8
	5%	DB	87.8	89.7	92.3	95.9	96.2	92.9	90.9	89.7	89.9	90.4	90.0	88.7
		MCWB	79.3	80.4	81.8	83.2	83.6	84.0	83.7	83.1	82.7	82.1	81.2	80.1
	10%	DB	86.4	88.0	90.5	94.3	94.2	91.1	89.0	87.8	88.2	88.8	88.5	87.2
		MCWB	78.3	79.4	80.9	82.7	83.2	83.5	82.8	82.2	82.1	81.5	80.7	79.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.8	84.3	85.5	86.9	87.7	87.0	86.6	86.2	86.2	85.8	84.7	84.2
		MCDB	88.8	90.5	92.8	96.0	97.0	94.4	92.7	91.6	91.2	91.2	90.5	89.8
	2%	WB	81.5	82.6	84.0	85.6	86.2	85.7	85.4	84.7	84.6	84.3	83.5	82.6
		MCDB	87.7	89.4	91.9	95.0	95.3	92.8	91.4	90.0	89.8	89.8	89.4	88.5
	5%	WB	80.2	81.2	82.7	84.4	85.1	84.6	84.2	83.6	83.6	83.2	82.4	81.2
		MCDB	86.6	88.3	90.8	93.8	93.9	91.5	89.9	88.6	88.7	88.7	88.5	87.2
	10%	WB	79.0	79.9	81.5	83.2	83.9	83.7	82.9	82.5	82.5	82.2	81.3	80.0
		MCDB	85.4	86.9	89.4	92.7	92.5	90.1	88.2	87.1	87.3	87.5	87.2	85.9
Mean Daily Temperature Range	5% DB	MDBR	15.1	16.2	17.3	18.4	16.9	14.0	12.2	11.1	12.1	13.2	14.1	13.7
		MCDBR	16.9	18.4	19.8	20.6	19.9	16.9	15.5	14.3	14.9	15.7	16.5	15.7
		MCWBR	9.7	10.2	10.2	9.5	8.6	8.6	8.8	8.2	8.2	8.3	8.6	8.5
	5% WB	MCDBR	15.8	17.3	18.4	19.4	18.5	15.8	14.8	13.6	14.0	14.6	15.5	14.9
		MCWBR	10.1	11.0	10.8	10.4	9.8	9.0	8.4	8.8	9.1	9.4	9.4	9.4
Clear-Sky Solar Irradiance	taub	0.410	0.415	0.454	0.493	0.485	0.467	0.463	0.473	0.470	0.474	0.431	0.428	
	taud	2.418	2.391	2.281	2.183	2.234	2.298	2.314	2.278	2.282	2.256	2.396	2.386	
	Ebn at Noon	279	284	274	262	260	262	264	264	266	262	271	270	
	Edh at Noon	36	38	44	48	45	42	42	43	43	43	36	36	
All-Sky Solar Radiation	RadAvg	1362	1582	1769	1958	1816	1649	1476	1374	1505	1450	1334	1243	
	RadStd	67	123	106	98	151	175	176	138	134	123	130	91	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	+0.58	+1.03	N/A	+0.72	+0.65	+0.76	N/A	N/A	+284

Nomenclature: See separate page