

BALER RADAR, Philippines

WMO: 983340

Lat: 15.7491N

Lon: 121.6320E

Elev: 178

StdP: 99.20

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.6	21.2	17.1	12.5	21.6	18.1	13.3	22.1	8.2	20.5	6.7	20.8	3.0	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.2	32.8	28.2	32.1	27.9	31.6	27.8	29.2	31.6	28.7	31.2	28.2	30.9	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.5	25.4	31.3	28.0	24.6	30.9	27.5	24.0	30.6	96.9	31.8	94.5	31.3	92.3	31.0	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	7.8	6.4	19.7	34.7	0.6	1.1	19.3	35.5	18.9	36.1	18.5	36.7	18.1	37.5		
(5)			17.7	30.1	1.2	0.6	16.8	30.5	16.1	30.8	15.4	31.1	14.5	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	24.3	24.9	25.8	27.0	28.0	28.4	27.7	28.0	27.8	27.2	26.4	25.2	(6)
(7)		DBStd	1.88	1.56	1.51	1.47	1.18	1.09	1.20	1.30	1.31	1.26	1.34	1.27	1.46	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6111	444	417	490	511	559	552	548	559	535	532	491	472	(10)
(11)		CDD18.3	3069	186	183	232	261	301	302	290	301	285	274	241	214	(11)
(12)		CDH23.3	26222	727	854	1444	2238	3154	3375	2956	3134	2896	2452	1812	1178	(12)
(13)		CDH26.7	6798	92	135	290	536	959	1150	817	931	834	577	318	158	(13)
(14)	Wind	WSAvg	2.6	2.1	1.8	1.8	1.6	2.2	3.2	3.3	3.9	3.5	2.9	2.0	2.3	(14)
(15)	Precipitation	PrecAvg	3299	195	182	194	196	286	241	278	199	304	378	365	380	(15)
(16)		PrecMax	4233	515	383	446	478	633	548	621	381	638	649	814	954	(16)
(17)		PrecMin	2307	37	15	7	15	109	58	71	65	100	76	108	67	(17)
(18)		PrecStd	522	113	96	105	98	109	112	141	67	122	153	208	245	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.1	30.4	31.7	31.9	32.7	33.8	32.9	33.8	32.9	32.7	31.4	30.6	(19)
(20)			MCWB	26.0	26.5	26.7	27.9	28.5	29.0	28.2	28.0	27.9	27.7	27.2	27.0	(20)
(21)		2%	DB	28.6	29.3	30.3	31.0	31.9	32.7	31.8	32.4	32.1	31.4	30.3	29.4	(21)
(22)			MCWB	25.3	25.9	26.7	27.7	28.3	28.6	27.9	27.7	27.7	27.2	26.8	26.2	(22)
(23)		5%	DB	27.7	28.4	29.4	30.2	31.2	31.8	31.0	31.5	31.3	30.6	29.5	28.4	(23)
(24)			MCWB	24.7	25.3	26.2	27.4	28.0	28.2	27.6	27.4	27.5	27.0	26.5	25.5	(24)
(25)		10%	DB	26.6	27.4	28.4	29.6	30.5	31.0	30.2	30.6	30.5	29.6	28.6	27.4	(25)
(26)			MCWB	24.1	24.7	25.5	27.0	27.7	27.9	27.2	27.1	27.1	26.5	26.0	24.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.2	27.9	28.7	29.7	30.0	29.2	29.2	29.1	28.6	28.1	27.4	(27)
(28)			MCDWB	29.1	29.6	30.3	30.9	31.9	32.6	31.6	32.2	31.7	31.1	30.2	29.9	(28)
(29)		2%	WB	25.7	26.3	27.1	28.1	28.9	29.2	28.6	28.4	28.3	27.9	27.4	26.6	(29)
(30)			MCDWB	28.1	28.6	29.9	30.4	31.1	31.9	31.0	31.4	31.2	30.7	29.6	28.9	(30)
(31)		5%	WB	25.0	25.6	26.4	27.6	28.3	28.6	28.0	27.9	27.8	27.3	26.8	25.8	(31)
(32)			MCDWB	27.2	27.9	29.1	30.0	30.7	31.3	30.5	30.9	30.7	30.0	29.0	27.9	(32)
(33)		10%	WB	24.2	24.9	25.6	27.0	27.8	28.0	27.3	27.2	27.2	26.7	26.1	25.2	(33)
(34)			MCDWB	26.0	27.0	28.1	29.4	30.2	30.8	29.9	30.2	30.1	29.3	28.2	26.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.0	5.2	5.4	5.4	5.2	4.8	5.1	5.2	5.1	4.6	4.2	(35)
(36)			MCDBR	6.2	6.5	6.7	6.1	6.0	6.2	5.8	6.4	6.3	6.4	6.0	5.8	(36)
(37)			MCWBR	4.2	4.4	4.5	4.2	4.2	4.5	4.2	4.3	4.4	4.3	3.9	4.0	(37)
(38)		5% WB	MCDWB	5.7	6.2	6.4	5.8	5.8	6.0	5.6	5.9	6.0	6.0	5.6	5.5	(38)
(39)			MCWBR	4.1	4.5	4.5	4.4	4.4	4.7	4.5	4.5	4.5	4.4	3.9	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.412	0.410	0.441	0.455	0.455	0.439	0.435	0.444	0.446	0.447	0.432	0.440	(40)	
(41)		taud	2.440	2.441	2.349	2.325	2.350	2.407	2.419	2.385	2.375	2.368	2.414	2.359	(41)	
(42)		Ebn at Noon	879	898	876	859	846	851	856	857	859	851	852	838	(42)	
(43)		Edh at Noon	110	115	129	132	127	119	118	123	124	122	112	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.76	4.52	5.15	6.04	5.89	5.47	4.93	4.68	4.93	4.31	3.79	3.37	(44)	
(45)		RadStd	0.27	0.49	0.44	0.36	0.46	0.47	0.47	0.39	0.39	0.37	0.47	0.32	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (17 neighbors)		+0.32	+0.57	N/A	+0.40	+0.36	+0.42	N/A	N/A	+158

Nomenclature: See separate page