

SUBIC BAY WEATHER, Philippines

WMO: 984260

Lat: 14.800N

Lon: 120.267E

Elev: 19

StdP: 101.10

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 41231

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	22.1	14.9	10.6	26.4	15.9	11.3	26.6	10.4	27.9	9.5	28.3	2.3	70	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.7	35.2	24.7	34.3	24.8	33.5	25.0	27.6	31.7	27.1	31.1	26.7	30.6	5.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.0	30.1	26.1	21.6	29.7	25.9	21.2	29.4	88.1	31.8	85.9	31.4	84.4	31.0	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	8.5	7.5	19.7	37.3	1.0	1.0	19.0	38.0	18.4	38.6	17.9	39.1	17.2	39.9		
			16.6	29.2	1.1	0.7	15.8	29.7	15.2	30.2	14.6	30.6	13.7	31.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	26.8	27.4	28.5	29.7	29.4	28.3	27.5	27.4	27.4	27.8	27.2		
		DBStd	1.42	1.08	1.08	1.07	1.12	1.52	1.30	1.16	1.04	1.05	0.93	0.96		
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0		
		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0		
		CDD10.0	6545	520	486	574	592	601	550	542	538	523	552	534		
		CDD18.3	3503	262	253	316	342	342	300	284	279	273	294	284		
		CDH23.3	37248	2306	2405	3496	4307	4288	3413	2893	2836	2709	3069	2917		
		CDH26.7	13905	749	893	1505	2080	1982	1306	900	807	811	1058	993		
(14)	Wind	WSAvg	3.5	3.9	3.9	3.8	3.6	3.2	3.1	3.3	3.6	2.9	3.0	3.4		
(15)	Precipitation	PrecAvg	3685	3	2	3	15	262	595	724	1131	577	233	73		
		PrecMax	5401	25	26	21	90	1410	2075	1891	2461	1090	716	357		
		PrecMin	2146	0	0	0	0	0	70	174	332	21	5	0		
		PrecStd	854	6	5	5	21	318	455	368	514	292	204	82		
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.3	33.9	35.2	36.2	36.8	35.0	33.2	32.6	33.0	33.2	33.1		
			MCWB	23.6	23.3	24.0	24.5	25.3	26.3	26.3	26.4	26.4	25.4	24.9		
		2%	DB	31.8	32.9	34.2	35.4	35.2	33.4	32.2	31.8	32.0	32.3	32.2		
			MCWB	23.5	23.2	23.6	24.5	25.2	26.5	26.1	26.2	25.9	25.4	24.8		
		5%	DB	31.0	32.0	33.2	34.7	34.0	32.2	31.2	30.9	31.1	31.9	31.9		
			MCWB	23.3	23.2	23.6	24.5	25.9	26.4	26.1	25.9	26.1	25.4	24.8		
		10%	DB	30.1	31.1	32.2	33.5	33.0	31.7	30.6	30.0	30.2	31.0	31.0		
			MCWB	23.0	23.1	23.8	24.9	26.1	26.3	26.0	25.7	25.9	25.4	24.8		
		0.4%	WB	25.5	26.0	27.0	27.9	28.3	28.2	27.3	27.5	27.5	27.4	26.7		
			MCDB	30.0	30.5	32.2	32.9	32.9	32.4	30.6	29.9	30.8	30.8	30.5		
		2%	WB	24.7	25.2	26.0	27.0	27.5	27.4	26.7	26.8	26.7	26.7	26.1		
			MCDB	29.5	29.9	30.9	32.0	32.1	31.5	30.2	29.4	30.0	30.4	30.1		
(31)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	24.2	24.6	25.4	26.5	26.9	26.8	26.5	26.5	26.4	26.2	25.7		
			MCDB	29.1	29.5	30.4	31.5	31.5	30.8	29.9	29.2	29.7	30.0	29.8		
		10%	WB	23.8	24.0	24.9	26.1	26.6	26.5	26.2	26.2	26.1	25.9	25.3		
			MCDB	28.6	29.1	30.0	31.1	31.1	30.3	29.5	28.9	29.3	29.7	29.5		
		5% DB	MDBR	7.8	8.4	9.0	8.7	7.4	6.4	5.8	5.2	5.9	6.8	6.9		
			MCDBR	8.4	9.2	9.8	9.9	9.2	7.7	7.3	6.7	7.1	7.9	7.8		
(36)	Mean Daily Temperature Range	5% WB	MCWBR	3.4	3.5	3.5	3.6	3.5	3.3	3.3	3.1	3.3	3.3	3.2		
			MCDBR	7.9	8.3	8.7	8.3	7.6	6.8	6.2	5.4	6.3	7.0	7.0		
		5% WB	MCWBR	3.6	3.7	3.8	3.6	3.4	3.3	3.1	2.9	3.3	3.4	3.4		
			MCDBR	3.6	3.7	3.8	3.6	3.4	3.3	3.1	2.9	3.3	3.4	3.4		
(40)	Clear-Sky Solar Irradiance	taub		0.414	0.421	0.458	0.497	0.476	0.468	0.468	0.473	0.468	0.484	0.433		
		taud		2.448	2.411	2.313	2.208	2.303	2.344	2.340	2.317	2.324	2.256	2.423		
		Ebn at Noon		880	889	862	824	828	826	828	833	841	820	854		
		Edh at Noon		110	119	134	149	133	126	127	132	131	137	112		
(44)	All-Sky Solar Radiation	RadAvg		4.80	5.54	6.21	6.66	5.88	5.17	4.54	4.35	4.76	4.90	4.67		
		RadStd		0.23	0.35	0.29	0.30	0.54	0.64	0.68	0.52	0.52	0.40	0.38		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	+0.72	+0.40	+0.30	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+0.26	N/A	N/A	N/A	+0.34	+0.42	N/A	N/A	+158	+158

Nomenclature: See separate page