

TAYABAS, Philippines

WMO: 984270

Lat: 14.0184N

Lon: 121.5967E

Elev: 158

StdP: 99.44

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.3	21.8	18.9	13.9	22.6	19.5	14.5	22.8	7.3	24.4	6.5	24.6	2.4	0	0.291

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.9	32.9	27.3	32.3	27.2	31.8	27.1	28.4	31.4	28.0	31.2	27.6	30.8	2.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	24.0	30.8	27.1	23.3	30.5	26.7	22.7	30.2	93.0	31.6	91.0	31.2	89.3	31.0	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.3	5.5	5.0	18.8	35.0	2.5	1.8	17.0	36.2	15.5	37.3	14.1	38.3	12.3	39.6		
			17.1	29.2	2.1	0.6	15.6	29.6	14.4	30.0	13.2	30.3	11.7	30.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	24.8	25.2	26.2	27.7	28.2	27.8	27.1	27.3	27.1	26.7	26.3	25.3
	DBStd	1.51	1.19	1.23	1.20	1.12	1.04	1.00	1.07	0.97	0.98	0.97	1.02	1.23
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6081	458	427	501	531	565	534	532	536	512	518	491	476
	CDD18.3	3039	200	193	243	281	307	284	273	278	262	260	241	217
	CDH23.3	26414	973	1138	1855	2830	3357	3031	2615	2721	2404	2253	1911	1326
	CDH26.7	7318	104	192	447	954	1233	1046	753	818	697	545	361	168
Wind	WSAvg	1.7	2.6	2.2	2.1	1.6	1.1	1.0	1.2	1.3	1.1	1.6	2.2	2.7
Precipitation	PrecAvg	2439	92	75	54	63	143	208	221	189	280	357	396	360
	PrecMax	3637	229	268	152	345	495	428	467	460	632	806	851	893
	PrecMin	983	22	3	17	3	1	50	56	79	97	128	104	81
	PrecStd	818	71	80	42	83	138	110	118	87	147	178	228	246
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.7	30.5	31.7	33.2	33.7	33.2	32.7	32.7	32.6	31.8	31.1	30.3
		MCWB	25.7	26.4	26.5	26.8	27.3	27.6	27.6	27.5	27.6	27.2	27.0	26.4
	2%	DB	28.7	29.6	30.7	32.4	32.9	32.5	31.7	31.9	31.7	31.0	30.3	29.4
		MCWB	25.3	25.8	26.1	26.7	27.2	27.5	27.3	27.4	27.3	26.8	26.6	25.9
	5%	DB	27.9	28.8	30.1	31.6	32.1	31.8	31.0	31.2	31.0	30.3	29.6	28.5
		MCWB	24.8	25.3	25.9	26.6	27.1	27.4	27.1	27.0	27.1	26.6	26.3	25.4
	10%	DB	27.0	28.0	29.3	30.9	31.4	31.0	30.2	30.3	30.1	29.5	28.8	27.6
		MCWB	24.2	24.7	25.5	26.3	27.0	27.1	26.7	26.7	26.8	26.2	25.9	25.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	27.2	27.6	28.3	28.8	29.0	28.5	28.7	28.6	28.2	27.7	27.1
		MCDB	28.8	29.6	30.3	31.1	31.8	31.8	31.5	31.6	31.4	30.8	30.1	29.5
	2%	WB	25.7	26.3	26.8	27.5	28.1	28.2	27.9	28.0	27.9	27.5	27.1	26.3
		MCDB	28.1	28.9	30.0	31.0	31.5	31.4	30.9	31.0	30.9	30.2	29.7	28.7
	5%	WB	25.1	25.6	26.2	27.0	27.6	27.7	27.3	27.4	27.3	27.0	26.5	25.7
		MCDB	27.4	28.2	29.5	30.9	31.2	31.0	30.4	30.4	30.4	29.7	29.1	28.0
	10%	WB	24.5	25.0	25.6	26.6	27.2	27.2	26.9	26.9	26.9	26.4	26.0	25.1
		MCDB	26.5	27.6	28.8	30.4	30.8	30.5	29.9	29.9	29.8	29.0	28.5	27.1
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	5.8	6.7	6.9	6.7	6.1	6.2	6.4	5.7	4.8	4.1
		MCDBR	5.6	6.5	7.1	7.6	7.8	7.8	7.4	7.6	7.7	7.0	6.2	5.4
		MCWBR	3.4	3.8	3.9	3.7	4.0	4.4	4.5	4.5	4.8	4.2	3.7	3.2
	5% WB	MCDBR	5.2	6.2	6.8	7.1	7.3	7.2	7.0	7.0	7.3	6.5	5.8	5.0
		MCWBR	3.5	4.1	4.2	4.0	4.3	4.6	4.6	4.7	4.9	4.4	3.9	3.3
Clear-Sky Solar Irradiance	taub	0.429	0.419	0.442	0.447	0.448	0.445	0.441	0.448	0.446	0.462	0.443	0.452	
	taud	2.384	2.405	2.343	2.335	2.362	2.385	2.398	2.371	2.372	2.307	2.365	2.312	
	Ebn at Noon	867	893	877	866	851	845	850	854	861	841	847	832	
	Edh at Noon	118	120	130	131	125	121	120	125	125	130	119	124	
All-Sky Solar Radiation	RadAvg	3.91	4.73	5.38	6.17	5.68	5.22	4.71	4.64	4.71	4.32	4.00	3.47	
	RadStd	0.32	0.51	0.47	0.38	0.49	0.38	0.46	0.33	0.41	0.31	0.37	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	+0.31	+0.49	N/A	+0.45	+0.37	+0.47	N/A	N/A	+158	+158

Nomenclature: See separate page