

QUEZON CITY SCIENCE GARDEN, Philippines

WMO: 984300

Lat: 14.6452N

Lon: 121.0441E

Elev: 46

StdP: 100.77

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.3	21.2	16.9	12.1	24.9	17.7	12.7	24.8	6.0	28.1	5.1	28.2	0.3	0	0.299

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.0	35.1	25.9	34.3	25.9	33.7	25.9	27.7	32.2	27.3	31.7	27.1	31.3	2.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	29.9	26.2	21.7	29.5	26.0	21.4	29.2	88.4	32.4	86.9	31.9	85.7	31.6	33.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.4	3.6	DB	17.9	37.1	2.0	1.2	16.4	37.9	15.2	38.6	14.1	39.3	12.6	40.1	(4)
(5)			WB	16.5	29.6	1.6	1.6	15.3	30.8	14.4	31.7	13.5	32.6	12.4	33.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	25.9	26.6	27.6	29.2	29.5	28.7	27.9	27.8	27.8	27.7	27.3	26.5	(6)
(7)		DBStd	1.57	1.21	1.22	1.20	1.21	1.27	1.24	1.21	1.20	1.12	0.99	1.06	1.21	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6465	492	463	547	574	606	562	556	551	534	548	521	511	(10)
(11)		CDD18.3	3423	234	230	289	324	347	312	297	293	284	289	271	253	(11)
(12)		CDH23.3	36134	1907	2167	3161	4120	4408	3617	3084	3046	2913	2931	2626	2156	(12)
(13)		CDH26.7	13604	556	778	1303	1987	2108	1463	1022	961	933	978	882	633	(13)
(14)	Wind	WSAvg	1.1	1.0	1.0	1.0	1.1	1.2	1.1	1.2	1.3	1.1	1.0	1.0	1.1	(14)
(15)	Precipitation	PrecAvg	2134	10	4	12	23	126	312	438	462	358	202	133	55	(15)
(16)		PrecMax	3338	39	18	45	67	469	725	1744	1188	885	411	352	145	(16)
(17)		PrecMin	1531	0	0	0	0	15	96	100	211	36	31	13	0	(17)
(18)		PrecStd	487	11	6	16	26	126	194	400	236	225	108	98	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	33.2	34.2	35.9	36.2	34.9	33.7	33.2	33.4	33.2	33.2	32.7	(19)
(20)			MCWB	24.5	24.5	24.9	25.7	26.0	26.6	26.7	26.8	26.6	25.6	25.4	24.8	(20)
(21)		2%	DB	31.0	32.2	33.5	35.0	35.2	33.9	32.7	32.2	32.4	32.3	32.4	31.7	(21)
(22)			MCWB	24.3	24.4	24.9	25.6	26.1	26.7	26.6	26.5	26.4	25.7	25.4	24.9	(22)
(23)		5%	DB	30.3	31.6	32.8	34.3	34.4	33.1	31.9	31.5	31.6	31.7	31.6	30.8	(23)
(24)			MCWB	24.1	24.3	24.8	25.6	26.1	26.7	26.5	26.4	26.4	25.8	25.4	24.9	(24)
(25)		10%	DB	29.5	30.7	32.0	33.6	33.6	32.2	31.0	30.7	30.8	30.9	30.8	29.9	(25)
(26)			MCWB	23.9	24.2	24.6	25.5	26.2	26.6	26.3	26.3	26.3	25.7	25.3	24.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.8	27.0	27.7	28.2	27.7	27.7	27.6	27.5	27.1	26.7	(27)	
(28)			MCDWB	29.7	30.8	31.9	33.3	33.1	32.8	32.0	31.4	31.4	31.1	31.0	30.1	(28)
(29)		2%	WB	25.3	25.8	26.2	27.0	27.6	27.5	27.2	27.1	27.1	26.9	26.5	26.1	(29)
(30)			MCDWB	29.2	30.2	31.2	32.7	32.6	32.0	31.2	30.7	30.8	30.4	30.4	29.7	(30)
(31)		5%	WB	24.9	25.2	25.8	26.6	27.1	27.1	26.8	26.8	26.7	26.6	26.1	25.6	(31)
(32)			MCDWB	28.9	29.7	30.7	32.2	32.1	31.5	30.6	30.1	30.2	29.9	29.9	29.1	(32)
(33)		10%	WB	24.5	24.7	25.2	26.2	26.8	26.8	26.5	26.5	26.4	26.2	25.7	25.1	(33)
(34)			MCDWB	28.3	29.2	30.2	31.7	31.5	30.9	30.0	29.6	29.7	29.4	29.3	28.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.6	8.3	8.6	8.9	8.0	6.8	6.1	5.6	6.0	6.7	7.1	6.9	(35)
(36)			MCDBR	8.6	9.6	9.8	9.9	9.3	8.2	7.7	7.1	7.4	8.0	8.5	8.4	(36)
(37)			MCWBR	3.7	4.0	3.9	3.6	3.1	2.8	2.9	2.7	2.7	2.9	3.1	3.3	(37)
(38)		5% WB	MCDBR	7.7	8.3	8.7	8.9	8.2	7.3	6.8	6.2	6.7	6.8	7.3	7.1	(38)
(39)			MCWBR	3.8	4.1	4.2	3.7	3.3	3.0	2.9	2.7	2.8	3.1	3.2	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.420	0.418	0.450	0.475	0.475	0.467	0.462	0.471	0.466	0.476	0.439	0.439	(40)	
(41)		taud	2.415	2.407	2.319	2.254	2.282	2.321	2.335	2.303	2.310	2.264	2.385	2.366	(41)	
(42)		Ebn at Noon	875	893	870	842	829	827	832	834	842	827	849	843	(42)	
(43)		Edh at Noon	114	119	133	142	136	129	128	134	133	136	117	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.18	4.94	5.58	6.28	5.71	5.14	4.54	4.37	4.64	4.43	4.14	3.73	(44)	
(45)		RadStd	0.25	0.43	0.39	0.34	0.50	0.51	0.57	0.44	0.45	0.36	0.38	0.32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		+0.32	+0.47	N/A	+0.45	+0.40	+0.54	N/A	N/A	+158	+158

Nomenclature: See separate page