

INFANTA, Philippines

WMO: 984340

Lat: 14.7484N

Lon: 121.6781E

Elev: 23

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.1	72.2	67.4	100.8	74.1	68.9	106.1	74.6	15.2	73.2	13.8	74.0	5.1	0	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.1	94.0	82.3	92.8	82.0	91.6	81.8	84.3	90.5	83.4	89.9	82.7	89.3	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.7	170.7	88.8	81.7	165.1	87.9	81.0	161.0	87.1	48.5	90.6	47.4	90.1	46.7	89.6	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.6	11.5	10.1	DB	65.7	96.7	4.4	1.7	62.5	97.9	59.9	98.8	57.4	99.8	54.2	101.0	
			WB	64.6	85.8	3.4	1.9	62.1	87.2	60.1	88.3	58.2	89.4	55.7	90.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	77.3	77.8	79.5	82.2	84.0	84.4	83.5	83.8	82.9	81.5	80.5	78.8
	DBStd	3.21	2.29	2.34	2.22	2.11	1.93	2.15	2.25	2.24	2.22	1.95	1.89	2.11
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11447	847	777	916	965	1053	1031	1038	1046	988	978	915	893
	CDD65	5972	382	357	451	515	588	581	573	581	538	513	465	428
	CDH74	61516	2363	2464	3931	5760	7182	7167	6681	6875	5995	5295	4430	3373
	CDH80	19999	222	380	872	2028	3026	3106	2628	2746	2172	1512	894	413
Wind	WSAvg	3.8	5.2	4.3	3.9	3.1	2.7	2.8	3.0	3.1	2.8	3.8	4.7	5.8
Precipitation	PrecAvg	155.0	13.7	9.3	6.9	7.0	8.3	8.7	10.6	7.7	14.1	21.1	25.8	26.6
	PrecMax	212.2	22.2	26.5	15.9	15.6	20.7	21.0	24.1	18.9	32.6	35.3	45.3	58.9
	PrecMin	89.1	6.3	3.2	3.5	1.3	1.0	3.1	3.3	2.4	3.5	11.1	7.4	6.1
	PrecStd	31.6	4.6	6.1	3.7	4.5	6.5	5.2	6.1	4.2	7.7	8.1	11.3	14.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.2	87.5	89.8	92.4	95.0	95.4	94.7	94.5	94.3	91.8	88.9	87.0
		MCWB	78.7	78.4	79.9	81.5	82.9	82.4	82.3	82.0	82.4	81.1	80.9	80.3
	2%	DB	83.7	85.5	87.7	90.5	93.1	93.8	92.7	92.7	92.0	89.6	87.1	85.1
		MCWB	78.2	78.2	79.7	81.1	82.1	82.4	82.0	81.7	81.9	81.1	80.5	79.7
	5%	DB	82.5	84.0	86.2	89.2	91.5	92.3	91.1	91.2	90.3	87.8	85.7	83.7
		MCWB	77.5	77.8	79.3	80.8	81.8	82.2	81.7	81.6	81.6	80.6	80.1	79.0
	10%	DB	81.1	82.5	84.7	87.9	90.0	90.7	89.5	89.6	88.7	86.3	84.4	82.3
		MCWB	76.9	77.3	78.8	80.5	81.7	82.0	81.4	81.3	81.2	80.1	79.7	78.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	80.2	81.8	84.0	85.0	85.7	84.5	84.7	84.8	83.1	82.2	81.5
		MCDB	83.7	84.5	86.7	89.0	90.8	91.3	90.7	90.8	90.6	88.1	86.4	84.9
	2%	WB	79.0	79.1	80.7	82.6	83.6	83.9	83.2	83.3	83.2	82.0	81.2	80.5
		MCDB	82.5	83.3	86.0	88.2	90.1	90.8	90.1	89.8	89.5	87.2	85.1	84.1
	5%	WB	78.2	78.5	79.9	81.7	82.7	83.0	82.4	82.4	82.2	81.2	80.7	79.7
		MCDB	81.4	82.6	84.9	87.5	89.4	90.0	89.6	89.1	88.6	86.1	84.6	82.6
	10%	WB	77.4	77.7	79.1	80.9	82.1	82.4	81.6	81.6	81.4	80.6	80.1	79.0
		MCDB	80.0	81.4	83.7	86.7	88.7	89.5	88.4	88.1	87.4	85.3	83.5	81.4
Mean Daily Temperature Range	5% DB	MDBR	6.4	8.0	9.0	10.8	11.9	12.1	11.2	10.9	11.1	9.2	7.3	6.0
		MCDBR	8.8	11.2	11.9	13.4	14.5	14.6	14.1	13.6	13.7	11.9	9.7	8.4
		MCWBR	4.9	5.7	5.9	6.0	6.3	6.4	6.3	6.1	6.3	5.8	4.9	4.5
	5% WB	MCDBR	7.8	9.4	10.8	11.9	12.7	13.1	13.0	12.3	12.4	10.5	8.6	7.6
MCWBR		4.8	5.5	6.1	6.3	6.5	6.7	6.6	6.5	6.6	5.8	4.8	4.6	
Clear-Sky Solar Irradiance	taub	0.438	0.428	0.454	0.459	0.462	0.453	0.449	0.458	0.456	0.470	0.457	0.467	
	taud	2.371	2.400	2.327	2.323	2.341	2.378	2.392	2.358	2.361	2.303	2.336	2.276	
	Ebn at Noon	272	280	275	272	266	266	268	268	270	264	263	259	
	Edh at Noon	38	38	42	42	41	39	38	40	40	42	39	41	
All-Sky Solar Radiation	RadAvg	1195	1442	1638	1915	1804	1657	1479	1440	1482	1327	1210	1055	
	RadStd	89	156	144	120	148	132	150	114	123	110	125	109	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.56	+0.88	N/A	+0.81	+0.67	+0.85	N/A	N/A	+284	+284

Nomenclature: See separate page