

INFANTA, Philippines

WMO: 984340

Lat: 14.7484N

Lon: 121.6781E

Elev: 7

StdP: 101.24

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	22.4	19.7	14.4	23.4	20.5	15.2	23.7	6.8	22.9	6.2	23.4	2.3	0	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.7	34.5	27.9	33.8	27.8	33.1	27.7	29.1	32.5	28.6	32.1	28.2	31.8	1.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.2	24.4	31.5	27.6	23.6	31.0	27.2	23.0	30.6	95.0	32.6	92.5	32.3	90.6	32.0	32.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.6	5.1	4.5	DB	18.7	35.9	2.5	0.9	17.0	36.6	15.5	37.1	14.1	37.7	12.3	38.3	(4)
			WB	18.1	29.9	1.9	1.1	16.7	30.7	15.6	31.3	14.5	31.9	13.2	32.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	25.2	25.4	26.4	27.9	28.9	29.1	28.6	28.8	28.3	27.5	26.9	26.0
	DBStd	1.79	1.27	1.30	1.23	1.17	1.07	1.20	1.25	1.25	1.23	1.08	1.05	1.17
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6359	471	432	509	536	585	573	577	581	549	543	508	496
	CDD18.3	3318	212	198	251	286	327	323	318	323	299	285	258	238
	CDH23.3	34176	1313	1369	2184	3200	3990	3982	3712	3819	3331	2942	2461	1874
	CDH26.7	11111	123	211	484	1127	1681	1726	1460	1526	1207	840	497	229
Wind	WSAvg	1.7	2.3	1.9	1.7	1.4	1.2	1.3	1.4	1.4	1.3	1.7	2.1	2.6
Precipitation	PrecAvg	3937	348	235	176	177	212	220	269	196	357	536	655	676
	PrecMax	5390	564	674	404	397	527	534	613	479	827	896	1150	1496
	PrecMin	2264	160	81	88	34	25	78	84	60	88	281	187	156
	PrecStd	802	117	156	94	114	164	132	154	106	196	206	288	368
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	30.8	32.1	33.6	35.0	35.2	34.9	34.7	34.6	33.2	31.6	30.6
		MCWB	26.0	25.8	26.6	27.5	28.3	28.0	28.0	27.8	28.0	27.3	27.2	26.8
	2%	DB	28.7	29.7	31.0	32.5	34.0	34.4	33.7	33.7	33.3	32.0	30.6	29.5
		MCWB	25.7	25.6	26.5	27.3	27.9	28.0	27.8	27.6	27.7	27.3	27.0	26.5
	5%	DB	28.1	28.9	30.1	31.8	33.0	33.5	32.9	32.9	32.4	31.0	29.8	28.7
		MCWB	25.3	25.4	26.3	27.1	27.7	27.9	27.6	27.6	27.5	27.0	26.7	26.1
	10%	DB	27.3	28.0	29.3	31.1	32.2	32.6	32.0	32.0	31.5	30.2	29.1	27.9
		MCWB	24.9	25.2	26.0	27.0	27.6	27.8	27.5	27.4	27.3	26.7	26.5	25.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	26.8	27.7	28.9	29.4	29.8	29.1	29.3	29.3	28.4	27.9	27.5
		MCDB	28.7	29.2	30.4	31.7	32.7	32.9	32.6	32.7	32.6	31.2	30.2	29.4
	2%	WB	26.1	26.2	27.1	28.1	28.7	28.9	28.4	28.5	28.5	27.8	27.3	27.0
		MCDB	28.0	28.5	30.0	31.2	32.3	32.7	32.3	32.1	31.9	30.7	29.5	28.9
	5%	WB	25.7	25.8	26.6	27.6	28.2	28.3	28.0	28.0	27.9	27.3	27.1	26.5
		MCDB	27.4	28.1	29.4	30.8	31.9	32.2	32.0	31.7	31.4	30.0	29.2	28.1
	10%	WB	25.2	25.4	26.1	27.2	27.8	28.0	27.6	27.5	27.4	27.0	26.7	26.1
		MCDB	26.7	27.4	28.7	30.4	31.5	32.0	31.3	31.2	30.8	29.6	28.6	27.5
Mean Daily Temperature Range	5% DB	MDBR	3.5	4.4	5.0	6.0	6.6	6.7	6.2	6.1	6.1	5.1	4.1	3.3
		MCDBR	4.9	6.2	6.6	7.4	8.1	8.1	7.8	7.5	7.6	6.6	5.4	4.7
		MCWBR	2.7	3.2	3.3	3.3	3.5	3.6	3.5	3.4	3.5	3.2	2.7	2.5
	5% WB	MCDBR	4.3	5.2	6.0	6.6	7.0	7.3	7.2	6.9	6.9	5.8	4.8	4.2
		MCWBR	2.6	3.1	3.4	3.5	3.6	3.7	3.7	3.6	3.7	3.2	2.7	2.6
Clear-Sky Solar Irradiance	taub	0.438	0.428	0.454	0.459	0.462	0.453	0.449	0.458	0.456	0.470	0.457	0.467	
	taud	2.371	2.400	2.327	2.323	2.341	2.378	2.392	2.358	2.361	2.303	2.336	2.276	
	Ebn at Noon	856	883	866	856	840	838	844	845	851	832	830	815	
	Edh at Noon	119	120	132	133	128	122	121	126	126	131	122	128	
All-Sky Solar Radiation	RadAvg	3.77	4.54	5.16	6.04	5.69	5.22	4.66	4.54	4.67	4.18	3.81	3.33	
	RadStd	0.28	0.49	0.46	0.38	0.47	0.42	0.47	0.36	0.39	0.35	0.39	0.34	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (17 neighbors)	+0.31	+0.49	N/A	+0.45	+0.37	+0.47	N/A	N/A	+158	+158	

Nomenclature: See separate page