

ALABAT, Philippines

WMO: 984350

Lat: 14.1054N

Lon: 122.0177E

Elev: 16

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.8	73.9	68.1	103.4	75.2	69.4	108.0	75.6	18.7	75.2	16.8	76.1	5.3	40	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.0	91.6	82.5	90.5	82.2	89.6	81.9	83.7	89.8	83.1	89.0	82.6	88.4	5.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.9	166.0	88.6	81.3	162.9	88.1	80.8	160.0	87.6	47.8	90.2	47.1	89.5	46.5	88.7	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
16.4	13.6	11.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			68.2	94.4	4.9	2.7	64.6	96.3	61.7	97.9	59.0	99.4	55.4	101.3		
			66.9	85.0	3.7	1.2	64.2	85.9	62.0	86.5	60.0	87.2	57.3	88.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	78.4	78.8	80.2	82.4	84.0	83.5	82.6	83.0	82.4	81.5	80.8	79.6	(6)
(7)		DBStd	2.48	1.84	1.88	1.81	1.61	1.42	1.75	1.69	1.83	1.75	1.65	1.79	1.72	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11474	880	806	936	971	1053	1006	1010	1023	971	977	923	918	(10)
(11)		CDD65	5999	415	386	471	521	588	556	545	558	521	512	473	453	(11)
(12)		CDH74	62649	3076	3045	4394	5864	7234	6648	6165	6446	5693	5355	4740	3989	(12)
(13)		CDH80	18281	273	420	904	1931	2965	2603	2091	2299	1826	1437	1006	526	(13)
(14)	Wind	WSAvg	4.8	6.2	5.3	5.1	4.1	3.5	3.4	4.1	4.2	3.9	4.6	5.7	7.0	(14)
(15)	Precipitation	PrecAvg	133.0	9.2	6.7	3.9	3.0	4.3	8.6	8.8	7.7	11.8	20.9	19.3	27.0	(15)
(16)		PrecMax	203.0	17.8	23.3	10.6	8.4	16.1	17.8	18.1	18.0	23.4	43.1	29.9	73.5	(16)
(17)		PrecMin	81.3	2.4	0.4	0.5	0.3	0.1	2.4	2.6	2.2	4.0	10.4	9.1	9.0	(17)
(18)		PrecStd	28.9	4.1	6.1	3.0	2.2	4.6	4.9	4.5	4.2	5.8	7.8	6.7	17.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.7	86.3	88.2	91.1	93.2	92.8	91.4	91.8	91.3	89.7	88.1	86.6	(19)
(20)			MCWB	79.0	79.7	80.4	81.1	82.9	83.2	82.3	82.6	82.1	81.9	81.1	80.2	(20)
(21)		2%	DB	83.5	84.8	86.6	89.4	91.6	91.2	89.8	90.1	89.6	88.1	86.6	85.1	(21)
(22)			MCWB	78.3	78.8	79.7	81.2	82.7	82.6	81.9	82.0	81.8	81.1	80.6	79.7	(22)
(23)		5%	DB	82.5	83.7	85.5	88.2	90.2	89.9	88.7	89.0	88.4	87.0	85.6	83.9	(23)
(24)			MCWB	77.6	78.2	79.2	80.9	82.3	82.1	81.5	81.5	81.4	80.6	80.1	79.1	(24)
(25)		10%	DB	81.6	82.7	84.4	87.0	89.1	88.7	87.4	87.8	87.2	85.8	84.4	82.7	(25)
(26)			MCWB	77.0	77.6	78.8	80.5	81.9	81.7	81.1	81.1	80.9	80.2	79.5	78.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	80.8	82.0	83.2	84.9	84.6	83.6	84.0	83.5	82.8	82.1	81.0	(27)
(28)			MCD B	83.8	85.2	86.6	88.9	91.2	90.8	89.4	90.3	89.2	88.0	86.6	85.0	(28)
(29)		2%	WB	79.0	79.6	80.8	82.3	83.6	83.5	82.7	82.8	82.6	81.8	81.1	80.3	(29)
(30)			MCD B	82.7	84.0	85.5	88.0	89.9	89.7	88.5	88.8	88.3	87.1	85.6	84.2	(30)
(31)		5%	WB	78.1	78.8	79.9	81.5	82.9	82.7	82.0	82.1	81.8	81.0	80.5	79.4	(31)
(32)			MCD B	81.8	83.2	84.6	87.2	89.1	88.8	87.6	87.9	87.4	86.0	84.9	83.2	(32)
(33)		10%	WB	77.4	78.0	79.1	80.8	82.3	82.0	81.3	81.4	81.0	80.3	79.8	78.6	(33)
(34)			MCD B	80.9	82.1	83.6	86.3	88.3	87.9	86.7	87.0	86.4	85.1	83.9	82.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	7.5	8.1	9.6	11.0	10.6	9.7	9.5	9.7	8.3	6.8	5.6	(35)
(36)			MCD BR	7.3	9.2	10.0	11.4	12.7	12.3	11.8	11.5	11.6	10.4	8.7	7.5	(36)
(37)			MCWBR	4.9	6.0	6.1	6.4	7.0	6.7	6.7	6.6	6.8	6.2	5.5	4.8	(37)
(38)		5% WB	MCD BR	6.9	8.5	9.1	10.6	11.9	11.7	11.1	10.9	11.0	9.8	8.1	7.2	(38)
(39)			MCWBR	4.9	6.0	6.2	6.7	7.4	7.1	7.0	6.9	7.0	6.3	5.4	4.9	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.445	0.432	0.453	0.451	0.451	0.449	0.446	0.453	0.451	0.470	0.458	0.472	(41)	
(42)		taud	2.349	2.387	2.329	2.343	2.371	2.390	2.400	2.372	2.374	2.304	2.331	2.259	(42)	
(43)		Ebn at Noon	270	279	275	274	269	267	268	269	272	265	264	258	(43)	
(44)		Edh at Noon	39	39	42	41	39	38	38	40	39	42	39	42	(44)	
(45)	All-Sky Solar Radiation	RadAvg	1237	1501	1707	1963	1838	1697	1530	1526	1532	1377	1274	1105	(45)	
(46)		RadStd	107	165	157	121	155	115	139	96	125	101	124	116	(46)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.63	+1.08	N/A	+0.74	+0.65	+1.01	N/A	N/A	+329	+329

Nomenclature: See separate page