

ALABAT, Philippines

WMO: 984350

Lat: 14.1054N

Lon: 122.0177E

Elev: 5

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	23.3	20.1	14.8	24.0	20.8	15.4	24.2	8.3	24.0	7.5	24.5	2.4	40	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.1	33.1	28.1	32.5	27.9	32.0	27.7	28.7	32.1	28.4	31.7	28.1	31.4	2.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.7	31.5	27.4	23.3	31.2	27.1	22.9	30.9	93.3	32.4	91.6	31.9	90.2	31.5	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.3	6.1	5.2	DB	20.1	34.7	2.7	1.5	18.1	35.7	16.5	36.6	15.0	37.4	13.0	38.5
			WB	19.4	29.5	2.1	0.7	17.9	29.9	16.7	30.3	15.5	30.7	14.0	31.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	25.8	26.0	26.8	28.0	28.9	28.6	28.1	28.3	28.0	27.5	27.1	26.5	(6)
(7)		DBStd	1.38	1.02	1.04	1.00	0.90	0.79	0.97	0.94	1.01	0.97	0.92	0.99	0.95	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6374	489	448	520	539	585	559	561	568	539	543	513	510	(10)
(11)		CDD18.3	3333	231	214	262	289	327	309	303	310	289	284	263	252	(11)
(12)		CDH23.3	34805	1709	1692	2441	3258	4019	3693	3425	3581	3163	2975	2633	2216	(12)
(13)		CDH26.7	10156	152	233	502	1073	1647	1446	1162	1277	1014	798	559	292	(13)
(14)	Wind	WSAvg	2.1	2.8	2.4	2.3	1.8	1.6	1.5	1.8	1.9	1.7	2.1	2.5	3.1	(14)
(15)	Precipitation	PrecAvg	3379	233	170	99	77	110	219	223	195	300	531	489	686	(15)
(16)		PrecMax	5156	453	591	269	213	410	453	461	457	595	1094	759	1866	(16)
(17)		PrecMin	2064	62	11	13	7	2	61	66	57	102	265	230	228	(17)
(18)		PrecStd	735	103	154	76	56	118	124	114	106	147	198	171	453	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.3	30.2	31.2	32.9	34.0	33.8	33.0	33.2	32.9	32.0	31.2	30.3	(19)
(20)			MCWB	26.1	26.5	26.9	27.3	28.3	28.4	27.9	28.1	27.8	27.7	27.3	26.8	(20)
(21)		2%	DB	28.6	29.4	30.3	31.9	33.1	32.9	32.1	32.3	32.0	31.2	30.3	29.5	(21)
(22)			MCWB	25.7	26.0	26.5	27.3	28.2	28.1	27.7	27.8	27.7	27.3	27.0	26.5	(22)
(23)		5%	DB	28.1	28.7	29.7	31.2	32.3	32.2	31.5	31.7	31.3	30.5	29.8	28.8	(23)
(24)			MCWB	25.3	25.7	26.2	27.2	28.0	27.8	27.5	27.5	27.4	27.0	26.7	26.2	(24)
(25)		10%	DB	27.5	28.2	29.1	30.6	31.7	31.5	30.8	31.0	30.7	29.9	29.1	28.2	(25)
(26)			MCWB	25.0	25.3	26.0	27.0	27.7	27.6	27.3	27.3	27.2	26.8	26.4	25.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.1	27.8	28.5	29.4	29.2	28.7	28.9	28.6	28.2	27.8	27.2	(27)
(28)			MCDWB	28.8	29.5	30.3	31.6	32.9	32.7	31.9	32.4	31.8	31.1	30.3	29.4	(28)
(29)		2%	WB	26.1	26.4	27.1	27.9	28.7	28.6	28.2	28.2	28.1	27.7	27.3	26.8	(29)
(30)			MCDWB	28.2	28.9	29.7	31.1	32.2	32.1	31.4	31.6	31.3	30.6	29.8	29.0	(30)
(31)		5%	WB	25.6	26.0	26.6	27.5	28.3	28.2	27.8	27.8	27.7	27.2	27.0	26.3	(31)
(32)			MCDWB	27.6	28.4	29.2	30.6	31.7	31.5	30.9	31.1	30.8	30.0	29.4	28.4	(32)
(33)		10%	WB	25.2	25.5	26.1	27.1	27.9	27.8	27.4	27.4	27.2	26.8	26.5	25.9	(33)
(34)			MCDWB	27.2	27.8	28.7	30.2	31.3	31.0	30.4	30.5	30.2	29.5	28.8	27.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.3	4.1	4.5	5.4	6.1	5.9	5.4	5.3	5.4	4.6	3.8	3.1	(35)
(36)			MCDBR	4.1	5.1	5.6	6.3	7.1	6.8	6.5	6.4	6.5	5.8	4.8	4.1	(36)
(37)			MCWBR	2.7	3.3	3.4	3.6	3.9	3.7	3.7	3.7	3.8	3.4	3.0	2.7	(37)
(38)		5% WB	MCDBR	3.8	4.7	5.0	5.9	6.6	6.5	6.2	6.1	6.1	5.4	4.5	4.0	(38)
(39)			MCWBR	2.7	3.3	3.4	3.7	4.1	4.0	3.9	3.9	3.9	3.5	3.0	2.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.445	0.432	0.453	0.451	0.451	0.449	0.446	0.453	0.451	0.470	0.458	0.472	(40)	
(41)		taud	2.349	2.387	2.329	2.343	2.371	2.390	2.400	2.372	2.374	2.304	2.331	2.259	(41)	
(42)		Ebn at Noon	851	880	867	863	849	841	846	849	857	834	831	812	(42)	
(43)		Edh at Noon	122	122	132	130	124	120	120	125	124	131	124	131	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.90	4.73	5.38	6.19	5.79	5.35	4.82	4.81	4.83	4.34	4.01	3.48	(44)	
(45)		RadStd	0.34	0.52	0.49	0.38	0.49	0.36	0.44	0.30	0.39	0.32	0.39	0.37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.35	+0.60	N/A	+0.41	+0.36	+0.56	N/A	N/A	+183	+183

Nomenclature: See separate page