

DAET, Philippines

WMO: 984400

Lat: 14.1286N

Lon: 122.9825E

Elev: 10

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.7	73.9	68.6	105.3	76.0	70.0	110.4	76.5	30.2	75.0	23.4	76.7	7.6	40	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.1	91.8	85.6	90.9	85.3	89.9	84.8	88.9	90.0	87.7	89.2	86.6	88.3	8.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
88.6	207.6	89.7	87.3	199.1	88.8	86.3	192.2	88.0	54.4	90.0	52.9	89.2	51.5	88.5	97.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.9	15.1	68.1	96.3	4.9	3.0	64.6	98.5	61.7	100.2	59.0	101.9	55.5	104.1
			66.8	89.9	4.7	3.1	63.4	92.1	60.7	93.9	58.1	95.6	54.7	97.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	78.8	79.0	80.5	82.6	83.8	83.6	82.8	83.0	82.4	81.6	81.5	80.2
	DBStd	2.45	2.01	2.04	2.04	1.85	1.64	1.86	1.80	1.98	1.77	1.75	1.72	1.69
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11557	893	813	945	978	1048	1009	1017	1022	971	978	946	937
	CDD65	6082	428	393	480	528	583	559	552	557	521	513	496	472
	CDH74	64948	3434	3314	4750	6219	7203	6669	6229	6314	5650	5466	5252	4448
	CDH80	19878	375	489	1094	2217	3011	2697	2212	2259	1889	1593	1325	717
(14) Wind	WSAvg	6.9	9.2	8.1	7.5	6.1	5.4	5.4	5.8	6.0	5.5	6.8	8.3	9.2
(15) Precipitation	PrecAvg	140.3	11.2	7.0	6.2	5.2	5.7	7.6	8.3	9.8	11.8	20.2	20.3	26.9
	PrecMax	199.3	22.4	15.9	16.3	11.6	18.6	17.8	13.7	22.4	16.4	36.7	55.5	58.3
	PrecMin	73.7	2.5	1.2	1.6	0.7	0.0	1.9	2.8	2.7	5.2	12.1	9.2	8.1
	PrecStd	33.2	5.4	4.5	4.3	3.4	5.7	4.2	2.9	5.6	2.9	6.9	11.5	15.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.3	86.2	88.1	90.8	93.3	93.6	91.8	92.3	91.7	89.9	88.2	86.5
		MCWB	81.4	82.8	82.9	85.9	86.0	86.2	86.2	85.5	85.3	83.4	83.4	82.1
	2%	DB	84.2	84.9	86.8	89.4	91.5	91.8	90.3	90.7	90.0	88.2	87.2	85.5
		MCWB	80.3	81.5	82.6	84.2	85.6	85.5	85.5	85.0	84.5	83.3	83.0	81.5
	5%	DB	83.3	84.0	86.0	88.2	90.3	90.6	89.3	89.4	88.8	87.3	86.2	84.5
		MCWB	79.6	80.4	82.2	83.7	85.0	85.2	84.9	84.4	83.9	82.9	82.6	80.9
	10%	DB	82.2	83.0	85.0	87.4	89.2	89.5	88.1	88.2	87.6	86.1	85.2	83.4
		MCWB	78.9	79.5	81.2	83.2	84.5	84.8	84.1	83.8	83.3	82.1	81.8	80.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.5	84.6	86.2	88.5	90.0	90.2	89.6	89.1	89.1	87.2	86.3	84.6
		MCDB	84.1	85.3	86.7	89.4	90.9	91.1	90.5	90.2	90.0	87.8	86.9	85.1
	2%	WB	81.9	83.3	84.9	86.9	88.0	88.5	87.8	87.4	87.0	85.4	84.7	82.7
		MCDB	83.0	84.2	85.9	88.1	89.7	89.9	89.0	88.9	88.2	86.7	85.9	84.1
	5%	WB	80.6	81.6	83.3	85.7	86.8	87.0	86.1	85.7	85.3	83.7	83.3	81.6
		MCDB	82.2	83.0	84.9	87.1	88.8	89.2	88.0	87.9	87.2	85.9	85.1	83.4
	10%	WB	79.5	80.2	81.8	84.2	85.4	85.2	84.4	84.2	83.6	82.5	82.2	80.7
		MCDB	81.3	82.0	83.9	86.3	88.0	88.3	87.3	87.5	86.6	85.4	84.5	82.8
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	7.1	7.9	9.2	11.1	11.3	10.3	10.3	10.4	8.7	7.0	5.9
		MCDBR	7.2	8.3	9.5	10.5	12.8	13.2	12.1	12.0	12.1	10.6	8.7	7.5
		MCWBR	5.6	6.6	7.2	8.2	9.4	9.4	8.8	8.4	8.6	7.5	6.5	5.4
	5% WB	MCDBR	7.0	8.1	8.9	10.0	12.0	12.2	11.5	11.2	11.2	9.8	8.4	7.1
		MCWBR	6.1	7.5	8.2	9.5	10.7	11.0	10.2	9.8	10.1	8.3	7.2	6.0
(40) Clear-Sky Solar Irradiance	taub		0.449	0.431	0.446	0.435	0.438	0.437	0.436	0.445	0.445	0.458	0.458	0.477
	taud		2.339	2.395	2.357	2.398	2.418	2.431	2.435	2.397	2.391	2.348	2.331	2.239
	Ebn at Noon		269	279	277	278	273	270	271	272	273	268	264	256
	Edh at Noon		39	38	41	39	38	37	37	39	39	40	39	43
(44) All-Sky Solar Radiation	RadAvg		1238	1525	1726	1992	1908	1772	1588	1617	1601	1413	1305	1128
	RadStd		124	176	174	125	157	117	132	87	124	103	143	127

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+0.61	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page