

LEGAZPI, Philippines

WMO: 984440

Lat: 13.1508N

Lon: 123.7283E

Elev: 51

StdP: 14.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.9	73.9	67.7	102.1	75.8	69.0	106.7	76.3	18.8	78.8	17.7	78.5	5.4	40	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.0	92.3	82.3	91.3	82.1	90.5	81.8	83.6	90.0	82.9	89.4	82.5	89.0	6.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.8	165.6	88.4	81.0	161.5	87.9	80.6	159.3	87.6	47.7	90.4	46.9	89.9	46.4	89.5	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.8	14.1	12.1	DB	69.2	95.3	3.0	2.5	67.1	97.1	65.3	98.5	63.6	99.9	61.4	101.7	
			WB	66.9	85.4	2.8	1.4	64.9	86.4	63.2	87.3	61.6	88.1	59.6	89.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	79.2	79.9	81.1	83.1	84.4	84.1	82.9	83.1	82.7	82.2	81.7	80.4
	DBStd	2.42	1.93	1.84	1.82	1.67	1.81	1.97	1.92	1.92	1.82	1.73	1.78	1.97
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11704	905	837	963	992	1065	1022	1020	1026	982	999	950	943
	CDD65	6229	440	417	498	542	600	572	555	561	532	534	500	478
	CDH74	66244	3484	3581	4914	6259	7429	6947	6250	6333	5801	5703	5146	4397
Wind	WSAvg	5.3	6.8	6.3	5.7	5.2	4.4	4.2	4.8	5.2	4.8	4.5	5.3	6.5
	PrecAvg	129.4	12.0	8.2	6.9	6.3	7.7	8.5	10.9	9.6	10.9	12.8	17.6	18.8
Precipitation	PrecMax	166.7	34.2	42.6	19.6	23.3	23.7	20.4	28.5	18.9	26.8	27.3	34.0	47.6
	PrecMin	82.3	0.9	0.4	0.9	1.1	0.7	2.0	2.6	2.6	1.4	2.4	5.0	4.9
	PrecStd	22.4	7.5	7.4	4.4	5.0	4.8	4.2	4.8	3.6	4.8	5.7	6.5	10.7
	PrecStd	22.4	7.5	7.4	4.4	5.0	4.8	4.2	4.8	3.6	4.8	5.7	6.5	10.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.3	88.0	89.2	91.5	93.4	94.0	92.5	92.4	92.0	91.3	89.8	88.5
		MCWB	79.9	79.6	80.3	81.8	82.4	82.8	82.6	82.0	81.9	82.0	81.4	80.8
	2%	DB	86.0	86.8	88.1	90.2	91.9	92.2	90.8	90.8	90.5	89.8	88.4	87.1
		MCWB	79.0	79.0	80.0	81.4	82.3	82.5	81.8	81.5	81.6	81.4	81.0	80.3
	5%	DB	84.8	85.8	87.1	89.2	90.9	90.9	89.6	89.5	89.4	88.7	87.5	85.9
		MCWB	78.2	78.5	79.6	81.1	82.1	82.2	81.5	81.2	81.3	81.1	80.7	79.8
	10%	DB	83.5	84.6	86.1	88.2	89.8	89.8	88.2	88.2	88.0	87.5	86.3	84.6
		MCWB	77.5	77.9	79.1	80.6	81.9	81.9	81.0	80.8	81.0	80.7	80.2	79.2
	0.4%	WB	81.3	81.5	82.5	83.4	84.4	84.4	83.6	83.7	83.3	83.2	82.7	82.0
		MCDB	85.9	86.3	87.2	89.3	91.0	91.1	90.4	89.9	89.4	89.3	87.7	86.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	80.0	80.2	81.2	82.4	83.3	83.5	82.6	82.5	82.4	82.4	81.8	81.0
		MCDB	84.6	85.4	86.6	88.9	90.1	90.3	89.4	89.1	89.0	88.4	87.0	85.7
	5%	WB	79.1	79.3	80.4	81.7	82.6	82.7	81.8	81.7	81.7	81.6	81.1	80.3
		MCDB	83.6	84.4	86.0	88.1	89.5	89.6	88.3	88.0	88.0	87.4	86.3	84.9
	10%	WB	78.1	78.5	79.6	81.0	82.1	82.1	81.1	81.0	81.0	80.9	80.6	79.6
		MCDB	82.3	83.3	85.0	87.2	88.7	88.7	87.1	87.0	87.0	86.3	85.6	83.7
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.1	9.6	10.5	11.0	11.0	10.1	10.1	10.4	10.4	8.9	7.8
		MCDBR	10.2	10.9	11.2	11.7	12.4	12.8	12.3	12.1	12.5	12.4	10.9	9.8
		MCWBR	5.4	5.6	5.8	5.6	5.6	5.7	5.6	5.5	5.9	6.1	5.6	5.2
	5% WB	MCDBR	9.3	10.0	10.5	11.2	11.7	12.2	11.8	11.5	11.7	11.6	10.1	9.2
		MCWBR	5.5	5.8	6.2	5.8	5.8	6.1	5.9	5.9	6.1	6.2	5.6	5.2
Clear-Sky Solar Irradiance	taub		0.455	0.437	0.443	0.436	0.440	0.445	0.444	0.475	0.477	0.462	0.454	0.469
	taud		2.307	2.359	2.346	2.374	2.392	2.390	2.395	2.291	2.275	2.318	2.334	2.263
	Ebn at Noon		268	278	278	278	272	268	269	264	265	267	266	260
	Edh at Noon		41	40	41	40	39	38	38	43	44	41	39	42
All-Sky Solar Radiation	RadAvg		1221	1527	1699	1931	1829	1682	1513	1565	1540	1415	1325	1151
	RadStd		134	176	184	125	154	108	121	84	139	86	136	115

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.61	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page