

SAN JOSE, Philippines

WMO: 985310

Lat: 12.3596N

Lon: 121.0478E

Elev: 14

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	72.0	73.7	63.2	86.7	80.2	65.0	92.4	80.7	25.9	80.6	18.8	80.5	3.4	90	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	14.1	95.4	80.0	94.0	80.2	92.8	80.3	84.2	90.8	83.6	90.1	83.0	89.4	12.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.5	169.2	89.0	81.8	165.5	88.3	81.2	162.4	87.8	48.3	91.1	47.7	90.4	47.0	89.5	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	17.8	15.3	68.7	98.7	3.1	1.9	66.5	100.1	64.6	101.3	62.9	102.4	60.6	103.8		
(5)			64.7	85.4	2.1	1.2	63.2	86.3	62.0	87.0	60.8	87.7	59.3	88.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.2	82.3	83.0	84.3	85.8	85.3	83.3	81.9	81.9	81.5	82.4	83.5	83.1	
	DBStd	2.56	2.47	2.27	2.45	2.42	2.55	2.35	2.09	1.86	1.71	1.79	1.98	2.33	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	12117	1002	924	1064	1073	1094	1000	989	990	946	1005	1005	1025	
	CDD65	6642	537	504	599	623	629	550	524	525	496	540	555	560	
	CDH74	75132	5620	5523	7167	8098	8026	6353	5474	5592	5003	5820	6288	6168	
	CDH80	28920	1983	2160	3151	4000	3774	2423	1656	1692	1374	1966	2444	2297	
Wind	WSAvg	6.3	7.3	7.3	7.7	7.2	5.9	5.4	5.5	5.6	5.5	5.2	6.4	7.3	
Precipitation	PrecAvg	93.4	0.8	0.7	0.6	1.4	7.2	13.0	19.0	18.6	16.9	9.2	4.1	3.0	
	PrecMax	134.3	5.7	4.9	3.2	7.4	18.1	38.9	47.1	40.0	36.9	32.1	9.2	14.8	
	PrecMin	54.5	0.0	0.0	0.0	0.0	0.2	2.0	1.5	5.0	4.4	1.7	0.1	0.1	
	PrecStd	17.3	1.1	1.1	0.8	1.9	5.1	7.6	8.1	7.1	7.6	5.9	2.7	3.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.4	93.8	95.5	97.2	97.5	94.8	91.9	90.6	90.3	92.4	93.5	93.0	
		MCWB	78.7	78.5	79.2	79.4	80.5	81.0	82.0	82.8	82.2	81.6	80.2	79.5	
	2%	DB	90.7	92.1	93.8	95.4	95.2	92.3	89.7	89.0	88.8	90.4	91.9	91.4	
		MCWB	78.3	78.0	78.7	79.6	81.2	82.0	82.0	82.4	82.0	81.7	80.3	79.7	
	5%	DB	89.3	90.6	92.3	94.1	93.3	90.5	88.2	87.9	87.6	89.1	90.6	90.0	
		MCWB	77.9	77.6	78.6	79.9	81.9	82.1	81.6	81.9	81.6	81.4	80.3	79.6	
	10%	DB	87.9	89.0	90.5	92.4	91.6	89.0	86.8	86.7	86.2	87.7	89.2	88.6	
		MCWB	77.6	77.6	78.8	80.3	82.0	81.7	81.0	81.4	81.0	81.1	80.1	79.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.7	82.6	83.9	84.4	84.8	84.4	83.7	84.2	83.9	83.7	83.8	84.0
			MCDB	89.7	90.2	91.9	92.0	92.0	90.4	88.8	88.8	88.3	89.3	90.3	90.4
2%		WB	81.0	81.3	82.4	83.5	84.1	83.5	82.8	83.2	82.8	82.8	82.6	82.3	
		MCDB	88.0	88.9	90.4	91.6	91.6	89.7	88.1	87.9	87.5	88.4	89.5	88.6	
5%		WB	79.9	80.2	81.1	82.5	83.3	82.6	81.9	82.4	81.9	82.1	81.7	81.1	
		MCDB	87.0	87.9	89.0	90.8	90.7	88.8	87.1	87.1	86.5	87.7	88.5	87.7	
10%		WB	78.8	79.1	80.1	81.5	82.4	81.8	81.1	81.6	81.0	81.4	80.8	80.1	
		MCDB	86.0	86.9	88.0	89.8	89.7	87.8	85.9	85.9	85.4	86.7	87.5	86.7	
Mean Daily Temperature Range	5% DB	MDBR	12.6	13.8	14.0	14.1	12.7	10.6	9.3	8.9	9.3	11.0	12.4	12.0	
		MCDBR	13.6	15.1	15.5	15.7	14.8	13.1	11.6	10.8	11.6	13.3	14.1	13.2	
		MCWBR	6.9	6.8	6.8	6.6	6.8	6.1	6.1	6.2	6.5	7.1	6.8	6.4	
	5% WB	MCDBR	13.3	13.9	14.2	14.4	13.7	12.1	10.7	10.4	10.9	12.2	13.3	12.7	
		MCWBR	8.4	8.5	8.5	8.1	7.6	6.7	6.3	6.4	6.7	7.3	7.8	7.5	
Clear-Sky Solar Irradiance	taub	0.427	0.420	0.436	0.451	0.449	0.442	0.447	0.457	0.448	0.464	0.439	0.441		
	taud	2.438	2.442	2.400	2.360	2.397	2.431	2.416	2.376	2.396	2.336	2.412	2.396		
	Ebn at Noon	278	284	280	273	270	268	268	268	273	268	272	270		
	Edh at Noon	36	37	39	41	38	36	37	39	39	41	36	37		
All-Sky Solar Radiation	RadAvg	1553	1810	1993	2118	1859	1612	1447	1472	1494	1555	1560	1428		
	RadStd	111	140	136	105	179	153	173	131	178	118	119	110		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page