

ROMBLON, Philippines

WMO: 985360

Lat: 12.5738N

Lon: 122.2607E

Elev: 541

StdP: 14.41

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.6	73.3	68.3	106.2	74.6	69.3	109.7	74.8	15.2	77.0	14.3	76.9	8.6	40	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.3	91.3	80.8	90.0	80.5	89.2	80.3	81.7	89.3	81.2	88.5	80.8	87.9	4.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	155.7	87.2	79.0	153.7	87.1	78.6	151.6	86.7	46.0	90.0	45.4	89.2	45.0	88.4	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.0	13.2	11.9	DB	71.2	94.2	1.8	3.8	69.9	96.9	68.8	99.1	67.8	101.3	66.4	104.0
			WB	68.6	82.5	2.5	0.7	66.8	83.0	65.3	83.4	64.0	83.8	62.2	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	77.9	78.8	80.5	82.9	84.1	83.2	81.7	81.6	81.6	81.2	80.7	79.0
	DBStd	2.75	2.16	2.21	2.19	1.98	2.12	2.25	2.42	2.16	2.05	1.89	1.89	1.87
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11358	866	807	947	988	1057	996	982	981	948	967	920	899
	CDD65	5883	401	387	482	538	592	546	517	516	498	502	470	434
	CDH74	58707	2684	2913	4442	6091	7186	6348	5469	5401	5158	5070	4511	3434
	CDH80	16169	277	477	1070	2132	2883	2291	1603	1487	1392	1241	930	386
(14) Wind	WSAvg	6.0	7.3	6.5	6.0	5.2	4.9	5.1	5.8	6.5	6.2	5.4	6.3	7.2
(15) Precipitation	PrecAvg	87.9	4.5	3.3	3.2	2.5	6.1	9.0	11.4	8.7	9.1	11.2	10.0	10.1
	PrecMax	145.3	12.3	12.0	14.8	12.1	27.2	16.1	22.0	15.7	22.8	25.1	28.3	23.4
	PrecMin	43.0	0.4	0.0	0.0	0.0	0.6	4.3	3.6	1.5	1.2	1.1	2.1	1.8
	PrecStd	24.2	3.0	3.6	3.1	3.0	6.1	3.0	4.7	4.0	5.2	5.7	5.2	5.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.7	87.4	89.3	91.3	93.5	93.0	90.9	90.7	90.6	89.2	88.3	86.1
		MCWB	78.2	78.4	79.6	80.0	81.0	81.6	81.1	81.0	80.8	80.4	80.1	79.2
	2%	DB	84.2	85.8	87.8	89.8	91.4	90.7	89.5	88.8	88.8	87.7	87.0	84.6
		MCWB	77.7	78.0	79.1	79.8	80.8	81.0	80.7	80.4	80.4	80.2	79.8	78.5
	5%	DB	83.0	84.5	86.4	88.8	90.0	89.5	88.1	87.5	87.3	86.4	85.8	83.4
		MCWB	77.0	77.7	78.6	79.6	80.5	80.7	80.4	80.1	80.0	79.6	79.4	77.9
	10%	DB	81.8	83.1	85.2	87.7	88.9	88.1	86.5	86.2	86.0	85.3	84.5	82.2
		MCWB	76.3	77.0	78.2	79.4	80.3	80.4	79.9	79.6	79.6	79.2	78.8	77.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.1	79.7	80.8	81.5	82.3	82.4	81.8	81.8	81.7	81.0	80.9	79.8
		MCDB	84.4	85.6	87.7	88.9	91.0	90.4	88.7	89.0	88.6	87.2	87.1	85.0
	2%	WB	78.2	78.8	79.8	80.8	81.6	81.6	81.0	80.9	80.9	80.4	80.1	78.8
		MCDB	83.3	84.9	86.6	88.3	89.8	89.2	87.8	87.6	87.5	86.5	85.8	83.8
	5%	WB	77.4	78.0	79.1	80.1	81.0	81.0	80.6	80.3	80.2	79.9	79.5	78.1
		MCDB	82.2	83.7	85.6	87.5	88.7	88.3	87.3	86.6	86.5	85.7	85.0	82.7
	10%	WB	76.6	77.1	78.3	79.6	80.5	80.5	80.0	79.7	79.6	79.2	78.9	77.4
		MCDB	81.2	82.5	84.5	86.7	88.0	87.5	86.1	85.6	85.5	84.7	84.1	81.7
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	7.3	8.1	9.1	9.3	8.7	8.0	7.7	8.0	7.5	6.8	5.6
		MCDBR	7.5	8.8	9.8	10.3	10.7	10.6	10.1	9.8	9.9	9.1	8.5	7.3
	5% WB	MCWBR	4.2	4.8	5.0	4.7	4.6	4.7	5.0	5.0	5.0	4.8	4.7	4.2
		MCWBR	7.1	8.5	9.3	9.7	10.1	10.0	9.5	9.1	9.4	8.5	8.0	6.8
(40) Clear-Sky Solar Irradiance	taub	0.431	0.418	0.427	0.428	0.427	0.427	0.427	0.428	0.437	0.432	0.446	0.434	0.444
		2.425	2.449	2.435	2.432	2.461	2.477	2.477	2.435	2.446	2.396	2.432	2.382	
	Ebn at Noon	276	285	283	280	275	272	273	274	278	272	273	269	
		36	36	38	38	36	35	35	37	37	38	36	37	
(44) All-Sky Solar Radiation	RadAvg	1389	1683	1888	2092	1898	1702	1546	1566	1596	1535	1478	1307	
	RadStd	121	152	159	100	174	132	136	109	161	101	118	107	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page