

ROMBLON, Philippines

WMO: 985360

Lat: 12.5738N

Lon: 122.2607E

Elev: 165

StdP: 99.36

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.5	23.0	20.2	15.2	23.7	20.7	15.7	23.8	6.8	25.0	6.4	24.9	3.8	40	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.1	32.9	27.1	32.2	27.0	31.8	26.8	27.6	31.8	27.3	31.4	27.1	31.1	2.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	22.2	30.7	26.1	22.0	30.6	25.9	21.7	30.4	89.0	32.2	87.7	31.8	86.7	31.3	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.7	5.9	5.3														
			DB	21.8	34.6	1.0	2.1	21.0	36.1	20.5	37.3	19.9	38.5	19.1	40.0	
			WB	20.3	28.0	1.4	0.4	19.3	28.3	18.5	28.6	17.8	28.8	16.8	29.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	25.5	26.0	27.0	28.3	28.9	28.4	27.6	27.6	27.6	27.3	27.0	26.1	(6)
(7)		DBStd	1.53	1.20	1.23	1.22	1.10	1.18	1.25	1.35	1.20	1.14	1.05	1.05	1.04	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6310	481	448	526	549	587	553	546	545	527	537	511	499	(10)
(11)		CDD18.3	3268	223	215	268	299	329	303	287	287	277	279	261	241	(11)
(12)		CDH23.3	32615	1491	1618	2468	3384	3992	3527	3038	3001	2866	2817	2506	1908	(12)
(13)	CDH26.7	8983	154	265	594	1184	1602	1273	891	826	773	689	517	214	(13)	
(14)	Wind	WSAvg	2.7	3.3	2.9	2.7	2.3	2.2	2.3	2.6	2.9	2.8	2.4	2.8	3.2	(14)
(15)	Precipitation	PrecAvg	2233	115	84	81	63	155	229	290	222	232	285	253	257	(15)
(16)		PrecMax	3690	313	304	377	307	690	408	558	398	578	638	720	594	(16)
(17)		PrecMin	1091	10	0	1	0	14	110	91	37	30	27	54	45	(17)
(18)		PrecStd	615	75	92	79	77	154	76	119	102	131	145	133	145	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.8	30.8	31.8	32.9	34.1	33.9	32.7	32.6	32.5	31.8	31.3	30.0	(19)
(20)			MCWB	25.7	25.8	26.4	26.7	27.2	27.6	27.3	27.2	27.1	26.9	26.7	26.2	(20)
(21)		2%	DB	29.0	29.9	31.0	32.1	33.0	32.6	31.9	31.5	31.6	31.0	30.6	29.2	(21)
(22)			MCWB	25.4	25.6	26.2	26.6	27.1	27.2	27.0	26.9	26.9	26.8	26.6	25.9	(22)
(23)		5%	DB	28.3	29.1	30.2	31.5	32.2	31.9	31.2	30.8	30.7	30.2	29.9	28.5	(23)
(24)			MCWB	25.0	25.4	25.9	26.5	27.0	27.0	26.9	26.7	26.7	26.5	26.3	25.5	(24)
(25)		10%	DB	27.6	28.4	29.6	30.9	31.6	31.2	30.3	30.1	30.0	29.6	29.2	27.9	(25)
(26)			MCWB	24.6	25.0	25.6	26.4	26.8	26.9	26.6	26.5	26.4	26.2	26.0	25.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.5	27.1	27.5	28.0	28.0	27.7	27.7	27.6	27.2	27.2	26.6	(27)
(28)			MCDWB	29.1	29.8	30.9	31.6	32.8	32.4	31.5	31.7	31.4	30.7	30.6	29.5	(28)
(29)		2%	WB	25.7	26.0	26.6	27.1	27.6	27.6	27.2	27.2	27.2	26.9	26.7	26.0	(29)
(30)			MCDWB	28.5	29.4	30.3	31.3	32.1	31.8	31.0	30.9	30.8	30.3	29.9	28.8	(30)
(31)		5%	WB	25.2	25.5	26.1	26.7	27.2	27.2	27.0	26.8	26.8	26.6	26.4	25.6	(31)
(32)			MCDWB	27.9	28.7	29.8	30.8	31.5	31.3	30.7	30.3	30.3	29.8	29.5	28.2	(32)
(33)		10%	WB	24.8	25.1	25.7	26.5	27.0	26.9	26.6	26.5	26.5	26.2	26.0	25.2	(33)
(34)			MCDWB	27.3	28.1	29.1	30.4	31.1	30.8	30.1	29.8	29.7	29.3	28.9	27.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.2	4.1	4.5	5.0	5.1	4.8	4.5	4.3	4.5	4.1	3.8	3.1	(35)
(36)			MCDBR	4.2	4.9	5.5	5.7	6.0	5.9	5.6	5.4	5.5	5.0	4.7	4.1	(36)
(37)			MCWBR	2.3	2.7	2.8	2.6	2.6	2.6	2.8	2.8	2.8	2.7	2.6	2.3	(37)
(38)		5% WB	MCDWB	3.9	4.7	5.1	5.4	5.6	5.5	5.3	5.0	5.2	4.7	4.5	3.8	(38)
(39)			MCWBR	2.4	2.8	2.9	2.7	2.7	2.8	2.9	2.8	2.9	2.7	2.6	2.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.431	0.418	0.427	0.428	0.427	0.427	0.428	0.437	0.432	0.446	0.434	0.444	(40)
(41)		taud		2.425	2.449	2.435	2.432	2.461	2.477	2.477	2.435	2.446	2.396	2.432	2.382	(41)
(42)		Ebn at Noon		871	897	893	883	868	859	861	863	875	859	861	847	(42)
(43)		Edh at Noon		115	115	119	119	113	110	111	117	116	120	113	117	(43)
(44)	All-Sky Solar Radiation	RadAvg		4.38	5.31	5.95	6.60	5.98	5.36	4.87	4.94	5.03	4.84	4.66	4.12	(44)
(45)		RadStd		0.38	0.48	0.50	0.32	0.55	0.42	0.43	0.34	0.51	0.32	0.37	0.34	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	+0.27	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page