

MASBATE, Philippines

WMO: 985430

Lat: 12.3663N

Lon: 123.6292E

Elev: 26

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.8	74.9	69.5	108.5	77.7	70.6	113.0	78.2	19.9	80.2	17.9	81.2	4.0	0	0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.7	92.9	82.4	91.8	81.9	91.0	81.7	83.7	90.4	83.2	89.8	82.7	89.2	5.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.8	165.8	88.8	81.1	161.5	88.1	80.8	160.1	87.9	47.8	90.9	47.2	90.2	46.6	89.6	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.8	14.5	12.3	DB	71.6	95.6	2.0	2.1	70.2	97.1	69.1	98.3	68.0	99.5	66.6	101.1	
			WB	69.2	85.2	2.5	1.2	67.4	86.1	65.9	86.8	64.5	87.5	62.7	88.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.1	80.5	81.2	82.4	84.3	85.1	84.5	83.5	83.7	83.5	83.0	81.7	(6)	
(7)		DBStd	2.22	1.90	1.81	1.79	1.62	1.71	1.97	1.87	1.77	1.71	1.66	1.70	1.92	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12075	947	874	1005	1029	1089	1035	1037	1046	1005	1037	990	981	(10)
(11)		CDD65	6600	482	454	540	579	624	585	572	581	555	572	540	516	(11)
(12)		CDH74	72887	4235	4272	5652	6886	7804	7092	6538	6740	6314	6385	5893	5076	(12)
(13)		CDH80	26020	971	1179	1851	2817	3464	2961	2380	2551	2290	2263	1949	1344	(13)
(14)	Wind	WSAvg	4.9	5.3	5.4	5.0	4.8	4.7	4.6	5.0	5.2	4.6	4.1	4.5	5.3	(14)
(15)	Precipitation	PrecAvg	70.6	6.5	2.6	2.2	1.4	4.9	5.7	6.7	7.7	8.1	8.4	8.8	7.6	(15)
(16)		PrecMax	93.9	21.4	5.9	5.3	3.9	13.5	11.3	13.5	17.1	13.8	14.4	14.4	17.1	(16)
(17)		PrecMin	45.3	0.6	0.1	0.0	0.2	0.1	0.4	0.2	2.9	2.2	2.9	2.9	1.0	(17)
(18)		PrecStd	13.8	5.9	1.6	1.5	1.2	4.4	2.6	3.5	4.2	3.1	4.1	3.7	4.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	90.3	91.6	93.4	93.8	93.7	92.4	92.6	92.1	92.3	91.5	90.0	(19)
(20)			MCWB	81.0	80.8	81.5	82.4	82.6	82.7	82.4	81.7	81.9	82.5	82.4	81.8	(20)
(21)		2%	DB	87.7	88.6	89.8	91.8	92.7	92.2	90.6	91.1	90.9	90.4	90.0	88.6	(21)
(22)			MCWB	80.1	80.2	80.8	81.7	82.3	82.4	81.4	81.3	81.4	81.6	81.9	81.1	(22)
(23)		5%	DB	86.3	87.5	88.6	90.6	91.5	91.0	89.5	89.9	89.6	89.4	88.9	87.6	(23)
(24)			MCWB	79.4	79.7	80.3	81.2	81.9	82.1	81.0	81.0	81.0	81.2	81.4	80.7	(24)
(25)		10%	DB	85.0	86.1	87.6	89.6	90.3	89.6	88.1	88.7	88.2	88.1	87.7	86.1	(25)
(26)			MCWB	78.9	79.0	79.8	80.7	81.6	81.6	80.7	80.7	80.7	80.8	81.0	80.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.3	82.6	83.1	83.7	84.3	84.4	83.7	83.4	83.5	83.6	83.7	83.1	(27)
(28)			MCD B	87.7	88.3	89.5	91.1	91.6	91.6	90.2	90.0	90.0	90.1	89.4	88.2	(28)
(29)		2%	WB	81.0	81.2	81.9	82.8	83.4	83.5	82.6	82.5	82.6	82.6	82.7	82.0	(29)
(30)			MCD B	86.2	87.1	88.3	90.1	90.6	90.4	88.7	89.0	88.8	88.8	88.5	87.1	(30)
(31)		5%	WB	80.1	80.4	81.0	82.0	82.7	82.7	81.8	81.7	81.8	81.9	81.9	81.1	(31)
(32)			MCD B	85.1	86.2	87.3	89.2	89.8	89.4	87.7	88.1	87.9	87.9	87.6	86.1	(32)
(33)		10%	WB	79.2	79.4	80.2	81.3	82.1	81.9	81.0	81.0	81.0	81.1	81.2	80.3	(33)
(34)			MCD B	83.8	84.9	86.3	88.2	88.9	88.3	86.8	87.1	86.9	86.9	86.6	85.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	11.0	11.4	12.2	11.7	11.0	10.4	10.6	10.7	10.9	10.5	9.6	(35)
(36)			MCDBR	11.9	12.9	12.9	13.5	13.0	12.6	12.0	12.2	12.4	12.4	12.1	11.6	(36)
(37)			MCWBR	6.4	6.6	6.5	6.2	5.8	5.8	5.7	5.5	5.9	6.0	6.3	6.1	(37)
(38)		5% WB	MCD BR	11.1	12.1	12.3	12.9	12.3	12.0	11.6	11.7	11.8	12.0	11.6	10.9	(38)
(39)			MCWBR	6.4	6.8	6.7	6.5	6.1	6.1	6.1	5.9	6.2	6.3	6.4	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.447	0.432	0.434	0.433	0.431	0.433	0.436	0.455	0.450	0.455	0.442	0.454	(40)	
(41)		taud	2.368	2.406	2.414	2.418	2.448	2.458	2.450	2.380	2.388	2.368	2.403	2.347	(41)	
(42)		Ebn at Noon	271	280	281	279	274	271	271	269	272	270	271	266	(42)	
(43)		Edh at Noon	38	38	39	38	36	36	36	39	39	39	37	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1300	1589	1810	2026	1881	1703	1558	1606	1584	1498	1418	1244	(44)	
(45)		RadStd	145	176	191	121	161	106	114	90	144	95	122	106	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (8 neighbors)	+0.47	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page