

TACLOBAN, Philippines

WMO: 985500

Lat: 11.2300N

Lon: 125.0254E

Elev: 10

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.4	74.2	69.2	107.4	77.0	70.4	112.0	77.3	14.9	81.8	12.7	81.6	3.1	320	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.2	92.7	82.7	91.7	82.4	90.9	82.1	84.3	91.0	83.5	90.2	82.8	89.5	5.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.3	168.6	90.0	81.6	164.3	89.2	80.9	160.6	88.4	48.4	91.2	47.6	90.5	46.8	89.9	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.3	10.7	9.0	DB	68.8	95.5	3.9	2.0	66.0	96.9	63.7	98.1	61.5	99.2	58.6	100.6
			WB	67.7	84.4	3.4	1.3	65.3	85.3	63.3	86.1	61.4	86.8	59.0	87.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	79.9	80.8	81.8	83.1	83.9	83.5	83.1	83.5	83.1	82.9	82.1	80.7	(6)
(7)		DBStd	2.29	2.15	2.18	2.11	1.72	1.68	1.87	1.87	1.78	1.77	1.80	1.96	2.12	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11816	927	863	986	993	1051	1004	1025	1040	992	1020	964	951	(10)
(11)		CDD65	6341	462	443	521	543	586	554	560	575	542	555	514	486	(11)
(12)		CDH74	66855	3801	3976	5236	6163	7011	6440	6236	6550	5979	5942	5165	4356	(12)
(13)		CDH80	22528	855	1110	1691	2278	2801	2466	2240	2491	2109	1988	1489	1010	(13)
(14)	Wind	WSAvg	3.1	3.5	3.6	3.3	3.2	2.9	2.9	2.8	3.0	3.0	2.9	3.0	3.4	(14)
(15)	Precipitation	PrecAvg	91.5	11.9	9.0	7.1	4.8	5.6	6.9	6.9	5.4	6.3	8.1	11.0	14.2	(15)
(16)		PrecMax	152.5	33.9	35.2	50.2	15.4	13.1	16.2	18.7	11.9	14.8	18.3	23.4	32.5	(16)
(17)		PrecMin	58.1	1.0	0.6	0.2	0.4	0.2	1.9	1.5	0.5	1.5	0.3	3.7	4.0	(17)
(18)		PrecStd	17.5	7.5	6.8	7.0	3.5	3.1	3.1	3.1	2.6	3.2	4.0	4.7	7.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	91.4	92.1	92.8	93.5	93.4	93.2	93.4	93.0	92.7	92.0	90.0	(19)
(20)			MCWB	81.1	82.2	82.2	82.7	83.4	83.3	82.5	81.8	82.5	83.2	83.1	81.4	(20)
(21)		2%	DB	88.0	89.5	90.5	91.4	91.8	91.6	91.4	91.6	91.0	90.9	90.2	88.3	(21)
(22)			MCWB	79.8	80.7	81.4	82.2	83.0	82.8	82.3	81.7	81.5	82.1	81.8	80.5	(22)
(23)		5%	DB	86.4	88.0	89.1	90.1	90.6	90.4	90.0	90.3	89.8	89.6	88.6	86.8	(23)
(24)			MCWB	79.1	79.8	80.5	81.6	82.4	82.3	81.8	81.3	81.2	81.5	81.1	79.8	(24)
(25)		10%	DB	84.7	86.3	87.7	88.9	89.4	89.1	88.6	89.0	88.4	88.1	87.0	85.3	(25)
(26)			MCWB	78.4	79.0	79.6	80.9	81.7	81.8	81.1	80.8	80.7	80.8	80.4	79.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.7	83.5	84.1	84.5	84.8	84.8	84.5	83.6	83.7	84.5	84.1	82.7	(27)
(28)			MCD B	88.5	90.1	90.7	91.3	91.5	91.8	91.1	90.9	90.8	91.3	90.6	88.5	(28)
(29)		2%	WB	80.9	81.8	82.4	83.0	83.7	83.6	83.1	82.7	82.6	82.9	82.7	81.4	(29)
(30)			MCD B	86.4	88.2	89.1	89.9	90.4	90.2	89.7	89.9	89.6	89.5	88.9	86.9	(30)
(31)		5%	WB	79.7	80.5	81.2	82.1	82.9	82.8	82.2	81.9	81.7	82.0	81.6	80.5	(31)
(32)			MCD B	85.0	86.7	87.7	89.0	89.6	89.3	88.8	88.8	88.4	88.2	87.4	85.4	(32)
(33)		10%	WB	78.8	79.4	80.1	81.3	82.1	81.9	81.4	81.1	80.9	81.1	80.7	79.6	(33)
(34)			MCD B	83.7	85.1	86.3	87.8	88.6	88.0	87.5	87.6	87.2	86.9	86.0	84.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	10.4	11.2	11.3	11.2	10.9	11.1	11.4	10.8	10.9	9.8	8.8	(35)
(36)			MCD BR	12.2	13.5	13.9	13.5	13.1	13.1	13.3	13.3	12.9	13.2	12.7	11.6	(36)
(37)			MCWBR	6.0	6.8	6.7	6.6	6.5	6.4	6.4	6.0	5.9	6.2	6.2	5.6	(37)
(38)		5% WB	MCD BR	11.2	12.2	12.9	12.7	12.6	12.5	12.7	12.7	12.4	12.5	11.9	10.4	(38)
(39)			MCWBR	6.2	6.8	7.1	6.7	6.9	6.7	6.7	6.4	6.4	6.6	6.4	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.462	0.441	0.434	0.428	0.425	0.423	0.426	0.448	0.439	0.449	0.441	0.457	(40)	
(41)		taud	2.294	2.361	2.393	2.412	2.441	2.462	2.451	2.373	2.393	2.369	2.391	2.319	(41)	
(42)		Ebn at Noon	268	279	281	280	276	273	273	271	276	273	272	266	(42)	
(43)		Edh at Noon	42	40	40	38	37	36	36	40	39	39	37	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1211	1496	1730	1892	1830	1646	1554	1616	1576	1510	1365	1217	(44)	
(45)		RadStd	174	185	185	127	137	99	113	98	140	105	121	109	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page