

TACLOBAN, Philippines

WMO: 985500

Lat: 11.2300N

Lon: 125.0254E

Elev: 3

StdP: 101.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 23.0	(c) 23.5	(d) 20.7	(e) 15.3	(f) 25.0	(g) 21.3	(h) 16.0	(i) 25.1	(j) 6.6	(k) 27.7	(l) 5.7	(m) 27.6	(n) 1.4	(o) 320	(p) 0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 6.2	(c) 33.7	(d) 28.2	(e) 33.2	(f) 28.0	(g) 32.7	(h) 27.8	(i) 29.0	(j) 32.8	(k) 28.6	(l) 32.3	(m) 28.2	(n) 32.0	(o) 2.4	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.0	24.1	32.2	27.5	23.5	31.8	27.2	22.9	31.3	94.7	32.9	92.7	32.5	91.1	32.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.9	4.8	4.0	20.5	35.3	2.2	1.1	18.9	36.1	17.6	36.7	16.4	37.3	14.8	38.1		
			19.9	29.1	1.9	0.7	18.5	29.6	17.4	30.0	16.3	30.4	15.0	30.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	26.6	27.1	27.7	28.4	28.8	28.6	28.4	28.6	28.4	28.3	27.8	27.0
	DBStd	1.27	1.19	1.21	1.17	0.96	0.93	1.04	1.04	0.99	0.98	1.00	1.09	1.18
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6564	515	479	548	552	584	558	569	578	551	567	536	528
	CDD18.3	3523	257	246	289	302	326	308	311	319	301	308	286	270
	CDH23.3	37142	2112	2209	2909	3424	3895	3578	3464	3639	3322	3301	2869	2420
	CDH26.7	12516	475	617	939	1266	1556	1370	1244	1384	1172	1104	827	561
Wind	WSAvg	1.4	1.5	1.6	1.5	1.4	1.3	1.3	1.2	1.3	1.3	1.3	1.3	1.5
Precipitation	PrecAvg	2323	301	228	180	121	142	176	175	138	159	206	279	361
	PrecMax	3874	862	894	1274	390	334	412	475	303	375	466	595	825
	PrecMin	1477	26	14	4	10	5	49	38	12	37	8	94	102
	PrecStd	445	190	173	179	88	78	79	78	67	81	102	119	194
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	33.0	33.4	33.8	34.1	34.1	34.0	34.1	33.9	33.7	33.3	32.2
		MCWB	27.3	27.9	27.9	28.2	28.5	28.5	28.1	27.7	28.0	28.4	28.4	27.4
	2%	DB	31.1	31.9	32.5	33.0	33.2	33.1	33.0	33.1	32.8	32.7	32.3	31.3
		MCWB	26.6	27.1	27.4	27.9	28.3	28.2	28.0	27.6	27.5	27.8	27.7	26.9
	5%	DB	30.2	31.1	31.7	32.3	32.6	32.4	32.2	32.4	32.1	32.0	31.5	30.4
		MCWB	26.2	26.5	26.9	27.6	28.0	28.0	27.7	27.4	27.3	27.5	27.3	26.6
	10%	DB	29.3	30.2	30.9	31.6	31.9	31.7	31.4	31.7	31.3	31.2	30.6	29.6
		MCWB	25.8	26.1	26.5	27.2	27.6	27.7	27.3	27.1	27.0	27.1	26.9	26.2
	0.4%	WB	28.2	28.6	29.0	29.1	29.4	29.4	29.2	28.7	28.7	29.2	28.9	28.2
		MCDB	31.4	32.3	32.6	32.9	33.1	33.2	32.8	32.7	32.7	32.9	32.5	31.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.2	27.7	28.0	28.3	28.7	28.7	28.4	28.2	28.1	28.3	28.1	27.5
		MCDB	30.2	31.2	31.7	32.2	32.5	32.4	32.1	32.1	32.0	31.9	31.6	30.5
	5%	WB	26.5	26.9	27.3	27.8	28.3	28.2	27.9	27.7	27.6	27.8	27.6	26.9
		MCDB	29.4	30.4	31.0	31.7	32.0	31.8	31.6	31.5	31.3	31.2	30.8	29.7
	10%	WB	26.0	26.3	26.7	27.4	27.8	27.7	27.4	27.3	27.2	27.3	27.0	26.5
		MCDB	28.7	29.5	30.2	31.0	31.4	31.1	30.8	30.9	30.7	30.5	30.0	28.9
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.8	6.2	6.3	6.2	6.1	6.2	6.3	6.0	6.0	5.4	4.9
		MCDBR	6.8	7.5	7.7	7.5	7.3	7.3	7.4	7.4	7.2	7.3	7.1	6.5
		MCWBR	3.3	3.8	3.7	3.7	3.6	3.6	3.5	3.3	3.3	3.5	3.4	3.1
	5% WB	MCDBR	6.2	6.8	7.2	7.1	7.0	6.9	7.0	7.1	6.9	7.0	6.6	5.8
		MCWBR	3.4	3.8	3.9	3.7	3.8	3.7	3.7	3.6	3.5	3.7	3.6	3.1
Clear-Sky Solar Irradiance	taub		0.462	0.441	0.434	0.428	0.425	0.423	0.426	0.448	0.439	0.449	0.441	0.457
	taud		2.294	2.361	2.393	2.412	2.441	2.462	2.451	2.373	2.393	2.369	2.391	2.319
	Ebn at Noon		844	878	887	883	869	861	861	854	870	860	858	838
	Edh at Noon		131	127	125	121	116	112	113	125	123	124	118	126
All-Sky Solar Radiation	RadAvg		3.82	4.72	5.45	5.96	5.77	5.19	4.90	5.09	4.97	4.76	4.30	3.84
	RadStd		0.55	0.58	0.58	0.40	0.43	0.31	0.36	0.31	0.44	0.33	0.38	0.34

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page