

PUERTO PRINCESA, Philippines

WMO: **986180**Lat: **9.7402N**Lon: **118.7590E**Elev: **71**StdP: **14.66**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.2	74.2	67.9	102.9	77.0	69.3	108.1	77.9	24.5	83.7	23.0	83.4	4.0	270	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	12.0	92.0	80.4	91.3	80.3	90.4	80.2	82.3	89.2	81.8	88.7	81.4	88.4	9.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.4	87.4	79.8	155.0	86.9	79.2	151.9	86.5	46.2	89.4	45.6	89.1	45.2	88.8	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.8	14.4	69.4	94.6	3.6	1.9	66.7	96.0	64.6	97.1	62.6	98.1	60.0	99.5		
(5)			66.5	83.9	3.0	1.0	64.4	84.6	62.7	85.3	61.0	85.8	58.9	86.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	81.4	81.4	82.6	84.0	84.1	82.9	82.2	82.3	82.1	82.3	82.3	82.0
	DBStd	1.83	1.51	1.47	1.57	1.56	1.92	1.78	1.55	1.66	1.58	1.63	1.61	1.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11860	975	880	1012	1021	1057	987	999	1001	964	1001	970	993
	CDD65	6385	510	460	547	571	592	537	534	536	514	536	520	528
	CDH74	69873	5190	4744	6200	7062	7236	6000	5648	5664	5324	5625	5566	5614
CDH80	24669	1545	1516	2314	3019	3067	2176	1861	1897	1732	1888	1858	1796	
Wind	WSAvg	6.3	8.8	8.4	7.4	6.2	5.3	4.8	4.8	5.1	5.0	5.2	6.4	8.1
Precipitation	PrecAvg	60.7	1.3	0.6	1.4	1.7	5.6	6.4	7.1	7.0	7.4	8.3	9.2	4.8
	PrecMax	82.2	3.3	3.9	4.0	5.4	12.5	15.5	10.9	11.8	11.7	19.1	16.6	15.0
	PrecMin	41.2	0.0	0.0	0.0	0.0	1.3	1.9	2.8	2.8	2.2	2.6	0.7	0.1
	PrecStd	11.0	1.0	1.1	1.3	1.5	3.1	3.6	2.1	2.1	3.1	4.8	4.5	3.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.3	89.8	91.6	93.1	93.3	92.3	91.1	91.3	91.4	91.3	90.6	90.0
		MCWB	78.6	78.7	78.6	80.3	81.2	80.7	80.3	79.5	79.7	79.7	80.1	79.8
	2%	DB	88.0	88.6	90.0	91.7	92.0	90.8	89.8	89.8	89.9	89.8	89.5	89.0
		MCWB	78.6	78.7	79.1	80.3	81.0	80.6	80.2	80.2	80.0	79.9	80.3	79.7
	5%	DB	87.2	87.7	89.3	91.0	91.2	89.7	88.8	88.9	88.9	89.0	88.6	88.1
		MCWB	78.4	78.5	79.1	80.2	80.8	80.4	80.1	80.2	79.9	79.8	80.2	79.6
	10%	DB	86.3	86.8	88.2	89.9	90.0	88.4	87.6	87.8	87.7	87.9	87.6	87.2
		MCWB	78.1	78.1	78.9	80.1	80.6	80.1	79.9	80.1	79.7	79.7	80.0	79.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	80.9	81.6	82.6	82.8	82.5	82.5	82.7	81.9	81.9	81.9	81.6
		MCDB	86.7	87.4	88.4	90.1	90.6	89.5	88.1	88.1	88.1	88.4	88.1	88.0
	2%	WB	80.0	80.0	80.7	81.7	82.1	81.7	81.4	81.6	81.2	81.1	81.4	80.8
		MCDB	86.2	86.8	88.1	89.6	89.9	88.8	87.7	87.7	87.8	88.0	87.7	87.4
	5%	WB	79.2	79.3	80.0	81.0	81.5	81.0	80.7	80.9	80.5	80.5	80.7	80.1
		MCDB	85.6	86.1	87.4	89.1	89.3	88.1	87.3	87.4	87.4	87.5	87.4	86.5
	10%	WB	78.6	78.6	79.3	80.4	80.9	80.4	80.0	80.1	79.8	79.8	80.0	79.6
		MCDB	84.9	85.4	86.6	88.5	88.5	87.2	86.3	86.5	86.3	86.3	86.3	85.6
Mean Daily Temperature Range	5% DB	MDBR	10.5	11.4	11.7	12.0	11.5	11.0	10.8	11.0	11.0	11.2	10.7	10.2
		MCDBR	11.4	12.4	12.8	13.1	12.6	12.4	12.4	12.5	12.7	12.8	12.0	11.5
		MCWBR	5.5	6.1	5.9	5.7	5.2	5.6	5.8	6.0	5.9	5.7	5.7	5.4
	5% WB	MCDBR	10.5	11.3	11.4	12.1	11.8	11.7	11.6	11.8	11.8	12.0	11.3	10.6
		MCWBR	5.5	6.1	5.9	5.9	5.6	5.8	6.0	6.3	6.1	5.9	5.8	5.4
Clear-Sky Solar Irradiance	taub	0.430	0.419	0.427	0.435	0.420	0.416	0.420	0.438	0.427	0.437	0.430	0.433	
	taud	2.454	2.463	2.450	2.421	2.492	2.520	2.509	2.432	2.458	2.433	2.455	2.446	
	Ebn at Noon	279	286	284	278	277	275	275	273	280	277	277	276	
	Edh at Noon	36	36	37	38	35	33	34	37	36	37	36	36	
All-Sky Solar Radiation	RadAvg	1566	1797	1940	1957	1739	1513	1448	1512	1496	1500	1466	1417	
	RadStd	145	149	169	141	174	105	126	127	158	111	132	174	