

PUERTO PRINCESA, Philippines

WMO: **986180**Lat: **9.7402N**Lon: **118.7590E**Elev: **22**StdP: **101.07**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	23.5	20.0	14.7	25.0	20.7	15.4	25.5	11.0	28.7	10.3	28.6	1.8	270	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.6	33.3	26.9	32.9	26.8	32.5	26.8	28.0	31.8	27.7	31.5	27.4	31.3	4.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.6	30.8	26.6	22.1	30.5	26.2	21.7	30.3	89.6	31.9	88.2	31.7	87.2	31.6	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.5	6.4	20.8	34.8	2.0	1.0	19.3	35.5	18.1	36.1	17.0	36.7	15.5	37.5		
(5)			19.2	28.8	1.6	0.6	18.0	29.2	17.0	29.6	16.1	29.9	14.9	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	27.5	27.5	28.1	28.9	28.9	28.3	27.9	27.9	27.9	27.9	28.0	27.8	
	DBStd	1.02	0.84	0.81	0.87	0.86	1.07	0.99	0.86	0.92	0.88	0.90	0.90	1.00	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6589	542	489	562	567	587	548	555	556	536	556	539	552	
	CDD18.3	3547	283	256	304	317	329	298	297	298	286	298	289	293	
	CDH23.3	38818	2883	2636	3444	3923	4020	3333	3138	3147	2958	3125	3092	3119	
	CDH26.7	13705	858	842	1286	1677	1704	1209	1034	1054	962	1049	1032	998	
Wind	WSAvg	2.8	3.9	3.7	3.3	2.8	2.3	2.2	2.2	2.3	2.2	2.3	2.9	3.6	
Precipitation	PrecAvg	1541	32	14	35	43	142	162	180	179	188	211	233	121	
	PrecMax	2087	85	100	102	136	318	394	276	300	298	486	422	381	
	PrecMin	1047	0	0	0	0	34	47	72	72	56	67	19	3	
	PrecStd	279	26	27	34	39	79	92	54	54	78	121	114	100	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	32.1	33.1	33.9	34.1	33.5	32.8	32.9	33.0	32.9	32.6	32.2	
		MCWB	25.9	26.0	25.9	26.8	27.3	27.1	26.8	26.4	26.5	26.5	26.7	26.6	
	2%	DB	31.1	31.4	32.2	33.2	33.4	32.6	32.1	32.1	32.1	32.1	32.0	31.7	
		MCWB	25.9	25.9	26.2	26.8	27.2	27.0	26.8	26.8	26.6	26.6	26.8	26.5	
	5%	DB	30.7	31.0	31.8	32.8	32.9	32.0	31.5	31.6	31.6	31.7	31.4	31.2	
		MCWB	25.8	25.8	26.2	26.8	27.1	26.9	26.7	26.8	26.6	26.6	26.8	26.4	
	10%	DB	30.2	30.4	31.2	32.2	32.2	31.3	30.9	31.0	30.9	31.0	30.9	30.7	
		MCWB	25.6	25.6	26.1	26.7	27.0	26.7	26.6	26.7	26.5	26.5	26.7	26.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.2	27.6	28.1	28.2	28.1	28.0	28.2	27.7	27.7	27.7	27.6
			MCDB	30.4	30.8	31.4	32.3	32.5	32.0	31.2	31.2	31.2	31.4	31.1	31.1
2%		WB	26.7	26.7	27.1	27.6	27.8	27.6	27.5	27.6	27.3	27.3	27.4	27.1	
		MCDB	30.1	30.5	31.2	32.0	32.1	31.5	30.9	31.0	31.0	31.1	31.0	30.8	
5%		WB	26.2	26.3	26.7	27.2	27.5	27.2	27.1	27.2	27.0	26.9	27.1	26.7	
		MCDB	29.8	30.1	30.8	31.7	31.8	31.1	30.7	30.8	30.8	30.9	30.8	30.3	
10%		WB	25.9	25.9	26.3	26.9	27.2	26.9	26.7	26.7	26.6	26.6	26.7	26.4	
		MCDB	29.4	29.7	30.4	31.4	31.4	30.7	30.1	30.3	30.1	30.2	30.2	29.8	
Mean Daily Temperature Range	5% DB	MDBR	5.8	6.3	6.5	6.6	6.4	6.1	6.0	6.1	6.1	6.2	5.9	5.7	
		MCDBR	6.4	6.9	7.1	7.3	7.0	6.9	6.9	6.9	7.0	7.1	6.7	6.4	
		MCWBR	3.0	3.4	3.3	3.2	2.9	3.1	3.2	3.4	3.3	3.2	3.2	3.0	
	5% WB	MCDBR	5.8	6.3	6.3	6.7	6.6	6.5	6.4	6.5	6.5	6.7	6.3	5.9	
		MCWBR	3.1	3.4	3.3	3.3	3.1	3.2	3.4	3.5	3.4	3.3	3.2	3.0	
Clear-Sky Solar Irradiance	taub	0.430	0.419	0.427	0.435	0.420	0.416	0.420	0.438	0.427	0.437	0.430	0.433		
	taud	2.454	2.463	2.450	2.421	2.492	2.520	2.509	2.432	2.458	2.433	2.455	2.446		
	Ebn at Noon	880	902	895	877	873	866	866	862	882	873	873	869		
	Edh at Noon	113	115	118	120	110	105	107	117	115	117	112	112		
All-Sky Solar Radiation	RadAvg	4.94	5.67	6.12	6.17	5.48	4.77	4.57	4.77	4.72	4.73	4.62	4.47		
	RadStd	0.46	0.47	0.53	0.44	0.44	0.55	0.33	0.40	0.40	0.50	0.35	0.42	0.55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.30	N/A	N/A	N/A	N/A	-0.23	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page