

CUYO, Philippines

WMO: 986300

Lat: 10.854N

Lon: 121.008E

Elev: 4

StdP: 101.28

Time Zone: 8.00 (E08)

Period: 89-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.5	25.0	21.6	16.3	26.3	22.1	16.8	26.6	10.1	26.5	8.5	27.2	1.7	N/A	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.4	33.6	28.0	33.0	27.9	32.5	27.7	28.7	32.3	28.3	32.0	28.1	31.8	1.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.6	31.5	27.3	23.1	31.1	27.0	22.7	30.8	93.1	32.4	91.4	32.2	90.0	31.9	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.6	7.6	5.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.7	28.0	28.2	28.9	29.6	29.7	28.8	28.4	28.7	28.4	28.6	29.1	28.4
	DBStd	1.06	0.75	0.84	0.94	0.89	0.91	1.00	1.03	0.97	1.00	1.02	0.80	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6840	559	509	586	589	611	566	569	578	552	577	572	572
	CDD18.3	3798	301	276	328	339	353	316	311	320	302	318	322	313
	CDH23.3	43348	3094	2941	3729	4223	4393	3653	3453	3649	3345	3639	3779	3451
CDH26.7	15096	728	827	1311	1849	1927	1327	1099	1257	1058	1258	1413	1041	
Wind	WSAvg	2.3	3.7	3.2	2.5	1.7	1.2	1.2	2.1	2.6	1.5	1.6	2.7	4.1
Precipitation	PrecAvg	2219	12	9	28	42	197	331	416	403	331	251	111	66
	PrecMax	2715	57	50	260	332	447	648	659	883	474	521	380	197
	PrecMin	1426	1	0	0	0	50	171	165	175	130	62	5	1
	PrecStd	312	17	15	56	69	103	119	126	158	105	121	96	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	32.1	33.5	34.2	34.3	33.7	32.9	33.0	32.7	32.7	33.0	32.2
		MCWB	27.1	26.9	27.7	28.0	28.3	28.4	28.3	28.3	27.9	28.2	27.7	27.4
	2%	DB	30.8	31.3	32.3	33.3	33.5	32.8	32.1	32.1	32.1	32.1	32.2	31.6
		MCWB	26.9	26.6	27.4	27.8	28.0	28.2	27.7	27.8	27.7	27.9	27.4	27.1
	5%	DB	30.1	30.7	31.6	32.7	33.0	32.1	31.5	31.5	31.4	31.5	31.7	30.9
		MCWB	26.7	26.4	27.2	27.7	27.8	27.8	27.4	27.5	27.4	27.6	27.2	26.9
	10%	DB	29.6	30.1	30.9	32.0	32.4	31.3	30.8	30.8	30.6	30.9	31.2	30.2
		MCWB	26.4	26.2	26.9	27.5	27.7	27.4	27.1	27.2	27.1	27.3	27.1	26.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	27.5	28.2	28.7	29.2	29.0	28.6	28.8	28.5	29.0	28.1	27.9
		MCDB	30.7	30.9	31.7	32.6	33.1	32.8	32.2	32.1	32.0	32.0	31.5	31.2
	2%	WB	27.1	27.1	27.7	28.2	28.5	28.4	28.1	28.2	27.9	28.3	27.7	27.5
		MCDB	30.0	30.4	31.3	32.2	32.6	32.1	31.5	31.5	31.4	31.4	31.2	30.6
	5%	WB	26.9	26.8	27.5	28.0	28.1	27.9	27.6	27.7	27.5	27.8	27.5	27.2
		MCDB	29.5	29.9	30.9	32.0	32.2	31.5	30.9	30.9	30.8	30.9	31.0	30.2
	10%	WB	26.6	26.5	27.2	27.7	27.7	27.5	27.1	27.2	27.1	27.4	27.2	26.9
		MCDB	29.0	29.4	30.4	31.4	31.6	30.8	30.3	30.3	30.1	30.3	30.6	29.8
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.5	4.9	5.3	5.4	5.1	4.5	4.5	4.6	4.5	4.9	4.2
		MCDBR	4.5	5.1	5.4	6.0	6.2	6.0	5.7	5.3	5.7	5.3	5.3	4.7
		MCWBR	2.1	2.3	2.2	2.6	2.4	2.8	2.8	2.5	2.6	2.5	2.3	2.1
	5% WB	MCDBR	4.1	4.7	5.2	5.6	5.9	5.9	5.4	5.3	5.4	5.0	5.1	4.5
		MCWBR	2.1	2.4	2.3	2.6	2.5	3.0	3.0	2.9	2.7	2.8	2.5	2.2
Clear-Sky Solar Irradiance	taub	0.433	0.421	0.431	0.444	0.436	0.427	0.428	0.443	0.434	0.448	0.440	0.441	
	taud	2.460	2.474	2.459	2.420	2.464	2.502	2.497	2.434	2.455	2.415	2.438	2.426	
	Ebn at Noon	875	898	891	869	860	858	859	858	875	861	861	857	
	Edh at Noon	112	113	117	120	113	107	108	117	115	119	113	114	
All-Sky Solar Radiation	RadAvg	5.21	5.96	6.55	6.79	5.83	5.00	4.62	4.83	4.83	5.09	5.23	4.88	
	RadStd	0.40	0.43	0.46	0.36	0.60	0.41	0.47	0.42	0.50	0.40	0.36	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page