

ILOILO, Philippines

WMO: 986370

Lat: 10.7728N

Lon: 122.5794E

Elev: 6

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.8	(c) 23.2	(d) 20.5	(e) 15.2	(f) 23.9	(g) 20.9	(h) 15.6	(i) 24.2	(j) 8.4	(k) 28.1	(l) 7.8	(m) 28.5	(n) 2.5	(o) 20	(p) 0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 7.4	(c) 34.7	(d) 27.9	(e) 33.9	(f) 27.7	(g) 33.2	(h) 27.5	(i) 28.5	(j) 33.2	(k) 28.2	(l) 32.8	(m) 27.9	(n) 32.5	(o) 3.6	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.0	31.6	26.9	22.6	31.5	26.6	22.2	31.3	92.2	33.5	90.6	33.0	89.3	32.7	34.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.4	6.4	5.6	20.3	37.1	2.6	1.5	18.4	38.2	16.9	39.0	15.5	39.8	13.6	40.9
			19.0	29.8	2.4	2.0	17.2	31.2	15.8	32.4	14.5	33.5	12.7	34.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	26.7	27.3	28.0	29.3	29.4	28.5	27.9	27.9	27.8	28.0	27.9	27.2	(6)
(7)		DBStd	1.30	1.02	1.07	1.15	1.08	1.31	1.15	1.03	0.98	1.04	0.93	0.96	0.96	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6564	518	486	558	579	602	556	554	554	533	557	536	533	(10)
(11)		CDD18.3	3522	259	252	299	329	343	306	296	296	283	298	286	275	(11)
(12)		CDH23.3	37976	2268	2442	3237	4106	4308	3558	3131	3142	2946	3190	3021	2628	(12)
(13)		CDH26.7	13740	617	809	1239	1894	1980	1399	998	1013	921	1078	1012	778	(13)
(14)	Wind	WSAvg	2.4	3.2	3.2	2.8	2.6	2.2	1.6	1.9	2.3	2.1	1.6	2.3	2.8	(14)
(15)	Precipitation	PrecAvg	2024	41	26	32	47	131	293	346	359	246	247	174	89	(15)
(16)		PrecMax	3066	185	122	152	226	514	648	979	892	519	706	484	321	(16)
(17)		PrecMin	1186	0	0	0	0	0	87	82	50	34	25	37	9	(17)
(18)		PrecStd	440	42	27	34	50	118	134	173	181	121	150	108	73	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	33.3	34.0	35.5	35.8	34.3	34.0	33.0	33.2	33.2	32.9	32.4	(19)
(20)			MCWB	26.5	27.3	27.7	28.1	28.1	28.1	27.7	27.7	27.6	27.9	27.5	27.1	(20)
(21)		2%	DB	31.1	32.2	33.1	34.5	34.8	33.4	32.5	32.1	32.1	32.4	32.2	31.5	(21)
(22)			MCWB	26.3	26.9	27.2	27.8	28.0	27.7	27.3	27.2	27.2	27.4	27.1	26.7	(22)
(23)		5%	DB	30.4	31.6	32.5	33.8	34.0	32.7	31.6	31.4	31.4	31.8	31.6	30.9	(23)
(24)			MCWB	26.0	26.5	26.9	27.6	27.8	27.5	27.0	27.0	27.0	27.1	26.8	26.4	(24)
(25)		10%	DB	29.8	30.8	31.8	33.1	33.2	31.9	30.8	30.8	30.8	31.1	31.0	30.2	(25)
(26)			MCWB	25.7	26.2	26.6	27.3	27.6	27.3	26.6	26.7	26.7	26.8	26.5	26.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.9	28.2	28.7	28.9	28.8	28.2	28.3	28.3	28.2	27.9	27.7	(27)
(28)			MCD B	31.0	32.5	33.1	34.0	34.1	33.0	31.9	32.0	31.9	32.1	32.0	31.3	(28)
(29)		2%	WB	26.7	27.2	27.6	28.3	28.5	28.2	27.7	27.7	27.7	27.7	27.5	27.2	(29)
(30)			MCD B	30.3	31.6	32.5	33.6	33.7	32.3	31.7	31.2	31.3	31.6	31.5	30.8	(30)
(31)		5%	WB	26.3	26.7	27.1	28.0	28.1	27.8	27.3	27.3	27.2	27.3	27.1	26.7	(31)
(32)			MCD B	29.8	30.9	31.9	33.3	33.2	31.8	31.0	30.7	30.8	31.2	31.0	30.3	(32)
(33)		10%	WB	25.9	26.3	26.7	27.6	27.7	27.4	26.8	26.9	26.8	26.9	26.7	26.2	(33)
(34)			MCD B	29.3	30.4	31.3	32.6	32.6	31.3	30.2	30.2	30.2	30.7	30.4	29.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.1	6.7	7.4	8.1	7.4	6.7	5.9	5.9	6.0	6.4	6.5	6.3	(35)
(36)			MCDBR	7.1	7.9	8.4	9.0	8.8	7.8	7.4	6.9	7.2	7.5	7.5	7.1	(36)
(37)			MCWBR	3.7	4.2	4.3	4.3	4.3	4.0	3.9	3.7	3.9	4.0	3.8	3.7	(37)
(38)		5% WB	MCDBR	6.7	7.5	8.1	8.6	8.1	7.4	6.9	6.5	6.6	7.2	7.1	6.7	(38)
(39)			MCWBR	3.9	4.3	4.4	4.4	4.2	4.0	3.8	3.7	3.8	4.0	3.8	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.426	0.419	0.428	0.441	0.442	0.434	0.432	0.446	0.439	0.452	0.437	0.432	(40)	
(41)		taud	2.430	2.433	2.416	2.376	2.395	2.431	2.439	2.383	2.397	2.358	2.403	2.409	(41)	
(42)		Ebn at Noon	880	900	893	871	855	851	856	856	870	857	863	865	(42)	
(43)		Edh at Noon	115	118	122	126	121	115	115	123	122	126	117	115	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.45	5.27	5.91	6.30	5.64	5.07	4.66	4.78	4.82	4.80	4.77	4.31	(44)	
(45)		RadStd	0.46	0.50	0.53	0.28	0.49	0.36	0.40	0.38	0.46	0.32	0.36	0.31	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (5 neighbors)	+0.24	+0.21	N/A	+0.43	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page