

TAGBILARAN, Philippines

WMO: 986440

Lat: 9.664N

Lon: 123.853E

Elev: 12

StdP: 101.19

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.2	22.9	20.3	15.0	24.0	20.9	15.6	24.7	6.6	26.7	5.7	27.6	0.9	0	0.330

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.7	33.8	27.4	33.3	27.3	32.8	27.1	28.3	32.1	28.0	31.9	27.7	31.5	2.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.1	30.8	26.9	22.6	30.7	26.7	22.3	30.4	91.3	32.0	89.8	32.1	88.5	31.8	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.5	4.8	4.2	DB	20.0	35.0	2.2	1.6	18.4	36.2	17.1	37.1	15.9	38.0	14.2	39.2	(4)
			WB	19.5	29.2	1.7	0.5	18.2	29.6	17.2	29.9	16.2	30.2	15.0	30.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	26.8	27.0	27.5	28.3	28.9	28.5	28.3	28.7	28.5	28.2	27.8	27.4	(6)
		DBStd	1.21	1.05	1.13	1.17	0.99	0.88	1.00	1.02	1.11	1.11	0.99	0.88	0.92	(7)
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
		CDD10.0	6565	522	476	542	548	586	554	567	578	554	563	535	539	(10)
		CDD18.3	3523	263	243	283	298	328	304	308	320	304	305	285	281	(11)
		CDH23.3	38514	2341	2309	2941	3469	4056	3538	3476	3762	3531	3359	2974	2758	(12)
		CDH26.7	13843	619	711	1034	1399	1727	1348	1246	1477	1332	1177	960	814	(13)
(14)	Wind	WSAvg	1.6	1.7	1.6	1.6	1.4	1.5	1.4	1.7	1.8	1.7	1.5	1.4	1.6	(14)
(15)	Precipitation	PrecAvg	1413	119	84	99	80	88	145	145	120	125	173	182	137	(15)
		PrecMax	1984	422	244	839	234	211	303	381	241	327	385	448	362	(16)
		PrecMin	952	7	1	2	0	0	9	10	11	25	30	9	34	(17)
		PrecStd	283	95	62	132	62	61	73	71	56	70	71	88	80	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	33.0	33.6	34.1	34.2	34.2	33.6	34.4	34.1	33.6	32.9	32.6	(19)
			MCWB	26.1	26.4	26.6	27.3	27.5	27.7	27.6	27.5	27.4	27.6	27.2	27.0	(20)
		2%	DB	31.2	32.0	32.6	33.2	33.5	33.0	32.7	33.4	33.1	32.6	32.1	31.7	(21)
			MCWB	26.0	26.2	26.6	27.0	27.4	27.4	27.3	27.4	27.3	27.3	27.1	26.8	(22)
		5%	DB	30.5	31.2	31.8	32.5	32.8	32.2	32.0	32.6	32.3	31.8	31.5	30.9	(23)
			MCWB	25.9	25.9	26.4	26.9	27.3	27.3	27.1	27.1	27.1	27.2	26.9	26.6	(24)
		10%	DB	29.8	30.4	31.0	31.8	32.1	31.5	31.3	31.7	31.5	31.1	30.7	30.3	(25)
			MCWB	25.8	25.7	26.2	26.7	27.2	27.1	27.0	26.9	26.9	26.9	26.8	26.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.6	27.8	28.3	28.6	28.7	28.3	28.5	28.2	28.2	28.1	28.0	(27)
			MCDB	30.4	31.3	31.8	32.5	32.4	32.1	32.0	32.7	32.2	31.9	31.5	31.1	(28)
		2%	WB	26.8	26.9	27.3	27.7	28.1	28.0	27.8	27.9	27.7	27.7	27.6	27.5	(29)
			MCDB	29.9	30.6	31.3	31.9	32.1	31.7	31.5	32.0	31.6	31.4	31.0	30.6	(30)
		5%	WB	26.4	26.5	26.9	27.4	27.7	27.6	27.5	27.5	27.4	27.4	27.2	27.1	(31)
			MCDB	29.5	30.1	30.8	31.5	31.7	31.2	31.1	31.4	31.2	31.0	30.5	30.2	(32)
		10%	WB	26.0	26.1	26.5	27.0	27.4	27.2	27.1	27.1	27.1	27.1	26.9	26.7	(33)
			MCDB	29.0	29.5	30.2	31.0	31.3	30.7	30.7	30.9	30.8	30.5	30.2	29.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.9	6.7	7.1	7.2	6.7	6.2	6.0	6.2	6.0	6.2	6.2	6.0	(35)
			MCDBR	7.1	8.1	8.2	8.2	7.5	7.2	6.9	7.5	7.3	7.2	7.1	7.0	(36)
		5% WB	MCWBR	3.4	3.7	3.9	3.8	3.4	3.3	3.3	3.2	3.1	3.4	3.5	3.4	(37)
			MCWBR	6.3	7.0	7.4	7.5	6.9	6.6	6.5	6.7	6.5	6.7	6.6	6.4	(38)
(40)	Clear-Sky Solar Irradiance	taub	0.429	0.419	0.419	0.425	0.425	0.417	0.419	0.438	0.434	0.446	0.428	0.426	(40)	
		taud	2.443	2.459	2.465	2.445	2.461	2.493	2.488	2.417	2.423	2.388	2.452	2.455	(41)	
		Ebn at Noon	881	902	903	885	869	865	866	862	875	865	876	875	(42)	
		Edh at Noon	114	116	116	117	113	108	109	119	119	122	112	111	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.13	4.93	5.74	6.23	5.73	5.21	4.96	5.17	5.04	4.90	4.64	4.21	(44)	
		RadStd	0.51	0.50	0.48	0.28	0.37	0.29	0.29	0.36	0.44	0.32	0.39	0.38	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.15	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page