

MAASIN, Philippines

WMO: 986480

Lat: 10.1348N

Lon: 124.8610E

Elev: 236

StdP: 14.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.4	73.2	68.5	105.6	74.9	69.6	109.6	75.2	18.2	80.3	13.7	80.1	4.0	0	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.9	92.1	82.5	90.9	82.3	90.0	82.1	84.5	89.2	83.7	88.6	83.1	88.2	5.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
83.2	174.9	88.2	82.5	170.7	87.9	81.8	166.7	87.4	48.9	89.7	48.2	88.6	47.4	88.4	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.6	11.4	9.6	DB	68.6	96.0	3.5	3.8	66.1	98.7	64.0	101.0	62.1	103.1	59.5	105.9	
			WB	68.0	86.0	2.0	1.2	66.6	86.9	65.4	87.6	64.3	88.3	62.8	89.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	78.9	79.7	80.9	82.7	83.7	82.8	81.5	81.8	81.4	81.5	81.1	80.3	(6)
(7)		DBStd	2.38	2.32	2.10	2.06	2.21	1.99	2.23	1.85	1.81	1.81	1.71	1.85	2.02	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11451	896	831	957	981	1045	985	978	985	943	977	933	940	(10)
(11)		CDD65	5976	431	411	492	531	580	535	513	520	493	512	483	475	(11)
(12)		CDH74	59446	3232	3377	4633	5791	6817	6004	5268	5430	4968	5066	4625	4235	(12)
(13)		CDH80	18308	646	800	1367	2111	2731	2164	1568	1643	1469	1488	1282	1039	(13)
(14)	Wind	WSAvg	3.7	3.6	3.9	3.9	3.7	3.6	3.5	3.7	3.9	3.8	3.7	3.5	3.9	(14)
(15)	Precipitation	PrecAvg	97.2	13.0	8.2	6.6	3.5	4.0	6.8	8.0	7.5	9.0	8.8	10.4	12.1	(15)
(16)		PrecMax	187.6	47.1	24.9	30.3	11.4	10.0	13.6	12.7	14.1	17.0	18.1	23.6	35.9	(16)
(17)		PrecMin	50.2	3.0	0.7	0.5	0.5	0.4	1.7	2.7	2.8	3.7	2.6	3.6	3.1	(17)
(18)		PrecStd	29.5	8.9	6.3	6.1	2.2	2.4	3.0	2.5	3.3	3.5	3.9	5.0	6.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.0	88.9	90.7	93.1	93.9	93.2	90.8	90.0	90.3	90.7	90.1	89.5	(19)
(20)			MCWB	80.6	81.6	80.4	82.0	82.9	83.6	82.9	83.7	82.9	82.9	83.0	83.1	(20)
(21)		2%	DB	86.5	87.4	89.1	91.4	92.3	91.5	89.1	88.9	89.0	89.2	88.7	87.9	(21)
(22)			MCWB	80.0	80.3	80.2	81.8	82.7	82.8	82.5	82.9	82.4	82.2	82.1	81.9	(22)
(23)		5%	DB	85.4	86.1	87.8	90.1	90.9	90.0	87.9	87.9	87.9	87.9	87.5	86.6	(23)
(24)			MCWB	79.6	79.6	80.1	81.4	82.4	82.5	82.0	82.1	81.9	81.4	81.0	80.9	(24)
(25)		10%	DB	83.8	84.7	86.4	88.8	89.7	88.6	86.6	86.7	86.6	86.6	86.2	85.4	(25)
(26)			MCWB	79.0	78.8	79.5	80.9	82.1	82.1	81.4	81.6	81.3	80.9	80.4	80.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.0	82.9	83.6	84.4	85.3	84.8	84.4	84.8	84.5	84.2	84.2	83.9	(27)
(28)			MCD B	85.5	87.0	87.6	90.8	91.0	89.7	88.1	88.5	88.2	88.3	89.0	87.9	(28)
(29)		2%	WB	80.9	81.2	82.1	83.0	84.1	83.9	83.2	83.6	83.1	82.8	82.7	82.6	(29)
(30)			MCD B	85.1	85.7	87.0	89.5	90.2	89.1	87.4	87.6	87.1	87.4	87.4	87.1	(30)
(31)		5%	WB	80.0	80.0	80.9	82.1	83.2	83.0	82.3	82.7	82.1	81.8	81.6	81.5	(31)
(32)			MCD B	84.3	84.7	86.2	88.6	89.5	88.4	86.8	86.7	86.3	86.5	86.4	85.9	(32)
(33)		10%	WB	79.0	79.0	79.8	81.0	82.4	82.1	81.4	81.7	81.2	80.9	80.5	80.4	(33)
(34)			MCD B	83.1	83.7	85.2	87.6	88.9	87.6	85.8	85.9	85.5	85.5	85.3	84.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.6	9.8	11.0	11.9	11.9	10.8	9.8	9.8	10.2	10.5	10.1	9.5	(35)
(36)			MCDBR	11.5	11.8	13.0	13.9	13.6	12.8	11.7	11.3	12.2	12.5	12.2	11.7	(36)
(37)			MCWBR	7.5	7.6	7.9	7.9	7.6	7.4	7.7	7.6	8.2	8.1	8.2	8.1	(37)
(38)		5% WB	MCD BR	10.2	10.7	12.0	13.0	12.5	11.7	11.0	10.7	11.2	11.3	11.7	11.3	(38)
(39)			MCWBR	7.5	7.9	8.5	8.6	8.3	8.0	8.0	8.2	8.2	8.3	8.5	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.441	0.425	0.418	0.416	0.415	0.411	0.415	0.435	0.429	0.438	0.425	0.432	(40)	
(41)		taud	2.397	2.440	2.470	2.473	2.497	2.521	2.504	2.430	2.442	2.417	2.465	2.434	(41)	
(42)		Ebn at Noon	275	284	286	284	279	276	276	274	279	276	278	275	(42)	
(43)		Edh at Noon	38	37	37	36	35	33	34	37	37	38	35	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1228	1504	1758	1933	1846	1661	1590	1657	1633	1560	1404	1261	(44)	
(45)		RadStd	181	168	165	117	120	108	103	105	142	107	126	125	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.27	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page