

MAASIN, Philippines

WMO: 986480

Lat: 10.1348N

Lon: 124.8610E

Elev: 72

StdP: 100.46

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.4	22.9	20.3	15.1	23.8	20.9	15.7	24.0	8.1	26.9	6.1	26.7	1.8	0	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.6	33.4	28.1	32.7	27.9	32.2	27.9	29.1	31.8	28.7	31.5	28.4	31.2	2.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.4	25.0	31.2	28.0	24.4	31.1	27.6	23.8	30.8	95.9	32.0	94.1	31.4	92.4	31.4	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.1	4.3	DB	20.4	35.6	2.0	2.1	18.9	37.1	17.8	38.3	16.7	39.5	15.3	41.0	(4)
(5)			WB	20.0	30.0	1.1	0.7	19.2	30.5	18.6	30.9	17.9	31.3	17.1	31.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	26.1	26.5	27.1	28.2	28.7	28.2	27.5	27.7	27.5	27.5	27.3	26.8	(6)
(7)		DBStd	1.32	1.29	1.17	1.14	1.23	1.11	1.24	1.03	1.00	1.00	0.95	1.03	1.12	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6362	498	462	532	545	581	547	543	547	524	543	518	522	(10)
(11)		CDD18.3	3320	239	228	273	295	322	297	285	289	274	284	268	264	(11)
(12)		CDH23.3	33026	1796	1876	2574	3217	3787	3336	2927	3017	2760	2814	2569	2353	(12)
(13)		CDH26.7	10171	359	444	759	1173	1517	1202	871	913	816	827	712	577	(13)
(14)	Wind	WSAvg	1.7	1.6	1.8	1.7	1.7	1.6	1.6	1.7	1.8	1.7	1.7	1.6	1.7	(14)
(15)	Precipitation	PrecAvg	2470	330	208	168	88	101	172	204	191	229	224	265	307	(15)
(16)		PrecMax	4766	1196	633	770	290	253	346	322	357	433	461	600	911	(16)
(17)		PrecMin	1274	76	17	13	12	11	43	69	70	93	65	92	80	(17)
(18)		PrecStd	749	226	161	154	57	62	75	64	83	89	100	127	171	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.6	32.6	33.9	34.4	34.0	32.6	32.2	32.4	32.6	32.3	32.0	(19)
(20)			MCWB	27.0	27.6	26.9	27.8	28.3	28.6	28.3	28.7	28.3	28.3	28.4	28.4	(20)
(21)		2%	DB	30.3	30.8	31.7	33.0	33.5	33.0	31.7	31.6	31.7	31.8	31.5	31.0	(21)
(22)			MCWB	26.7	26.8	26.8	27.6	28.1	28.2	28.0	28.3	28.0	27.9	27.8	27.7	(22)
(23)		5%	DB	29.6	30.1	31.0	32.3	32.7	32.2	31.1	31.0	31.0	31.1	30.8	30.3	(23)
(24)			MCWB	26.4	26.4	26.7	27.4	28.0	28.0	27.8	27.9	27.7	27.5	27.2	27.2	(24)
(25)		10%	DB	28.8	29.3	30.2	31.5	32.1	31.5	30.3	30.4	30.3	30.3	30.1	29.6	(25)
(26)			MCWB	26.1	26.0	26.4	27.2	27.8	27.8	27.4	27.6	27.4	27.1	26.9	26.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.8	28.3	28.7	29.1	29.6	29.4	29.1	29.3	29.1	29.0	29.0	28.8	(27)
(28)			MCD B	29.7	30.5	30.9	32.6	32.8	32.0	31.1	31.4	31.2	31.3	31.6	31.1	(28)
(29)		2%	WB	27.2	27.3	27.9	28.3	29.0	28.9	28.5	28.7	28.4	28.2	28.2	28.1	(29)
(30)			MCD B	29.5	29.9	30.6	32.0	32.3	31.7	30.8	30.9	30.6	30.8	30.8	30.6	(30)
(31)		5%	WB	26.7	26.7	27.2	27.8	28.5	28.3	28.0	28.1	27.9	27.7	27.6	27.5	(31)
(32)			MCD B	29.1	29.3	30.1	31.5	32.0	31.3	30.5	30.4	30.2	30.3	30.2	30.0	(32)
(33)		10%	WB	26.1	26.1	26.5	27.2	28.0	27.9	27.4	27.6	27.3	27.1	27.0	26.9	(33)
(34)			MCD B	28.4	28.7	29.6	30.9	31.6	30.9	29.9	29.9	29.7	29.7	29.6	29.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.4	6.1	6.6	6.6	6.0	5.5	5.5	5.7	5.8	5.6	5.3	(35)
(36)			MCDBR	6.4	6.6	7.2	7.7	7.5	7.1	6.5	6.3	6.8	6.9	6.8	6.5	(36)
(37)			MCWBR	4.1	4.2	4.4	4.4	4.2	4.1	4.3	4.2	4.5	4.5	4.5	4.5	(37)
(38)		5% WB	MCD BR	5.7	5.9	6.6	7.2	6.9	6.5	6.1	5.9	6.2	6.3	6.5	6.3	(38)
(39)			MCWBR	4.2	4.4	4.7	4.8	4.6	4.4	4.4	4.5	4.6	4.6	4.7	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.441	0.425	0.418	0.416	0.415	0.411	0.415	0.435	0.429	0.438	0.425	0.432	(40)	
(41)		taud	2.397	2.440	2.470	2.473	2.497	2.521	2.504	2.430	2.442	2.417	2.465	2.434	(41)	
(42)		Ebn at Noon	868	896	903	894	878	871	870	865	879	871	877	868	(42)	
(43)		Edh at Noon	119	118	116	114	109	105	107	118	117	119	111	113	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.87	4.74	5.54	6.09	5.82	5.24	5.01	5.22	5.15	4.92	4.43	3.98	(44)	
(45)		RadStd	0.57	0.53	0.52	0.37	0.38	0.34	0.33	0.33	0.45	0.34	0.40	0.39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		+0.15	N/A	N/A	+0.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page