

DIPOLOG, Philippines

WMO: 987410

Lat: 8.5995N

Lon: 123.3439E

Elev: 12

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	74.2	74.8	70.5	112.3	81.5	72.1	118.6	79.7	12.3	81.8	11.4	82.4	2.5	140	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	12.8	92.6	81.4	91.5	81.6	90.5	81.5	83.6	89.6	82.9	89.2	82.6	89.0	6.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.8	165.5	88.2	81.0	161.3	88.0	80.6	159.1	87.9	47.5	89.9	46.9	89.5	46.3	89.3	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	10.9	9.0	72.1	94.3	2.3	3.3	70.5	96.7	69.2	98.6	67.9	100.5	66.2	102.9		
(5)			71.0	84.3	2.9	1.0	69.0	85.0	67.3	85.6	65.7	86.2	63.6	86.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	80.5	80.9	81.9	83.0	83.0	82.3	82.0	82.5	82.2	82.2	81.5	81.4		
	DBStd	1.67	1.50	1.43	1.44	1.69	1.45	1.50	1.47	1.52	1.52	1.42	1.50	1.51		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11672	946	867	990	991	1024	970	993	1009	965	998	946	973		
	CDD65	6197	481	447	525	541	559	520	528	544	515	533	496	508		
	CDH74	67642	4731	4550	5845	6413	6541	5809	5687	6024	5573	5740	5299	5430		
	CDH80	23772	1196	1337	2070	2573	2612	2131	2036	2271	2012	2057	1760	1717		
(14) Wind	WSAvg	3.5	3.8	3.9	4.0	3.3	3.3	3.1	3.7	3.8	3.8	3.3	3.0	3.6		
(15) Precipitation	PrecAvg	96.8	6.5	3.0	3.3	3.4	8.6	8.7	9.1	8.9	8.9	11.1	13.3	12.0		
	PrecMax	119.6	18.4	6.9	9.1	10.8	19.6	15.0	18.3	16.0	17.9	20.8	32.6	25.9		
	PrecMin	59.9	0.6	0.4	0.2	0.1	2.4	3.4	4.0	2.5	3.5	2.8	3.8	2.0		
	PrecStd	15.4	4.9	2.0	2.9	2.5	4.4	3.1	4.1	3.5	4.4	6.1	8.0	6.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	89.9	91.6	93.5	93.6	92.5	92.3	93.2	92.2	93.0	91.8	90.9		
		MCWB	80.9	79.0	79.6	79.4	82.2	82.2	81.9	81.4	81.6	81.6	81.3	81.1		
	2%	DB	87.3	88.2	89.8	91.5	91.8	90.8	90.6	91.4	90.6	90.6	89.4	88.9		
		MCWB	80.2	79.6	80.1	81.0	82.3	82.1	81.8	81.6	81.7	81.7	81.7	81.1		
	5%	DB	86.3	87.2	88.7	90.0	90.3	89.4	89.2	89.8	89.3	89.1	88.1	87.7		
		MCWB	79.9	79.6	80.1	81.2	82.1	81.9	81.6	81.4	81.4	81.5	81.2	80.9		
	10%	DB	85.3	86.2	87.5	88.9	89.0	88.2	87.9	88.5	88.1	87.9	87.1	86.6		
		MCWB	79.5	79.4	80.0	81.1	81.8	81.4	81.0	81.0	81.0	81.0	80.9	80.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	81.8	82.5	83.6	84.3	84.1	83.8	83.6	83.4	83.5	82.9	82.8		
		MCDB	87.4	87.9	88.9	89.5	90.3	89.4	89.8	89.9	90.0	90.3	88.4	88.4		
	2%	WB	80.9	80.9	81.7	82.7	83.3	83.1	82.7	82.6	82.5	82.6	82.3	82.1		
		MCDB	86.2	86.7	88.2	89.1	89.7	88.9	89.1	89.5	89.3	89.2	87.8	87.8		
	5%	WB	80.3	80.4	81.0	82.0	82.6	82.4	81.9	81.9	81.8	81.8	81.6	81.4		
		MCDB	85.3	85.9	87.3	88.6	89.2	88.5	88.3	88.7	88.4	88.2	87.1	86.8		
	10%	WB	79.8	79.7	80.4	81.5	81.9	81.6	81.2	81.2	81.1	81.1	81.0	80.6		
		MCDB	84.4	85.1	86.6	87.9	88.3	87.5	87.3	87.7	87.4	87.2	86.4	85.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	10.7	12.1	12.8	13.1	12.5	12.6	13.1	12.7	12.8	11.7	11.0		
		MCDBR	11.3	12.4	13.7	14.3	14.8	14.1	14.2	14.8	14.5	14.2	13.1	12.6		
	5% WB	MCWBR	5.8	5.8	6.4	6.8	7.4	7.3	7.4	7.2	7.4	7.3	7.0	6.6		
		MCWBR	10.6	11.5	12.7	13.5	13.8	13.6	13.7	14.0	14.0	13.7	12.6	12.3		
(40) Clear-Sky Solar Irradiance	taub	taub	0.430	0.425	0.429	0.441	0.437	0.423	0.418	0.438	0.437	0.452	0.435	0.433		
		taud	2.441	2.445	2.441	2.405	2.428	2.476	2.490	2.414	2.407	2.371	2.428	2.431		
	Ebn at Noon	Ebn at Noon	280	285	284	276	272	272	275	273	277	273	276	276		
		Edh at Noon	36	37	38	39	37	35	35	38	39	40	37	36		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1391	1624	1836	1925	1732	1584	1532	1598	1588	1526	1499	1419		
	RadStd	RadStd	146	161	127	88	99	74	85	111	129	105	115	114		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.40	N/A	N/A	+1.10	+0.85	+0.70	N/A	N/A	N/A	N/A

Nomenclature: See separate page