

DIPOLOG, Philippines

WMO: 987410

Lat: 8.5995N

Lon: 123.3439E

Elev: 4

StdP: 101.28

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	23.8	21.4	16.0	27.5	22.3	16.9	26.5	5.5	27.7	5.1	28.0	1.1	140	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	7.1	33.6	27.4	33.1	27.5	32.5	27.5	28.6	32.0	28.3	31.8	28.1	31.6	2.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.6	31.2	27.2	23.0	31.1	27.0	22.7	31.1	92.6	32.2	91.3	32.0	89.9	31.8	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	4.9	4.0	DB	22.3	34.6	1.3	1.9	21.4	35.9	20.7	37.0	19.9	38.1	19.0	39.4	(4)
(5)			WB	21.7	29.1	1.6	0.5	20.5	29.5	19.6	29.8	18.7	30.1	17.5	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	26.9	27.2	27.7	28.4	28.4	28.0	27.8	28.1	27.9	27.9	27.5	27.4	(6)	
	DBStd	0.93	0.84	0.79	0.80	0.94	0.81	0.83	0.82	0.85	0.85	0.79	0.83	0.84	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6484	526	482	550	551	569	539	552	561	536	554	526	541	(10)	
	CDD18.3	3443	267	248	292	301	311	289	293	302	286	296	276	282	(11)	
	CDH23.3	37579	2628	2528	3247	3563	3634	3227	3159	3347	3096	3189	2944	3017	(12)	
(13)	CDH26.7	13207	664	743	1150	1429	1451	1184	1131	1262	1118	1143	978	954	(13)	
(14)	Wind	WSAvg	1.6	1.7	1.8	1.8	1.5	1.5	1.4	1.6	1.7	1.7	1.5	1.4	1.6	(14)
(15) Precipitation	PrecAvg	2458	165	75	84	87	218	220	231	226	225	283	339	305	(15)	
	PrecMax	3037	467	176	230	274	499	382	465	407	454	529	827	657	(16)	
	PrecMin	1522	14	9	4	2	61	86	102	63	89	71	96	51	(17)	
	PrecStd	390	124	51	74	63	113	79	104	90	112	154	202	172	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	32.2	33.1	34.2	34.2	33.6	33.5	34.0	33.5	33.9	33.2	32.7	(19)	
		MCWB	27.2	26.1	26.4	26.4	27.9	27.9	27.7	27.5	27.6	27.6	27.4	27.3	(20)	
	2%	DB	30.7	31.2	32.1	33.0	33.2	32.7	32.6	33.0	32.6	32.6	31.9	31.6	(21)	
		MCWB	26.8	26.5	26.7	27.2	27.9	27.8	27.7	27.5	27.6	27.6	27.6	27.3	(22)	
	5%	DB	30.2	30.7	31.5	32.2	32.4	31.9	31.8	32.1	31.8	31.7	31.2	31.0	(23)	
		MCWB	26.6	26.5	26.7	27.4	27.8	27.7	27.5	27.4	27.5	27.5	27.3	27.2	(24)	
	10%	DB	29.6	30.1	30.8	31.6	31.7	31.2	31.1	31.4	31.2	31.1	30.6	30.3	(25)	
		MCWB	26.4	26.3	26.7	27.3	27.7	27.5	27.2	27.2	27.2	27.2	27.1	26.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.7	28.1	28.7	29.0	28.9	28.8	28.6	28.5	28.6	28.3	28.2	(27)	
		MCDB	30.8	31.1	31.6	31.9	32.4	31.9	32.1	32.2	32.2	32.4	31.3	31.4	(28)	
	2%	WB	27.2	27.2	27.6	28.2	28.5	28.4	28.2	28.1	28.1	28.1	27.9	27.8	(29)	
		MCDB	30.1	30.4	31.2	31.7	32.0	31.6	31.7	31.9	31.8	31.8	31.0	31.0	(30)	
	5%	WB	26.9	26.9	27.2	27.8	28.1	28.0	27.7	27.7	27.7	27.7	27.6	27.4	(31)	
		MCDB	29.6	30.0	30.7	31.4	31.8	31.4	31.3	31.5	31.3	31.2	30.6	30.4	(32)	
	10%	WB	26.5	26.5	26.9	27.5	27.7	27.6	27.3	27.3	27.3	27.3	27.2	27.0	(33)	
		MCDB	29.1	29.5	30.3	31.1	31.3	30.9	30.7	31.0	30.8	30.7	30.2	29.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.0	6.7	7.1	7.3	6.9	7.0	7.3	7.1	7.1	6.5	6.1	(35)	
		MCDBR	6.3	6.9	7.6	7.9	8.2	7.8	7.9	8.2	8.1	7.9	7.3	7.0	(36)	
	5% WB	MCWBR	3.2	3.2	3.5	3.8	4.1	4.1	4.1	4.0	4.1	4.0	3.9	3.7	(37)	
		MCWBR	5.9	6.4	7.1	7.5	7.7	7.5	7.6	7.8	7.8	7.6	7.0	6.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.430	0.425	0.429	0.441	0.437	0.423	0.418	0.438	0.437	0.452	0.435	0.433	(40)	
		taud	2.441	2.445	2.441	2.405	2.428	2.476	2.490	2.414	2.407	2.371	2.428	2.431	(41)	
	Edn at Noon	Edn at Noon	883	898	894	871	857	859	866	862	874	862	871	871	(42)	
		Edh at Noon	115	118	119	122	117	109	109	119	122	125	116	114	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.39	5.12	5.79	6.07	5.46	5.00	4.83	5.04	5.00	4.81	4.73	4.47	(44)	
	RadStd	RadStd	0.46	0.51	0.40	0.28	0.31	0.23	0.27	0.35	0.41	0.33	0.36	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.22	N/A	N/A	+0.61	+0.47	+0.39	N/A	N/A	N/A	N/A

Nomenclature: See separate page