

HINATUAN, Philippines

WMO: 987550

Lat: 8.375N

Lon: 126.318E

Elev: 3

StdP: 101.29

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	23.1	21.1	15.7	24.3	21.7	16.3	24.7	8.4	27.1	6.5	26.3	1.4	270	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.7	27.4	33.2	27.5	32.7	27.5	28.6	32.3	28.3	31.9	28.1	31.7	2.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.5	31.6	27.2	23.0	31.3	27.0	22.7	31.1	92.8	32.5	91.2	32.1	90.0	32.0	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.2	5.3	4.7	21.0	35.4	1.9	0.7	19.7	35.9	18.6	36.3	17.5	36.7	16.2	37.2		
(5)			20.2	29.4	1.7	0.6	19.0	29.8	17.9	30.1	17.0	30.5	15.7	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	26.5	26.6	27.0	27.7	28.2	28.2	28.2	28.6	28.4	28.1	27.4	27.1		
	DBStd	1.22	1.17	1.06	0.93	0.91	0.94	0.95	1.02	0.99	0.93	0.95	1.06	0.97		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6449	511	464	526	530	566	547	565	576	551	561	522	531		
	CDD18.3	3407	252	231	267	280	307	297	307	318	301	303	272	273		
	CDH23.3	35694	2176	2034	2602	3047	3546	3354	3377	3582	3322	3282	2737	2637		
	CDH26.7	12250	484	490	728	1032	1346	1296	1312	1475	1310	1216	844	717		
(14) Wind	WSAvg	1.8	1.9	1.9	1.9	1.7	1.6	1.6	1.8	1.9	1.8	1.8	1.6	1.9		
(15) Precipitation	PrecAvg	4452	724	587	446	351	278	252	201	199	206	226	348	612		
	PrecMax	5926	1549	1308	745	837	520	437	344	361	437	500	741	976		
	PrecMin	3120	179	146	122	120	103	78	82	40	87	61	19	152		
	PrecStd	806	331	306	169	184	113	108	67	89	89	113	162	224		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	31.7	32.2	33.0	33.6	33.7	34.1	34.7	34.5	34.1	32.9	32.4		
		MCWB	27.1	27.2	27.4	27.9	28.0	28.2	27.2	26.7	27.2	27.0	27.6	27.7		
	2%	DB	30.7	30.9	31.4	32.2	32.7	32.9	33.1	33.6	33.3	33.0	32.1	31.4		
		MCWB	26.7	26.9	27.1	27.6	27.9	28.0	27.3	27.0	27.3	27.3	27.5	27.3		
	5%	DB	29.9	30.2	30.7	31.5	32.1	32.3	32.4	32.7	32.6	32.1	31.4	30.6		
		MCWB	26.4	26.6	26.7	27.3	27.7	27.8	27.3	27.2	27.3	27.3	27.3	26.9		
	10%	DB	29.2	29.4	29.9	30.8	31.4	31.6	31.7	32.0	31.8	31.3	30.5	29.9		
		MCWB	26.0	26.1	26.2	27.0	27.4	27.5	27.1	27.2	27.2	27.0	26.9	26.5		
	0.4%	WB	27.7	27.9	28.1	28.6	28.9	29.0	28.6	28.6	28.7	28.6	28.5	28.4		
		MCDB	30.6	30.9	31.4	32.1	32.5	32.8	32.4	32.4	32.6	32.3	31.8	31.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.1	27.3	27.4	28.0	28.4	28.4	28.1	28.1	28.2	28.0	28.0	27.7		
		MCDB	30.0	30.3	30.6	31.6	31.9	32.2	32.0	32.1	32.1	31.8	31.5	30.7		
	5%	WB	26.7	26.9	27.0	27.6	28.0	28.0	27.7	27.7	27.8	27.6	27.5	27.2		
		MCDB	29.3	29.8	30.1	30.9	31.5	31.8	31.6	31.7	31.7	31.2	30.7	30.0		
	10%	WB	26.2	26.3	26.6	27.2	27.6	27.6	27.2	27.3	27.3	27.1	27.1	26.8		
		MCDB	28.6	28.9	29.4	30.4	30.9	31.2	31.0	31.3	31.1	30.7	30.0	29.3		
	5% DB	MDBR	5.0	5.4	5.7	6.1	6.4	6.9	7.1	7.6	7.4	7.0	6.0	5.4		
		MCDBR	6.4	6.6	7.1	7.3	7.6	7.9	8.2	8.5	8.6	8.2	7.5	6.8		
		MCWBR	3.4	3.6	3.7	3.7	3.8	4.2	4.0	4.0	4.1	4.0	3.9	3.6		
		MCWBR	5.8	6.2	6.4	6.9	7.2	7.7	7.7	8.0	8.1	7.6	7.0	6.3		
	5% WB	MCWBR	3.3	3.6	3.7	3.8	3.9	4.3	4.2	4.3	4.4	4.2	3.9	3.6		
(40) Clear-Sky Solar Irradiance	taub		0.454	0.442	0.426	0.418	0.408	0.397	0.406	0.427	0.425	0.436	0.419	0.437		
	taud		2.346	2.380	2.436	2.457	2.499	2.539	2.502	2.424	2.420	2.394	2.470	2.409		
	Ebn at Noon		860	883	897	891	882	881	877	872	884	876	888	868		
	Edh at Noon		127	126	120	116	109	103	107	118	120	122	111	117		
(44) All-Sky Solar Radiation	RadAvg		3.88	4.54	5.13	5.43	5.32	4.95	4.97	5.19	5.24	4.98	4.29	4.03		
	RadStd		0.45	0.48	0.41	0.41	0.35	0.32	0.34	0.31	0.41	0.35	0.40	0.36		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.24	N/A	N/A	N/A	N/A

Nomenclature: See separate page