

ZAMBOANGA, PhilippinesWMO: **988360**Lat: **6.922N**Lon: **122.060E**Elev: **33**StdP: **14.68**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.9	73.8	67.6	101.7	77.7	69.3	108.0	78.3	12.5	86.8	11.3	87.3	0.9	40	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.6	93.5	81.3	92.9	81.1	91.7	80.8	83.0	91.1	82.4	90.5	81.8	89.8	5.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.0	89.0	80.2	156.7	88.4	79.4	152.8	87.5	47.0	90.9	46.2	90.5	45.6	90.5	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.1	10.5	9.2	68.5	95.8	3.1	1.2	66.2	96.7	64.4	97.4	62.7	98.1	60.4	98.9		
			66.7	85.1	2.1	1.0	65.2	85.9	63.9	86.5	62.7	87.0	61.2	87.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	82.3	82.6	83.2	83.7	83.8	83.1	82.6	82.9	82.8	82.7	83.0	82.9
	DBStd	1.65	1.61	1.48	1.47	1.40	1.64	1.78	1.75	1.67	1.70	1.66	1.51	1.42
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12031	1000	913	1028	1010	1048	993	1012	1021	984	1012	990	1020
	CDD65	6556	535	493	563	560	583	543	547	556	534	547	540	555
	CDH74	71200	5539	5254	6288	6414	6655	5929	5821	6053	5708	5816	5799	5924
	CDH80	27584	2083	2084	2605	2658	2707	2216	2101	2275	2134	2161	2258	2302
Wind	WSAvg	3.4	3.0	3.3	3.4	3.5	3.2	3.2	3.5	3.7	3.7	3.7	3.1	3.2
Precipitation	PrecAvg	47.8	2.1	2.1	2.2	2.5	3.6	5.3	5.7	5.1	5.9	7.8	3.9	2.7
	PrecMax	62.1	6.4	8.2	6.9	7.3	10.5	10.7	14.1	12.6	14.0	24.8	12.0	11.3
	PrecMin	30.3	0.0	0.0	0.0	0.0	0.1	0.6	0.6	0.7	0.4	0.8	0.5	0.2
	PrecStd	8.7	1.8	1.9	1.9	2.0	2.0	2.3	2.7	2.8	3.5	4.6	2.4	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.0	93.2	93.8	94.4	94.9	93.5	93.0	93.0	93.3	93.3	93.5	93.3
		MCWB	80.0	80.1	80.3	81.4	82.5	82.0	81.6	81.4	81.1	81.5	81.5	81.1
	2%	DB	91.3	91.5	92.4	92.8	93.0	91.8	91.3	91.5	91.5	91.5	91.8	91.7
		MCWB	80.0	79.8	80.1	81.0	81.9	81.3	81.1	81.1	80.9	81.1	81.1	80.5
	5%	DB	89.8	90.2	91.2	91.4	91.4	90.3	89.8	90.0	90.0	90.0	90.9	90.4
		MCWB	79.7	79.5	79.9	80.8	81.4	80.8	80.6	80.6	80.6	80.6	80.8	80.2
	10%	DB	88.6	89.3	89.8	89.9	89.9	89.1	88.4	89.2	89.0	88.9	89.5	89.3
		MCWB	79.4	79.3	79.7	80.4	80.8	80.5	80.3	80.4	80.3	80.3	80.3	79.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	81.8	82.5	82.8	83.8	83.5	83.0	82.8	82.8	82.8	83.2	82.5
		MCDB	90.2	90.5	91.4	91.4	92.4	91.9	90.8	90.6	90.4	90.6	91.3	91.0
	2%	WB	81.0	81.0	81.5	81.9	82.7	82.2	81.8	81.8	81.8	81.8	81.9	81.6
		MCDB	89.2	89.5	90.2	90.2	90.9	89.9	89.3	89.6	89.5	89.4	90.0	89.7
	5%	WB	80.4	80.4	80.8	81.4	81.8	81.4	81.0	81.2	81.1	81.1	81.2	80.9
		MCDB	88.4	88.7	89.5	89.6	89.6	88.8	88.3	88.8	88.6	88.6	89.1	88.8
	10%	WB	79.7	79.8	80.1	80.8	81.1	80.7	80.4	80.6	80.4	80.5	80.6	80.3
		MCDB	87.2	87.7	88.3	88.8	88.5	87.8	87.4	88.0	87.7	87.7	88.2	87.7
Mean Daily Temperature Range	5% DB	MDBR	13.9	14.5	14.7	14.1	13.6	12.7	12.4	12.8	13.1	13.3	14.0	14.1
		MCDBR	15.6	15.9	16.4	15.8	15.4	14.7	14.2	14.4	14.7	15.2	16.0	15.6
		MCWBR	7.4	7.8	7.8	7.4	7.3	7.1	6.8	6.8	7.1	7.4	7.6	7.4
	5% WB	MCDBR	14.4	14.8	15.1	14.7	14.5	13.7	13.3	13.9	13.9	14.2	15.0	14.5
	MCWBR	7.4	7.7	7.6	7.4	7.4	7.1	6.8	7.0	7.1	7.3	7.7	7.3	
Clear-Sky Solar Irradiance	taub	0.419	0.425	0.427	0.439	0.411	0.402	0.404	0.432	0.430	0.442	0.417	0.418	
	taud	2.503	2.465	2.466	2.427	2.521	2.562	2.553	2.447	2.437	2.408	2.492	2.495	
	Ebn at Noon	285	285	285	277	279	278	278	275	279	277	283	283	
	Edh at Noon	35	37	37	38	34	32	32	36	37	38	35	34	
All-Sky Solar Radiation	RadAvg	1602	1782	1890	1878	1697	1556	1556	1634	1634	1611	1627	1578	
	RadStd	127	140	135	106	106	71	103	91	125	114	118	114	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-1.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page