

GENERAL SANTOS, Philippines

WMO: 988510

Lat: 6.0572N

Lon: 125.1030E

Elev: 436

StdP: 14.47

Time Zone: 8.00 (E08)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	73.0	73.4	68.6	106.7	76.4	69.4	110.0	76.1	13.3	87.8	12.0	87.7	2.0	270	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	15.8	95.0	81.1	93.8	80.8	92.8	80.7	82.7	91.8	82.2	91.0	81.7	90.4	8.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	159.0	88.9	79.7	156.8	88.5	79.2	153.9	88.1	47.0	92.2	46.4	91.5	45.9	90.8	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	11.9	10.8	DB	68.3	98.2	5.1	1.8	64.6	99.4	61.6	100.5	58.8	101.5	55.0	102.8	(4)
(5)			WB	66.6	84.0	3.3	0.9	64.2	84.6	62.2	85.2	60.4	85.7	57.9	86.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	81.9	82.5	83.5	84.2	83.2	81.9	81.3	81.6	81.9	82.4	82.8	82.9	(6)	
	DBStd	2.08	2.08	2.08	2.38	1.96	2.05	1.93	1.61	1.67	1.83	1.61	1.68	1.97	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	11862	990	911	1039	1025	1029	958	969	979	956	1005	983	1018	(10)	
	CDD65	6387	525	491	574	575	564	508	504	514	506	540	533	553	(11)	
	CDH74	67438	5295	5197	6428	6709	6202	5171	4946	5153	5145	5635	5672	5885	(12)	
	CDH80	26206	1963	2037	2772	2981	2492	1830	1652	1784	1883	2200	2281	2331	(13)	
(14) Wind	WSAvg	3.8	4.4	4.5	4.6	4.2	3.7	3.1	3.2	3.3	3.3	3.6	3.9	4.0	(14)	
(15) Precipitation	PrecAvg	41.6	4.2	2.4	2.5	2.4	3.5	4.4	4.0	3.9	3.6	3.9	3.5	3.2	(15)	
	PrecMax	57.2	10.4	8.2	6.1	6.1	9.2	9.2	7.8	8.9	9.4	7.2	7.4	6.6	(16)	
	PrecMin	26.1	0.6	0.5	0.2	0.3	0.9	1.8	1.1	0.9	1.5	0.7	1.1	0.8	(17)	
	PrecStd	8.7	2.4	1.6	1.5	1.5	1.7	1.9	1.7	1.9	1.7	1.9	1.8	1.7	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.9	94.6	96.2	96.7	95.4	93.6	91.9	92.2	93.6	94.1	94.5	94.8	(19)	
		MCWB	80.2	80.6	80.5	82.2	81.8	81.4	80.9	81.2	80.9	80.7	80.9	80.6	(20)	
	2%	DB	92.1	92.7	94.3	94.8	93.4	91.3	89.9	90.5	91.2	92.1	92.9	92.9	(21)	
		MCWB	79.8	80.3	80.5	81.5	81.3	81.0	80.5	80.8	80.9	80.8	80.7	80.2	(22)	
	5%	DB	90.5	91.3	92.8	93.2	91.5	89.7	88.6	89.1	89.6	90.5	91.4	91.3	(23)	
		MCWB	79.5	79.9	80.2	81.0	80.9	80.6	80.1	80.4	80.5	80.6	80.6	80.0	(24)	
	10%	DB	88.8	89.6	91.2	91.3	89.7	88.2	87.3	87.6	88.1	89.0	89.8	89.6	(25)	
		MCWB	79.2	79.5	80.0	80.7	80.6	80.1	79.7	79.8	80.1	80.2	80.2	79.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	82.6	82.7	83.4	82.8	82.7	82.0	82.3	82.6	82.8	82.7	82.5	(27)	
		MCDB	91.0	91.8	93.5	93.8	91.8	90.9	89.3	90.0	90.5	91.1	91.2	91.5	(28)	
	2%	WB	81.0	81.5	81.8	82.4	82.0	81.7	81.1	81.3	81.6	81.8	81.8	81.5	(29)	
		MCDB	89.6	90.4	92.1	92.4	90.8	89.6	88.4	89.0	89.3	90.0	90.3	90.2	(30)	
	5%	WB	80.2	80.7	81.0	81.6	81.4	80.9	80.5	80.7	80.8	81.0	81.1	80.7	(31)	
		MCDB	88.4	89.3	90.8	91.1	90.0	88.5	87.7	88.2	88.3	89.0	89.6	89.3	(32)	
	10%	WB	79.4	79.9	80.4	80.9	80.7	80.3	79.9	80.0	80.1	80.4	80.4	80.0	(33)	
		MCDB	87.1	88.1	89.6	89.9	89.0	87.4	86.6	87.0	87.2	88.1	88.7	88.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	14.4	15.7	15.8	14.3	13.1	12.7	13.0	13.9	14.8	15.2	14.6	(35)	
		MCDBR	17.0	17.1	18.3	18.5	17.0	15.6	14.7	15.2	15.8	16.9	17.4	17.1	(36)	
	5% WB	MCWBR	8.1	8.1	8.4	8.6	8.3	8.3	8.3	8.4	8.7	8.5	7.8	7.8	(37)	
		MCWBR	15.3	15.9	16.9	16.9	15.5	14.6	14.0	14.2	14.4	15.6	16.1	15.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.406	0.405	0.408	0.415	0.402	0.394	0.401	0.421	0.423	0.444	0.407	0.405	(40)	
		taud	2.505	2.487	2.487	2.465	2.510	2.546	2.514	2.437	2.416	2.357	2.490	2.500	(41)	
	Ebn at Noon	Ebn at Noon	290	292	290	283	281	280	279	278	281	277	287	287	(42)	
		Edh at Noon	35	36	36	36	34	32	33	37	38	41	35	34	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1459	1679	1797	1847	1704	1565	1558	1618	1707	1677	1570	1495	(44)	
	RadStd	RadStd	132	137	152	142	87	75	102	81	91	94	115	119	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.43	+0.49	N/A	+0.74	+0.81	+0.72	N/A	N/A	N/A	N/A

Nomenclature: See separate page