

HOTEL BUOY 44004, USA

WMO: 992070

Lat: 38.484N

Lon: 70.433W

Elev: 0

StdP: 101.33

Time Zone: -5.00 (W05)

Period: 94-09

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.6	0.3	N/A	N/A	N/A	N/A	N/A	N/A	18.8	7.1	17.7	6.8	11.2	300	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.0	28.0	N/A	27.7	N/A	27.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	15.1	13.9	DB	-2.2	27.4	1.7	1.2	-3.5	28.3	-4.5	29.0	-5.5	29.7	-6.7	30.5	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	10.0	9.3	10.4	12.7	15.6	20.4	23.9	24.5	22.6	19.2	15.0	12.4
	DBStd	6.52	5.46	5.01	4.46	4.11	2.73	2.63	1.76	1.72	2.34	3.57	4.28	4.57
	HDD10.0	235	69	66	48	19	0	0	0	0	0	0	6	27
	HDD18.3	1385	263	254	248	173	91	12	0	0	1	33	118	193
	CDD10.0	2561	68	48	61	101	175	311	432	448	378	284	155	101
	CDD18.3	669	4	2	3	4	7	73	173	190	128	59	17	8
	CDH23.3	2864	0	0	0	0	0	97	866	1139	490	218	52	2
	CDH26.7	193	0	0	0	0	0	0	39	78	60	16	0	0
Wind	WSAvg	7.2	8.8	8.7	8.2	7.5	6.6	5.7	5.4	5.7	6.1	7.2	7.6	8.5
Precipitation	PrecAvg	1853	185	169	189	147	134	108	129	137	133	148	167	208
	PrecMax	2377	305	275	289	241	233	197	246	241	289	222	273	323
	PrecMin	1376	111	99	89	75	50	33	54	48	28	67	39	114
	PrecStd	192	44	38	42	44	44	40	35	47	64	43	54	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	21.2	21.7	21.8	22.1	26.2	28.3	28.4	28.5	28.0	25.6	23.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	21.1	20.0	20.7	20.9	21.1	25.2	27.6	27.9	28.0	27.1	25.0	21.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	19.4	18.3	19.6	20.2	20.4	24.6	27.1	27.6	27.6	25.8	23.1	21.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.8	4.7	4.6	3.6	3.0	2.1	1.9	2.0	2.3	2.8	3.6	4.3
		MCDBR	3.6	3.7	3.7	3.0	3.1	1.7	2.1	1.8	1.4	2.1	2.1	3.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Clear-Sky Solar Irradiance	taub	0.354	0.366	0.372	0.408	0.444	0.463	0.477	0.458	0.405	0.385	0.358	0.350
taud		2.412	2.378	2.414	2.317	2.252	2.247	2.235	2.285	2.407	2.449	2.475	2.444	
Ebn at Noon		813	853	887	871	843	824	808	815	842	823	804	789	
Edh at Noon		87	101	108	126	137	138	138	128	107	94	81	79	
All-Sky Solar Radiation	RadAvg	1.50	2.28	3.49	4.83	5.70	6.21	6.06	5.58	4.54	3.26	2.02	1.37	
	RadStd	0.21	0.26	0.31	0.39	0.54	0.46	0.35	0.46	0.41	0.22	0.26	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page