

OREGON BUOY 46002, USA

WMO: 992160

Lat: 42.612N

Lon: 130.537W

Elev: 0

StdP: 14.70

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	43.5	44.6	N/A	N/A	N/A	N/A	N/A	N/A	36.7	49.8	34.2	49.4	19.5	320	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.3	67.3	N/A	66.4	N/A	65.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	13.5	0

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		Extreme Max WB	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
34.9	31.8	29.3	40.8	67.5	2.7	1.4	38.9	68.5	37.3	69.4	35.8	70.2	33.9	71.2		
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	51.3	49.7	49.1	50.1	52.5	55.9	60.1	63.1	63.2	60.1	56.3	52.6
	DBStd	5.56	2.82	2.71	2.69	2.22	2.36	2.21	2.23	1.90	1.69	2.56	2.87	2.84
	HDD50	144	20	34	49	26	5	0	0	0	0	0	1	9
	HDD65	3525	424	428	493	448	388	273	152	65	57	153	261	383
	CDD50	2103	61	26	21	28	82	177	313	406	397	312	190	90
	CDD65	9	0	0	0	0	0	0	0	5	3	1	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.0	18.2	17.9	16.0	15.8	13.8	14.6	13.9	13.7	15.3	16.0	18.1	19.3
Precipitation	PrecAvg	38.4	6.6	4.6	3.7	2.0	1.8	1.4	0.8	0.9	1.4	3.1	5.8	6.3
	PrecMax	48.4	12.0	8.7	5.5	4.3	4.8	3.1	2.7	2.9	4.9	8.1	9.6	10.6
	PrecMin	30.3	3.3	1.4	1.6	0.6	0.3	0.2	0.0	0.0	0.0	0.2	3.0	1.7
	PrecStd	4.4	2.2	1.9	1.0	0.9	1.1	0.9	0.8	0.9	1.1	2.1	1.6	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	57.2	56.5	56.2	59.0	63.0	66.4	68.4	68.0	66.5	63.1	60.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	56.5	55.7	55.5	55.0	57.7	61.3	65.0	67.5	66.9	65.5	62.2	59.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	55.8	54.7	53.9	54.1	56.7	60.0	64.1	66.8	66.3	64.5	61.4	58.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	55.2	53.5	52.8	53.3	55.9	59.1	63.3	66.1	65.7	63.7	60.5	57.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.2	3.1	3.3	2.8	2.5	2.3	2.3	2.4	2.3	2.9	3.6	3.9
		MCDBR	3.4	3.2	3.1	3.1	2.8	2.4	2.5	2.9	2.7	3.0	3.9	4.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.346	0.352	0.373	0.411	0.403	0.383	0.367	0.373	0.375	0.368	0.350	0.352	
	taud	2.449	2.450	2.403	2.264	2.340	2.459	2.535	2.530	2.488	2.466	2.467	2.390	
	Ebn at Noon	249	268	276	272	277	282	286	281	272	259	246	233	
	Edh at Noon	24	28	33	41	39	35	32	31	30	28	24	24	
All-Sky Solar Radiation	RadAvg	466	739	1102	1475	1697	1792	1711	1594	1363	915	549	398	
	RadStd	43	41	79	110	131	140	141	107	69	61	33	37	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page