

SOUTHEAST PAPA BUOY 46006, USA

WMO: 992200

Lat: 40.782N

Lon: 137.397W

Elev: 0

StdP: 101.33

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	7.0	7.6	N/A	N/A	N/A	N/A	N/A	N/A	19.0	8.8	17.6	9.3	9.8	330	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.5	20.6	N/A	20.2	N/A	19.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.6	15.2	14.0	DB	5.2	20.9	0.8	0.8	4.7	21.5	4.2	22.0	3.8	22.4	3.2	23.0	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.6	11.5	10.5	10.1	10.5	11.6	13.6	16.1	18.0	18.2	16.4	13.9	12.1
	DBStd	3.16	1.52	1.54	1.50	1.31	1.22	1.34	1.34	1.15	1.09	1.46	1.74	1.65
	HDD10.0	48	5	12	17	9	2	0	0	0	0	0	0	3
	HDD18.3	1764	211	219	254	233	209	142	69	21	16	62	134	193
	CDD10.0	1349	52	27	21	26	51	108	191	248	245	197	116	68
	CDD18.3	23	0	0	0	0	0	0	1	11	10	2	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.4	9.2	8.5	8.6	8.2	6.7	5.9	5.6	5.6	6.0	7.2	8.6	9.4
Precipitation	PrecAvg	1051	184	129	115	59	48	40	18	27	34	85	138	175
	PrecMax	1351	312	233	206	136	124	97	60	133	129	202	241	306
	PrecMin	728	62	23	29	9	7	5	0	1	1	10	77	62
	PrecStd	153	66	50	38	35	31	25	17	29	33	54	40	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	14.1	13.9	14.1	15.4	17.2	19.7	21.4	21.3	20.3	18.0	16.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	14.6	13.6	13.2	13.5	14.6	16.6	19.1	20.7	20.6	19.5	17.7	15.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	14.1	13.2	12.9	13.0	13.9	16.1	18.6	20.3	20.2	19.0	17.1	15.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	13.7	12.8	12.5	12.6	13.4	15.5	18.0	19.8	19.8	18.5	16.5	14.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.9	1.9	2.0	1.7	1.5	1.5	1.5	1.4	1.5	1.8	2.2	2.3
		MCDBR	2.2	2.1	2.2	1.9	1.7	1.7	1.6	1.7	1.8	2.2	2.7	2.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.354	0.366	0.391	0.436	0.418	0.385	0.377	0.374	0.375	0.365	0.361	0.363	
	taud	2.448	2.400	2.345	2.185	2.310	2.466	2.529	2.547	2.517	2.508	2.440	2.370	
	Ebn at Noon	795	840	857	838	861	889	894	889	866	833	778	742	
	Edh at Noon	80	96	113	142	128	110	102	98	94	86	80	80	
All-Sky Solar Radiation	RadAvg	1.56	2.39	3.37	4.46	5.06	5.35	5.39	5.13	4.33	3.02	1.84	1.35	
	RadStd	0.13	0.17	0.19	0.34	0.34	0.33	0.38	0.32	0.31	0.23	0.18	0.09	0.09

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page