

WASHINGTON BUOY 46005, USA

WMO: 992210

Lat: 46.134N

Lon: 131.079W

Elev: 0

StdP: 101.33

Time Zone: -9.00 (W09)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.2	5.0	N/A	N/A	N/A	N/A	N/A	N/A	17.5	7.6	16.1	7.3	9.5	340	0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.4	18.7	N/A	18.2	N/A	17.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	15.0	13.8	2.9	19.1	1.7	1.7	1.7	20.3	0.7	21.2	-0.3	22.2	-1.5	23.4		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	9.0	8.2	7.8	8.5	9.8	11.8	14.1	16.0	15.9	14.0	11.5	9.6
	DBStd	3.23	1.81	1.60	1.68	1.20	1.34	1.34	1.45	1.27	1.09	1.60	1.77	1.69
	HDD10.0	266	40	53	72	47	21	1	0	0	0	0	6	27
	HDD18.3	2541	290	282	327	295	266	195	130	74	74	134	204	270
	CDD10.0	767	9	3	3	2	13	56	128	185	176	124	52	15
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	7.4	8.5	8.0	7.9	7.2	6.3	6.3	6.1	6.0	6.6	8.0	9.0	9.5
(15) Precipitation	PrecAvg	1167	170	119	107	82	59	54	34	29	58	126	162	167
	PrecMax	1324	318	219	165	181	108	130	86	88	140	238	261	276
	PrecMin	1004	104	33	50	39	12	24	6	2	13	35	72	68
	PrecStd	80	46	44	32	30	23	24	18	23	28	50	43	53
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	12.9	12.8	12.4	13.2	16.8	17.9	19.6	19.0	18.5	16.3	14.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	12.5	11.9	11.9	11.6	12.6	15.6	17.2	19.0	18.4	17.8	15.5	13.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	11.9	11.3	10.8	10.7	12.2	14.5	16.7	18.5	18.0	16.9	14.8	13.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	11.4	10.4	10.1	10.2	11.7	13.7	16.1	18.0	17.6	16.4	14.1	11.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	1.9	1.7	1.8	1.5	1.3	1.3	1.3	1.4	1.4	1.8	2.1	2.1
		MCDBR	1.8	1.4	1.8	1.8	1.4	1.4	1.4	1.6	1.6	1.9	2.4	2.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.341	0.348	0.375	0.411	0.414	0.384	0.368	0.381	0.382	0.368	0.352	0.342
	taud		2.427	2.438	2.365	2.237	2.277	2.436	2.526	2.493	2.454	2.424	2.388	2.362
	Ebn at Noon		749	825	849	845	855	882	893	868	834	786	722	694
	Edh at Noon		72	85	105	130	129	111	100	100	96	85	74	69
(44) All-Sky Solar Radiation	RadAvg		1.11	1.97	3.12	4.49	5.14	5.43	5.02	4.74	3.82	2.44	1.35	0.97
	RadStd		0.10	0.16	0.22	0.29	0.32	0.44	0.40	0.32	0.20	0.16	0.09	0.10

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page