

CAPE SAN MARTIN BUOY 46028, USA

WMO: 992380

Lat: 35.774N

Lon: 121.905W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	48.2	49.4	N/A	N/A	N/A	N/A	N/A	N/A	36.5	51.6	35.0	52.1	16.5	320	0.708

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	2.7	64.5	N/A	63.7	N/A	62.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	11.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.6	31.8	30.1	DB	45.5	66.5	2.6	2.5	43.6	68.3	42.1	69.8	40.7	71.2	38.8	73.0	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.7	54.5	53.8	53.7	53.3	54.2	55.2	57.0	58.2	59.1	58.4	56.5	54.9	(6)	
(7)		DBStd	2.95	2.55	2.47	2.30	1.96	2.12	1.90	2.01	1.98	2.22	2.57	2.19	2.20	(7)	
(8)		HDD50	6	1	2	1	1	0	0	0	0	0	0	0	1	(8)	
(9)		HDD65	3380	325	313	351	350	335	295	249	212	178	204	254	314	(9)	
(10)		CDD50	2103	142	108	115	101	130	155	216	253	273	262	196	152	(10)	
(11)		CDD65	1	0	0	0	0	0	0	0	0	0	1	0	0	(11)	
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14)	Wind	WSAvg	15.2	13.1	14.5	15.6	17.7	19.0	18.5	14.4	15.1	13.9	14.0	13.7	13.1	(14)	
(15)	Precipitation	PrecAvg	17.6	3.5	3.4	2.6	1.2	0.6	0.1	0.0	0.1	0.9	1.8	3.3		(15)	
(16)		PrecMax	30.6	10.8	11.8	9.1	3.8	3.2	1.1	0.3	0.1	0.4	3.9	4.7	7.2	(16)	
(17)		PrecMin	7.6	0.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2	(17)	
(18)		PrecStd	5.6	2.6	2.5	2.2	0.9	0.7	0.2	0.1	0.0	0.1	1.1	1.1	2.0	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.8	60.6	60.7	60.9	61.5	61.8	64.6	64.7	66.0	67.0	63.3	62.1	(19)	
(20)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)
(21)		2%	DB	60.0	59.3	58.7	57.8	59.4	60.1	62.2	63.6	64.4	64.5	61.4	60.4	(21)	
(22)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)
(23)		5%	DB	58.8	58.3	57.6	56.8	58.4	59.1	61.0	62.3	63.4	63.5	60.5	58.9	(23)	
(24)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)
(25)		10%	DB	57.9	57.2	57.0	56.0	57.3	58.0	59.8	61.1	62.3	62.3	59.7	57.8	(25)	
(26)			MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
(28)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)
(29)		2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
(30)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)
(31)		5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
(32)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)
(33)		10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)
(34)			MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)
(35)	Mean Daily Temperature Range		MDBR	2.9	2.8	2.8	2.7	2.4	2.4	2.6	2.6	2.7	2.9	2.8	2.8	(35)	
(36)		5% DB	MCDBR	4.0	3.9	3.4	3.7	3.4	3.4	3.2	3.1	3.0	3.8	3.4	3.5	(36)	
(37)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)
(38)		5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)
(39)			MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.329	0.344	0.356	0.366	0.350	0.359	0.342	0.347	0.343	0.321	0.325	(40)		
(41)		taud	2.578	2.561	2.512	2.466	2.459	2.510	2.519	2.555	2.534	2.555	2.582	2.571	(41)		
(42)		Ebn at Noon	280	291	294	294	291	294	291	295	289	281	278	271	(42)		
(43)		Edh at Noon	24	28	32	35	36	34	33	31	30	27	24	23	(43)		
(44)	All-Sky Solar Radiation	RadAvg	872	1140	1570	1951	2135	2224	1922	1758	1644	1287	980	764	(44)		
(45)		RadStd	79	115	110	151	168	134	123	144	122	94	59	87	(45)		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (21 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-272	+304	+52	(47)

Nomenclature: See separate page