

CAPE SAN MARTIN BUOY 46028, USA

WMO: 992380

Lat: 35.774N

Lon: 121.905W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.0	9.6	N/A	N/A	N/A	N/A	N/A	N/A	16.3	10.9	15.6	11.2	7.4	320	0.708

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.5	18.1	N/A	17.6	N/A	17.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	14.2	13.5	DB	7.5	19.2	1.4	1.4	6.5	20.2	5.6	21.0	4.8	21.8	3.8	22.8	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	12.5	12.1	12.0	11.9	12.3	12.9	13.9	14.5	15.0	14.7	13.6	12.7
	DBStd	1.64	1.42	1.37	1.28	1.09	1.18	1.06	1.12	1.10	1.23	1.43	1.21	1.22
	HDD10.0	3	1	1	1	1	0	0	0	0	0	0	0	1
	HDD18.3	1878	181	174	195	194	186	164	138	118	99	113	141	174
	CDD10.0	1168	79	60	64	56	72	86	120	141	152	146	109	84
	CDD18.3	1	0	0	0	0	0	0	0	0	0	1	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.8	5.9	6.5	7.0	7.9	8.5	8.3	6.4	6.7	6.2	6.3	6.1	5.8
Precipitation	PrecAvg	448	90	87	67	31	16	3	1	1	2	23	45	83
	PrecMax	777	275	300	230	97	82	28	8	3	11	99	119	183
	PrecMin	192	11	1	1	2	0	0	0	0	0	5	5	5
	PrecStd	141	67	63	56	23	18	6	2	1	3	28	28	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.6	15.9	15.9	16.1	16.4	16.6	18.1	18.2	18.9	19.5	17.4	16.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	15.5	15.2	14.8	14.3	15.2	15.6	16.8	17.5	18.0	18.0	16.3	15.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	14.9	14.6	14.2	13.8	14.7	15.1	16.1	16.8	17.4	17.5	15.8	15.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	14.4	14.0	13.9	13.3	14.1	14.5	15.4	16.2	16.8	16.8	15.4	14.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.6	1.6	1.6	1.5	1.3	1.4	1.4	1.4	1.5	1.6	1.6	1.6
		MCDBR	2.2	2.2	1.9	2.0	1.9	1.9	1.8	1.7	1.7	2.1	1.9	1.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.321	0.329	0.344	0.356	0.366	0.350	0.359	0.342	0.347	0.343	0.321	0.325	
	taud	2.578	2.561	2.512	2.466	2.459	2.510	2.519	2.555	2.534	2.555	2.582	2.571	
	Ebn at Noon	884	916	928	927	917	928	917	930	911	887	876	855	
	Edh at Noon	77	87	100	109	112	106	105	99	96	86	76	73	
All-Sky Solar Radiation	RadAvg	2.75	3.59	4.95	6.15	6.73	7.01	6.06	5.54	5.18	4.06	3.09	2.41	
	RadStd	0.25	0.36	0.35	0.47	0.53	0.42	0.39	0.45	0.39	0.30	0.19	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-151	+169	+29

Nomenclature: See separate page