

MONTEREY BUOY 46042, USA

WMO: 992410

Lat: 36.785N

Lon: 122.398W

Elev: 0

StdP: 14.70

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	47.2	48.2	N/A	N/A	N/A	N/A	N/A	N/A	34.2	52.8	32.5	52.4	13.6	330	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.1	65.5	N/A	64.2	N/A	63.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.9	26.5	24.5	45.3	66.7	2.1	1.8	43.8	68.1	42.6	69.1	41.5	70.2	40.0	71.5		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.3	53.4	53.0	52.9	53.0	53.7	55.2	57.5	58.3	58.5	57.9	56.0	53.8
	DBStd	3.29	2.46	2.64	2.46	2.18	2.03	1.90	2.95	2.33	2.30	2.84	2.82	2.55
	HDD50	13	4	3	3	1	0	0	0	0	0	0	0	2
	HDD65	3547	359	336	374	360	350	295	233	207	196	220	269	348
	CDD50	1942	109	87	94	91	115	155	233	258	254	246	181	119
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	13.2	12.9	13.8	14.6	15.2	15.4	14.6	12.2	12.3	10.4	11.7	12.6	13.3
Precipitation	PrecAvg	28.7	5.4	5.4	3.4	2.2	0.9	0.3	0.1	0.1	0.1	1.6	3.2	6.3
	PrecMax	49.8	16.1	17.9	11.5	7.5	3.7	1.4	0.1	0.5	0.3	5.7	9.9	14.6
	PrecMin	11.3	0.0	0.0	0.0	0.3	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.3
	PrecStd	9.4	4.8	4.2	3.5	1.9	1.1	0.3	0.0	0.1	0.1	1.7	2.5	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.1	61.2	60.5	60.9	61.8	62.3	69.2	65.8	65.1	66.2	65.5	61.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	58.7	59.4	59.1	59.1	59.6	59.9	66.2	64.3	63.9	64.3	63.5	60.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	57.5	58.3	57.5	57.4	57.6	58.9	63.7	63.2	62.8	63.4	61.6	58.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	56.8	56.8	56.5	55.7	56.5	57.9	61.7	62.2	61.9	62.3	59.8	57.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.4	3.3	3.0	2.6	2.4	2.6	2.7	2.7	3.1	3.2	3.3	3.5
		MCDBR	3.8	4.5	3.8	3.7	3.7	3.9	4.3	3.1	3.5	4.3	3.9	3.9
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.320	0.330	0.335	0.360	0.372	0.360	0.365	0.343	0.352	0.333	0.316	0.320	
	taud	2.584	2.558	2.545	2.444	2.433	2.474	2.476	2.541	2.494	2.580	2.600	2.589	
	Ebn at Noon	279	289	297	292	289	291	288	294	286	284	278	271	
	Edh at Noon	24	28	30	35	36	35	35	32	31	26	23	23	
All-Sky Solar Radiation	RadAvg	808	1086	1526	1938	2125	2234	1947	1747	1611	1253	922	707	
	RadStd	89	117	117	153	166	140	106	146	108	85	54	89	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (34 neighbors)	+0.67	N/A	-2.16	N/A	N/A	N/A	N/A	-225	+252	N/A	

Nomenclature: See separate page