

MONTEREY BUOY 46042, USA

WMO: 992410

Lat: 36.785N

Lon: 122.398W

Elev: 0

StdP: 101.33

Time Zone: -8.00 (W08)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	8.5	9.0	N/A	N/A	N/A	N/A	N/A	N/A	15.3	11.6	14.5	11.3	6.1	330	0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	1.7	18.6	N/A	17.9	N/A	17.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.8	11.9	11.0	7.4	19.3	1.2	1.0	6.6	20.0	5.9	20.6	5.3	21.2	4.4	21.9		
			DB	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	11.9	11.7	11.6	11.7	12.1	12.9	14.2	14.6	14.7	14.4	13.4	12.1
	DBStd	1.83	1.37	1.46	1.37	1.21	1.13	1.06	1.64	1.30	1.28	1.58	1.57	1.42
	HDD10.0	7	2	2	2	1	0	0	0	0	0	0	0	1
	HDD18.3	1971	199	187	208	200	194	164	129	115	109	122	149	193
	CDD10.0	1079	61	48	52	51	64	86	129	143	141	137	101	66
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.9	5.8	6.2	6.5	6.8	6.9	6.5	5.5	5.5	4.7	5.2	5.6	5.9
Precipitation	PrecAvg	728	137	136	86	55	22	8	2	2	2	40	81	159
	PrecMax	1264	408	455	292	191	94	35	3	13	8	146	251	371
	PrecMin	287	0	0	0	7	0	2	1	1	0	1	6	7
	PrecStd	240	122	107	90	47	27	8	1	3	3	44	63	113
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.6	16.2	15.8	16.0	16.5	16.8	20.7	18.8	18.4	19.0	18.6	16.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	14.8	15.2	15.0	15.0	15.3	15.5	19.0	17.9	17.7	18.0	17.5	15.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	14.2	14.6	14.2	14.1	14.2	15.0	17.6	17.3	17.1	17.5	16.5	14.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	13.8	13.8	13.6	13.2	13.6	14.4	16.5	16.8	16.6	16.8	15.4	14.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.9	1.8	1.7	1.5	1.3	1.5	1.5	1.5	1.7	1.8	1.8	2.0
		MCDBR	2.1	2.5	2.1	2.1	2.1	2.2	2.4	1.7	2.0	2.4	2.2	2.1
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.320	0.330	0.335	0.360	0.372	0.360	0.365	0.343	0.352	0.333	0.316	0.320	
	taud	2.584	2.558	2.545	2.444	2.433	2.474	2.476	2.541	2.494	2.580	2.600	2.589	
	Ebn at Noon	878	910	935	921	911	918	909	927	902	895	876	853	
	Edh at Noon	75	87	95	111	115	110	109	100	99	83	73	71	
All-Sky Solar Radiation	RadAvg	2.55	3.42	4.81	6.11	6.70	7.04	6.14	5.51	5.08	3.95	2.91	2.23	
	RadStd	0.28	0.37	0.37	0.48	0.52	0.44	0.33	0.46	0.34	0.27	0.17	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	+0.37	N/A	-1.20	N/A	N/A	N/A	N/A	-125	+140	N/A

Nomenclature: See separate page