

EAST GULF BUOY 42003, USA

WMO: 992440

Lat: 25.925N

Lon: 85.615W

Elev: 0

StdP: 101.33

Time Zone: -6.00 (W06)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 14.4	(c) 15.6	(d) 5.9	(e) 5.8	(f) 15.2	(g) 7.1	(h) 6.2	(i) 16.0	(j) 15.8	(k) 19.2	(l) 14.9	(m) 19.4	(n) 8.3	(o) 350	(p) 0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 2.0	(c) 30.3	(d) 25.8	(e) 30.1	(f) 25.8	(g) 29.9	(h) 25.8	(i) 28.4	(j) 29.2	(k) 27.6	(l) 28.7	(m) 26.8	(n) 28.8	(o) 2.8	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.2	24.5	29.0	27.3	23.1	28.5	26.2	21.7	28.3	91.4	29.2	87.3	28.7	83.8	28.8	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years				
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	11.9	10.9	13.5	31.2	1.0	0.7	12.7	31.6	12.1	32.0	11.6	32.4	10.8	32.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	21.0	21.2	22.3	24.0	25.8	27.7	28.5	28.7	28.1	26.4	23.9	22.3
	DBStd	3.32	2.72	2.63	2.34	1.65	1.24	1.04	0.89	0.84	0.92	1.36	1.94	2.57
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	23	10	7	3	0	0	0	0	0	0	0	0	3
	CDD10.0	5479	339	312	382	420	491	530	572	581	543	509	418	382
	CDD18.3	2461	91	86	127	170	233	280	314	323	293	251	168	127
	CDH23.3	22335	206	212	392	858	1977	3206	3932	4179	3577	2399	913	485
CDH26.7	5816	1	0	1	6	132	878	1475	1712	1213	356	32	9	
Wind	WSAvg	6.0	7.1	6.7	6.9	6.3	5.6	4.5	3.9	4.2	5.4	6.7	7.2	7.1
Precipitation	PrecAvg	1074	98	81	91	88	58	104	70	98	141	107	62	75
	PrecMax	1674	291	260	270	204	145	340	195	233	444	314	199	207
	PrecMin	555	11	15	3	5	4	16	6	8	24	1	4	8
	PrecStd	272	64	59	65	47	41	87	39	59	100	73	49	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	26.3	26.7	27.4	28.5	30.2	30.7	30.8	30.5	29.6	28.0	27.5
		MCWB	23.9	23.8	24.2	24.5	24.9	25.8	26.1	25.7	25.7	24.7	24.8	24.1
	2%	DB	25.8	25.8	26.2	26.9	28.0	29.7	30.2	30.5	30.0	29.1	27.6	27.0
		MCWB	23.0	23.4	23.6	24.1	24.7	25.9	25.9	25.8	25.7	25.1	24.6	23.8
	5%	DB	25.2	25.3	25.7	26.5	27.8	29.4	30.0	30.2	29.7	28.6	27.0	26.1
		MCWB	22.5	23.1	23.1	23.8	24.6	25.8	25.9	25.8	25.7	25.4	23.9	23.1
	10%	DB	24.6	24.8	25.3	26.1	27.5	29.1	29.7	30.0	29.5	28.2	26.5	25.5
		MCWB	22.0	22.4	22.7	23.4	24.5	25.7	25.8	25.8	25.6	24.9	23.1	22.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	25.1	25.1	25.7	27.1	28.6	29.1	29.3	27.4	27.2	25.7	25.1
		MCDB	26.0	25.7	26.0	26.3	27.2	28.7	29.7	29.7	28.9	27.9	27.5	26.5
	2%	WB	23.8	24.1	24.3	25.2	26.2	28.0	28.2	28.6	26.8	26.6	25.2	24.5
		MCDB	25.1	25.4	25.8	26.3	26.7	28.5	29.2	29.5	28.9	28.0	27.4	26.5
	5%	WB	23.0	23.4	23.6	24.7	25.6	27.1	27.3	27.1	26.4	26.0	24.6	23.9
		MCDB	24.2	25.1	25.5	26.0	26.8	28.5	29.0	29.4	28.9	27.9	27.0	26.3
	10%	WB	22.3	22.6	22.9	24.0	25.2	26.5	26.5	26.5	26.2	25.4	23.8	23.2
		MCDB	23.9	24.5	25.1	25.6	26.8	28.6	29.2	29.4	28.8	27.7	26.5	25.7
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.5	2.2	1.9	1.5	1.6	1.9	2.0	2.0	1.6	1.9	2.2
		MCDBR	2.8	2.7	2.5	2.1	1.6	1.7	1.9	2.0	2.0	1.9	2.2	2.6
		MCWBR	3.2	3.5	2.5	2.2	1.7	1.5	1.5	1.6	1.7	2.0	2.3	2.8
	5% WB	MCDBR	2.5	3.0	2.4	2.1	1.5	1.6	1.7	2.1	2.2	1.9	2.3	2.8
MCWBR		3.5	3.9	2.8	2.8	2.0	1.9	2.0	2.2	1.8	2.0	2.6	3.3	
Clear-Sky Solar Irradiance	taub		0.368	0.379	0.385	0.408	0.425	0.436	0.453	0.436	0.422	0.406	0.376	0.369
	taud		2.517	2.496	2.466	2.399	2.376	2.426	2.376	2.446	2.453	2.472	2.517	2.537
	Ebn at Noon		885	900	911	892	871	855	840	856	863	861	869	868
	Edh at Noon		94	102	111	121	124	117	123	114	111	103	93	89
All-Sky Solar Radiation	RadAvg		3.44	4.34	5.41	6.44	6.91	6.53	6.46	6.11	5.26	4.75	3.85	3.27
	RadStd		0.39	0.46	0.45	0.32	0.38	0.47	0.34	0.30	0.37	0.33	0.32	0.31

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page