

BODEGA BAY BUOY 46013, CA, USAWMO: **992490**Lat: **38.253N**Lon: **123.303W**Elev: **0**StdP: **14.70**Time Zone: **-8.00 (W08)**Period: **94-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	45.4	46.4	N/A	N/A	N/A	N/A	N/A	N/A	38.2	49.2	36.4	49.8	13.8	330	0.734

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	3.3	62.0	N/A	60.7	N/A	59.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	10.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.8	32.7	30.8	43.4	65.3	2.0	2.2	42.0	66.9	40.8	68.1	39.7	69.4	38.3	70.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.1	52.0	51.9	51.5	51.3	51.6	52.6	53.8	55.0	55.5	55.3	53.9	52.2
	DBStd	2.79	2.38	2.55	2.39	1.87	1.88	1.80	2.31	2.26	2.46	2.61	2.43	2.89
	HDD50	57	9	10	12	8	5	1	0	0	0	1	1	10
	HDD65	4363	404	367	419	410	417	372	348	311	284	301	333	397
	CDD50	1169	70	63	58	47	53	79	117	154	167	165	118	78
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.6	13.5	14.6	15.5	16.3	18.6	18.4	13.9	13.9	11.9	12.3	12.5	13.7
Precipitation	PrecAvg	48.5	9.3	8.8	5.6	3.1	2.0	0.5	0.0	0.1	0.1	2.1	4.9	10.9
	PrecMax	75.2	28.3	27.0	17.2	10.5	7.0	2.5	0.2	1.3	0.5	5.7	12.6	24.6
	PrecMin	27.0	0.1	0.5	0.2	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.5
	PrecStd	14.4	6.7	6.5	5.0	2.6	2.2	0.7	0.0	0.3	0.1	1.6	3.6	7.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.3	59.2	58.6	57.7	58.2	58.7	61.3	62.6	64.3	63.3	61.7	60.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	57.0	57.6	56.9	55.5	56.1	57.3	59.7	61.0	62.0	61.6	59.7	59.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	56.1	56.5	55.8	54.7	55.2	56.4	58.6	59.7	60.0	60.3	58.6	57.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	55.4	55.4	54.9	53.9	54.3	55.4	57.4	58.5	59.0	59.1	57.4	56.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.7	3.3	3.2	2.8	2.6	2.7	3.1	3.3	3.3	3.3	3.6	3.9
		MCDBR	4.4	4.1	4.0	3.6	3.6	3.5	3.7	4.1	4.0	4.5	5.0	4.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.321	0.330	0.336	0.359	0.363	0.353	0.360	0.339	0.340	0.334	0.317	0.322	
	taud	2.573	2.547	2.537	2.434	2.456	2.487	2.476	2.540	2.513	2.573	2.595	2.571	
	Ebn at Noon	274	286	294	292	291	292	290	294	289	281	274	266	
	Edh at Noon	23	27	30	36	35	34	34	31	30	26	23	22	
All-Sky Solar Radiation	RadAvg	721	1015	1437	1889	2172	2354	2092	1833	1620	1214	849	620	
	RadStd	104	131	126	134	159	124	127	119	109	88	66	95	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (35 neighbors)	N/A	N/A	-2.12	N/A	N/A	N/A	N/A	N/A	+229	N/A

Nomenclature: See separate page